

Barricades (Rev. 0)

	YES	N/A	LOI OBSERVED
1.	<input type="checkbox"/>	<input type="checkbox"/>	Are barricades used properly (e.g; rigid/protective - 200# capacity for fall protection, Red & White rope for warning barricades?)
2.	<input type="checkbox"/>	<input type="checkbox"/>	Are barricades erected properly with tags or signs identifying hazards and a contact point for entry?
3.	<input type="checkbox"/>	<input type="checkbox"/>	Are barricades not in use removed or lowered?
4.	<input type="checkbox"/>	<input type="checkbox"/>	Are barricades provided with proper access points?
5.	<input type="checkbox"/>	<input type="checkbox"/>	Are rigid/protective barricades constructed properly and capable of withstanding 200# of horizontal force?
6.	<input type="checkbox"/>	<input type="checkbox"/>	Are open holes in grating or solid surfaces adequately covered and labeled (WARNING - TEMPORARY COVER - DO NOT REMOVE - UNLESS AUTHORIZED), or guarded with a rigid/protective barricade.
7.	<input type="checkbox"/>	<input type="checkbox"/>	Are rigid/protective barricades installed when working on platforms or building structures with a fall potential of 6 feet or greater?
8.	<input type="checkbox"/>	<input type="checkbox"/>	Are barricades used for fall protection/prevention, and equipment protection adequately illuminated for dark conditions?
9.	<input type="checkbox"/>	<input type="checkbox"/>	Are barricades or appropriate warning devices installed (e.g; high visibility flagging) while personnel are working on roofs?

Comments:

<hr/> <hr/> <hr/> <hr/>

Contractor: _____

P.O. Number: _____

Area/Location: _____

Project No: _____

Print Name_____
Signature_____
Date