

Fall Prevention & Protection

	YES	N/A	LOI OBSERVED
1.	<input type="checkbox"/>	<input type="checkbox"/>	Personal fall arrest system components (harness, lanyards, rope grabs, etc.) are inspected as required
2.	<input type="checkbox"/>	<input type="checkbox"/>	Personnel are provided fall protection whenever they are exposed to falls of Six (6) Feet or greater
3.	<input type="checkbox"/>	<input type="checkbox"/>	Personnel are using proper anchorages for fall arrest systems
4.	<input type="checkbox"/>	<input type="checkbox"/>	Guard rail systems in place where required to prevent fall exposure
5.	<input type="checkbox"/>	<input type="checkbox"/>	Personnel exposed to fall hazards are trained by a competent person familiar with Fall Protection methods, systems, equipment, and equipment use instructions.
6.	<input type="checkbox"/>	<input type="checkbox"/>	Hole covers secured in place and properly labeled
7.	<input type="checkbox"/>	<input type="checkbox"/>	Personnel are utilizing full body harness or belts, and attached to designed anchorage points within aerial lifting devices (JLGs, Man lifts)?
8.	<input type="checkbox"/>	<input type="checkbox"/>	Personnel working on scaffolds where fall protection is required are using proper fall protection or arrest systems
9.	<input type="checkbox"/>	<input type="checkbox"/>	Warning Barricades used to prevent access to fall hazards are located at least 6 feet away from the fall hazard and visible during darkness
10.	<input type="checkbox"/>	<input type="checkbox"/>	Documented record of training certification available at work site for employees using fall protection
11.	<input type="checkbox"/>	<input type="checkbox"/>	Personnel are using "Three Points of Contact" when utilizing ladders

Comments:

Contractor: _____

P.O. Number: _____

Area/Location: _____

Project No: _____

Print Name

Signature

Date