



FO12 - Barricades (Rev. 0)

	YES	N/A	LOI OBSERVED
1.			Are barricades used properly (e.g.; rigid/protective - 200# capacity for fall protection, Red & White rope for warning barricades?)
2.			Are barricades erected properly with tags or signs identifying hazards and a contact point for entry?
3.			Are barricades not in use removed or lowered?
4.			Are barricades provided with proper access points?
5.			Are rigid/protective barricades constructed properly and capable of withstanding 200# of horizontal force?
6.			Are open holes in grating or solid surfaces adequately covered and labeled (WARNING - TEMPORARY COVER - DO NOT REMOVE - UNLESS AUTHORIZED), or guarded with a rigid/protective barricade.
7.			Are rigid/protective barricades installed when working on platforms or building structures with a fall potential of 6 feet or greater?
8.			Are barricades used for fall protection/prevention, and equipment protection adequately illuminated for dark conditions?
9.			Are barricades or appropriate warning devices installed (e.g.; high visibility flagging) while personnel are working on roofs?

Comments:

Contractor: _____ **P.O. Number:** _____
Area/Location: _____ **Project No:** _____

Print Name **Signature** **Date**