

NOTE: (a) G-G std. < valid range

NOTE: (b) QC issue

NOTE: (c) Matrix interference in sample & trip blank

Data Table 4–8 2014 National Pollutant Discharge Elimination System Industrial Wastewater

Sample Measurement Section

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
A-01	Biochemical Oxygen Demand	1/9/2014	<	2.0	MG/L
A-01	Biochemical Oxygen Demand	2/11/2014	<	2.0	MG/L
A-01	Biochemical Oxygen Demand	2/11/2014	<	2.0	MG/L
A-01	Biochemical Oxygen Demand	3/11/2014	<	2.0	MG/L
A-01	Biochemical Oxygen Demand	4/2/2014	<	2.0	MG/L
A-01	Biochemical Oxygen Demand	5/6/2014 ^a		INVALID	MG/L
A-01	Biochemical Oxygen Demand	5/20/2014	<	2.0	MG/L
A-01	Biochemical Oxygen Demand	6/3/2014	<	2.0	MG/L
A-01	Biochemical Oxygen Demand	7/22/2014	<	2.0	MG/L
A-01	Biochemical Oxygen Demand	7/22/2014	<	2.0	MG/L
A-01	Biochemical Oxygen Demand	8/13/2014	<	2.0	MG/L
A-01	Biochemical Oxygen Demand	8/13/2014	<	2.0	MG/L
A-01	Biochemical Oxygen Demand	9/10/2014	<	2.0	MG/L
A-01	Biochemical Oxygen Demand	10/8/2014		2.4	MG/L
A-01	Biochemical Oxygen Demand	11/4/2014 ^b		INVALID	MG/L
A-01	Biochemical Oxygen Demand	11/12/2014	<	2.0	MG/L
A-01	Biochemical Oxygen Demand	11/19/2014	<	2.0	MG/L
A-01	Biochemical Oxygen Demand	12/2/2014	<	2.0	MG/L
A-01	Flow	1/1/2014		Holiday	GPD
A-01	Flow	1/2/2014		877,842	GPD
A-01	Flow	1/3/2014		859,826	GPD
A-01	Flow	1/6/2014		643,689	GPD
A-01	Flow	1/7/2014		584,906	GPD
A-01	Flow	1/8/2014		514,426	GPD
A-01	Flow	1/9/2014		546,315	GPD
A-01	Flow	1/10/2014		445,606	GPD
A-01	Flow	1/13/2014		1,292,862	GPD
A-01	Flow	1/14/2014		1,150,353	GPD
A-01	Flow	1/15/2014		837,757	GPD
A-01	Flow	1/16/2014		673,207	GPD
A-01	Flow	1/17/2014		659,530	GPD
A-01	Flow	1/20/2014		Holiday	GPD
A-01	Flow	1/21/2014		587,609	GPD
A-01	Flow	1/22/2014		516,662	GPD
A-01	Flow	1/23/2014		535,190	GPD
A-01	Flow	1/24/2014		583,403	GPD
A-01	Flow	1/27/2014		542,390	GPD
A-01	Flow	1/28/2014		563,936	GPD
A-01	Flow	1/29/2014		545,293	GPD
A-01	Flow	1/30/2014		559,325	GPD
A-01	Flow	1/31/2014		688,670	GPD
A-01	Flow	2/3/2014		629,053	GPD
A-01	Flow	2/4/2014		579,800	GPD
A-01	Flow	2/5/2014		618,776	GPD
A-01	Flow	2/6/2014		584,043	GPD
A-01	Flow	2/7/2014		624,658	GPD
A-01	Flow	2/10/2014		605,720	GPD
A-01	Flow	2/11/2014		686,073	GPD
A-01	Flow	2/12/2014		1,026,152	GPD
A-01	Flow	2/13/2014		1,559,555	GPD
A-01	Flow	2/14/2014		1,593,940	GPD
A-01	Flow	2/17/2014		Holiday	GPD
A-01	Flow	2/18/2014		1,340,886	GPD
A-01	Flow	2/19/2014		765,700	GPD
A-01	Flow	2/20/2014		617,136	GPD
A-01	Flow	2/21/2014		535,721	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
A-01	Flow	2/24/2014		748,498	GPD
A-01	Flow	2/25/2014		533,858	GPD
A-01	Flow	2/26/2014		507,001	GPD
A-01	Flow	2/27/2014		492,049	GPD
A-01	Flow	2/28/2014		414,353	GPD
A-01	Flow	3/3/2014		310,064	GPD
A-01	Flow	3/4/2014		232,063	GPD
A-01	Flow	3/5/2014		240,099	GPD
A-01	Flow	3/6/2014		277,357	GPD
A-01	Flow	3/7/2014		532,089	GPD
A-01	Flow	3/10/2014		719,329	GPD
A-01	Flow	3/11/2014		586,319	GPD
A-01	Flow	3/12/2014		594,174	GPD
A-01	Flow	3/13/2014		566,210	GPD
A-01	Flow	3/14/2014		530,711	GPD
A-01	Flow	3/17/2014		Not measured	GPD
A-01	Flow	3/18/2014		823,967	GPD
A-01	Flow	3/19/2014		1,002,887	GPD
A-01	Flow	3/20/2014		794,802	GPD
A-01	Flow	3/21/2014		955,948	GPD
A-01	Flow	3/24/2014		507,134	GPD
A-01	Flow	3/25/2014		502,967	GPD
A-01	Flow	3/26/2014		467,310	GPD
A-01	Flow	3/27/2014		504,379	GPD
A-01	Flow	3/28/2014		492,952	GPD
A-01	Flow	3/31/2014		572,223	GPD
A-01	Flow	4/1/2014		519,865	GPD
A-01	Flow	4/2/2014		571,110	GPD
A-01	Flow	4/3/2014		471,573	GPD
A-01	Flow	4/4/2014		544,169	GPD
A-01	Flow	4/7/2014		535,338	GPD
A-01	Flow	4/8/2014		1,319,178	GPD
A-01	Flow	4/9/2014		1,285,388	GPD
A-01	Flow	4/10/2014		837,103	GPD
A-01	Flow	4/11/2014		623,918	GPD
A-01	Flow	4/14/2014		543,774	GPD
A-01	Flow	4/15/2014		846,496	GPD
A-01	Flow	4/16/2014		1,115,136	GPD
A-01	Flow	4/17/2014		851,760	GPD
A-01	Flow	4/18/2014		Holiday	GPD
A-01	Flow	4/21/2014		1,189,601	GPD
A-01	Flow	4/22/2014		988,580	GPD
A-01	Flow	4/23/2014		600,010	GPD
A-01	Flow	4/24/2014		479,082	GPD
A-01	Flow	4/25/2014		376,463	GPD
A-01	Flow	4/28/2014		339,301	GPD
A-01	Flow	4/29/2014		368,542	GPD
A-01	Flow	4/30/2014		463,898	GPD
A-01	Flow	5/1/2014		648,210	GPD
A-01	Flow	5/2/2014		654,807	GPD
A-01	Flow	5/5/2014		466,046	GPD
A-01	Flow	5/6/2014		749,091	GPD
A-01	Flow	5/7/2014		518,432	GPD
A-01	Flow	5/8/2014		521,333	GPD
A-01	Flow	5/9/2014		561,516	GPD
A-01	Flow	5/12/2014		526,810	GPD
A-01	Flow	5/13/2014		615,872	GPD
A-01	Flow	5/14/2014		500,295	GPD
A-01	Flow	5/15/2014		663,552	GPD
A-01	Flow	5/16/2014		1,818,531	GPD
A-01	Flow	5/19/2014		1,061,392	GPD
A-01	Flow	5/20/2014		477,179	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
A-01	Flow	5/21/2014		457,298	GPD
A-01	Flow	5/22/2014		549,669	GPD
A-01	Flow	5/23/2014		561,047	GPD
A-01	Flow	5/26/2014		Holiday	GPD
A-01	Flow	5/27/2014		526,909	GPD
A-01	Flow	5/28/2014		620,487	GPD
A-01	Flow	5/29/2014		675,988	GPD
A-01	Flow	5/30/2014		622,504	GPD
A-01	Flow	6/2/2014		1,365,294	GPD
A-01	Flow	6/3/2014		1,524,378	GPD
A-01	Flow	6/4/2014		1,416,698	GPD
A-01	Flow	6/5/2014		1,235,059	GPD
A-01	Flow	6/6/2014		1,222,187	GPD
A-01	Flow	6/9/2014		864,764	GPD
A-01	Flow	6/10/2014		1,246,644	GPD
A-01	Flow	6/11/2014		1,218,744	GPD
A-01	Flow	6/12/2014		1,259,298	GPD
A-01	Flow	6/13/2014		1,432,571	GPD
A-01	Flow	6/16/2014		715,431	GPD
A-01	Flow	6/17/2014		539,120	GPD
A-01	Flow	6/18/2014		531,062	GPD
A-01	Flow	6/19/2014		441,799	GPD
A-01	Flow	6/20/2014		257,570	GPD
A-01	Flow	6/23/2014		164,530	GPD
A-01	Flow	6/24/2014		827,407	GPD
A-01	Flow	6/25/2014		1,013,692	GPD
A-01	Flow	6/26/2014		1,072,431	GPD
A-01	Flow	6/27/2014		846,423	GPD
A-01	Flow	6/30/2014		808,134	GPD
A-01	Flow	7/1/2014		1,560,310	GPD
A-01	Flow	7/2/2014		677,542	GPD
A-01	Flow	7/3/2014		598,131	GPD
A-01	Flow	7/4/2014		Holiday	GPD
A-01	Flow	7/7/2014		568,262	GPD
A-01	Flow	7/8/2014		676,018	GPD
A-01	Flow	7/9/2014		423,851	GPD
A-01	Flow	7/10/2014		386,790	GPD
A-01	Flow	7/11/2014		1,261,930	GPD
A-01	Flow	7/14/2014		1,247,412	GPD
A-01	Flow	7/15/2014		629,749	GPD
A-01	Flow	7/16/2014		823,814	GPD
A-01	Flow	7/17/2014		591,209	GPD
A-01	Flow	7/18/2014		519,151	GPD
A-01	Flow	7/21/2014		696,796	GPD
A-01	Flow	7/22/2014		970,911	GPD
A-01	Flow	7/23/2014		978,812	GPD
A-01	Flow	7/24/2014		766,930	GPD
A-01	Flow	7/25/2014		529,546	GPD
A-01	Flow	7/28/2014		665,952	GPD
A-01	Flow	7/29/2014		647,190	GPD
A-01	Flow	7/30/2014		570,896	GPD
A-01	Flow	7/31/2014		663,988	GPD
A-01	Flow	8/1/2014		614,532	GPD
A-01	Flow	8/4/2014		704,630	GPD
A-01	Flow	8/5/2014		647,350	GPD
A-01	Flow	8/6/2014		679,112	GPD
A-01	Flow	8/7/2014		485,458	GPD
A-01	Flow	8/8/2014		479,602	GPD
A-01	Flow	8/11/2014		926,041	GPD
A-01	Flow	8/12/2014		1,249,154	GPD
A-01	Flow	8/13/2014		1,275,800	GPD
A-01	Flow	8/14/2014		937,004	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
A-01	Flow	8/15/2014		539,344	GPD
A-01	Flow	8/18/2014		460,018	GPD
A-01	Flow	8/19/2014		661,200	GPD
A-01	Flow	8/20/2014		569,233	GPD
A-01	Flow	8/21/2014		494,014	GPD
A-01	Flow	8/22/2014		466,070	GPD
A-01	Flow	8/25/2014		449,954	GPD
A-01	Flow	8/26/2014		488,498	GPD
A-01	Flow	8/27/2014		475,497	GPD
A-01	Flow	8/28/2014		434,176	GPD
A-01	Flow	8/29/2014		586,911	GPD
A-01	Flow	9/1/2014		Holiday	GPD
A-01	Flow	9/2/2014		721,334	GPD
A-01	Flow	9/3/2014		892,216	GPD
A-01	Flow	9/4/2014		954,132	GPD
A-01	Flow	9/5/2014		1,171,378	GPD
A-01	Flow	9/8/2014		885,682	GPD
A-01	Flow	9/9/2014		1,237,643	GPD
A-01	Flow	9/10/2014		1,022,163	GPD
A-01	Flow	9/11/2014		781,685	GPD
A-01	Flow	9/12/2014		699,695	GPD
A-01	Flow	9/15/2014		1,087,045	GPD
A-01	Flow	9/16/2014		1,249,358	GPD
A-01	Flow	9/17/2014		1,254,802	GPD
A-01	Flow	9/18/2014		1,323,175	GPD
A-01	Flow	9/19/2014		1,713,613	GPD
A-01	Flow	9/22/2014		1,057,401	GPD
A-01	Flow	9/23/2014		809,260	GPD
A-01	Flow	9/24/2014		808,414	GPD
A-01	Flow	9/25/2014		770,655	GPD
A-01	Flow	9/26/2014		738,870	GPD
A-01	Flow	9/29/2014		659,561	GPD
A-01	Flow	9/30/2014		809,511	GPD
A-01	Flow	10/1/2014		673,487	GPD
A-01	Flow	10/2/2014		704,144	GPD
A-01	Flow	10/3/2014		677,272	GPD
A-01	Flow	10/6/2014		659,355	GPD
A-01	Flow	10/7/2014		733,922	GPD
A-01	Flow	10/8/2014		677,418	GPD
A-01	Flow	10/9/2014		660,962	GPD
A-01	Flow	10/10/2014		663,736	GPD
A-01	Flow	10/13/2014		670,286	GPD
A-01	Flow	10/14/2014		704,797	GPD
A-01	Flow	10/15/2014		806,807	GPD
A-01	Flow	10/16/2014		973,375	GPD
A-01	Flow	10/17/2014		730,171	GPD
A-01	Flow	10/20/2014		660,429	GPD
A-01	Flow	10/21/2014		702,065	GPD
A-01	Flow	10/22/2014		672,377	GPD
A-01	Flow	10/23/2014		639,671	GPD
A-01	Flow	10/24/2014		680,143	GPD
A-01	Flow	10/27/2014		643,553	GPD
A-01	Flow	10/28/2014		569,664	GPD
A-01	Flow	10/29/2014		577,570	GPD
A-01	Flow	10/30/2014		479,892	GPD
A-01	Flow	10/31/2014		468,688	GPD
A-01	Flow	11/3/2014		717,627	GPD
A-01	Flow	11/4/2014		542,681	GPD
A-01	Flow	11/5/2014		566,979	GPD
A-01	Flow	11/6/2014		590,846	GPD
A-01	Flow	11/7/2014		585,063	GPD
A-01	Flow	11/10/2014		596,999	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
A-01	Flow	11/11/2014		696,175	GPD
A-01	Flow	11/12/2014		645,023	GPD
A-01	Flow	11/13/2014		683,761	GPD
A-01	Flow	11/14/2014		655,790	GPD
A-01	Flow	11/17/2014		593,490	GPD
A-01	Flow	11/18/2014		705,484	GPD
A-01	Flow	11/19/2014		674,800	GPD
A-01	Flow	11/20/2014		686,856	GPD
A-01	Flow	11/21/2014		658,818	GPD
A-01	Flow	11/24/2014		956,133	GPD
A-01	Flow	11/25/2014		1,374,926	GPD
A-01	Flow	11/26/2014		1,447,690	GPD
A-01	Flow	11/27/2014		Holiday	GPD
A-01	Flow	11/28/2014		Holiday	GPD
A-01	Flow	12/1/2014		998,435	GPD
A-01	Flow	12/2/2014		643,680	GPD
A-01	Flow	12/3/2014		613,652	GPD
A-01	Flow	12/4/2014		635,279	GPD
A-01	Flow	12/5/2014		638,858	GPD
A-01	Flow	12/8/2014		618,143	GPD
A-01	Flow	12/9/2014		718,057	GPD
A-01	Flow	12/10/2014		657,526	GPD
A-01	Flow	12/11/2014		608,775	GPD
A-01	Flow	12/12/2014		624,010	GPD
A-01	Flow	12/15/2014		611,739	GPD
A-01	Flow	12/16/2014		641,185	GPD
A-01	Flow	12/17/2014		663,761	GPD
A-01	Flow	12/18/2014		678,985	GPD
A-01	Flow	12/19/2014		625,239	GPD
A-01	Flow	12/22/2014		671,582	GPD
A-01	Flow	12/23/2014		1,043,193	GPD
A-01	Flow	12/24/2014		Holiday	GPD
A-01	Flow	12/25/2014		Holiday	GPD
A-01	Flow	12/26/2014		1,854,199	GPD
A-01	Flow	12/29/2014		1,599,322	GPD
A-01	Flow	12/30/2014		1,398,568	GPD
A-01	Flow	12/31/2014		1,263,761	GPD
A-01	Iron	1/9/2014		0.0641	MG/L
A-01	Iron	2/11/2014		0.0966	MG/L
A-01	Iron	2/11/2014		0.0944	MG/L
A-01	Iron	3/11/2014		0.1416	MG/L
A-01	Iron	4/2/2014		0.1592	MG/L
A-01	Iron	5/6/2014		0.6767	MG/L
A-01	Iron	6/3/2014		0.5470	MG/L
A-01	Iron	7/22/2014		0.9535	MG/L
A-01	Iron	7/22/2014		1.0017	MG/L
A-01	Iron	8/13/2014		0.4572	MG/L
A-01	Iron	8/13/2014		0.4319	MG/L
A-01	Iron	9/10/2014		0.4129	MG/L
A-01	Iron	10/8/2014		0.1780	MG/L
A-01	Iron	11/4/2014		0.1519	MG/L
A-01	Iron	12/2/2014		0.1330	MG/L
A-01	Oil & Grease	1/8/2014	<	5.5	MG/L
A-01	Oil & Grease	2/10/2014	<	4.0	MG/L
A-01	Oil & Grease	2/10/2014	<	4.0	MG/L
A-01	Oil & Grease	3/10/2014	<	4.0	MG/L
A-01	Oil & Grease	4/1/2014	<	4.0	MG/L
A-01	Oil & Grease	5/5/2014	<	4.0	MG/L
A-01	Oil & Grease	6/3/2014	<	4.0	MG/L
A-01	Oil & Grease	7/21/2014	<	4.0	MG/L
A-01	Oil & Grease	7/21/2014	<	4.0	MG/L
A-01	Oil & Grease	8/13/2014	<	5.0	MG/L

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
A-01	Oil & Grease	8/13/2014	<	5.3	MG/L
A-01	Oil & Grease	9/9/2014	<	4.8	MG/L
A-01	Oil & Grease	10/7/2014	<	4.7	MG/L
A-01	Oil & Grease	11/3/2014	<	5.0	MG/L
A-01	Oil & Grease	12/2/2014	<	4.5	MG/L
A-01	pH	1/8/2014		7.2	SU
A-01	pH	2/10/2014		6.4	SU
A-01	pH	3/10/2014		6.1	SU
A-01	pH	4/1/2014		6.6	SU
A-01	pH	5/5/2014		5.9	SU
A-01	pH	6/3/2014		5.6	SU
A-01	pH	7/21/2014		7.2	SU
A-01	pH	8/13/2014		6.8	SU
A-01	pH	9/9/2014		6.6	SU
A-01	pH	10/7/2014		7.1	SU
A-01	pH	11/3/2014		7.6	SU
A-01	pH	12/2/2014		7.6	SU
A-01	Total Suspended Solids	1/9/2014	<	1.0	MG/L
A-01	Total Suspended Solids	2/11/2014		1.0	MG/L
A-01	Total Suspended Solids	2/11/2014		1.0	MG/L
A-01	Total Suspended Solids	3/11/2014		1.0	MG/L
A-01	Total Suspended Solids	4/2/2014	<	1.0	MG/L
A-01	Total Suspended Solids	5/6/2014		2.0	MG/L
A-01	Total Suspended Solids	6/3/2014		1.0	MG/L
A-01	Total Suspended Solids	7/22/2014		5.0	MG/L
A-01	Total Suspended Solids	7/22/2014		5.0	MG/L
A-01	Total Suspended Solids	8/13/2014		4.0	MG/L
A-01	Total Suspended Solids	8/13/2014		2.0	MG/L
A-01	Total Suspended Solids	9/10/2014		2.0	MG/L
A-01	Total Suspended Solids	10/8/2014		1.0	MG/L
A-01	Total Suspended Solids	11/4/2014		1.0	MG/L
A-01	Total Suspended Solids	12/2/2014	<	1.0	MG/L
A-11	Biochemical Oxygen Demand	1/9/2014	<	2.0	MG/L
A-11	Biochemical Oxygen Demand	1/9/2014	<	2.0	MG/L
A-11	Biochemical Oxygen Demand	2/11/2014		3.7	MG/L
A-11	Biochemical Oxygen Demand	3/11/2014		2.8	MG/L
A-11	Biochemical Oxygen Demand	4/8/2014	<	2.0	MG/L
A-11	Biochemical Oxygen Demand	5/6/2014 ^a		INVALID	MG/L
A-11	Biochemical Oxygen Demand	5/20/2014		4.7	MG/L
A-11	Biochemical Oxygen Demand	6/3/2014	<	2.0	MG/L
A-11	Biochemical Oxygen Demand	6/3/2014	<	2.0	MG/L
A-11	Biochemical Oxygen Demand	7/22/2014	<	2.0	MG/L
A-11	Biochemical Oxygen Demand	7/22/2014	<	2.0	MG/L
A-11	Biochemical Oxygen Demand	8/13/2014	<	2.0	MG/L
A-11	Biochemical Oxygen Demand	9/10/2014	<	2.0	MG/L
A-11	Biochemical Oxygen Demand	10/8/2014	<	2.0	MG/L
A-11	Biochemical Oxygen Demand	11/4/2014 ^b		INVALID	MG/L
A-11	Biochemical Oxygen Demand	11/12/2014	<	2.0	MG/L
A-11	Biochemical Oxygen Demand	12/2/2014	<	2.0	MG/L
A-11	Flow	1/8/2014		227	GPM
A-11	Flow	2/10/2014		208	GPM
A-11	Flow	3/10/2014		245	GPM
A-11	Flow	4/7/2014		259	GPM
A-11	Flow	5/5/2014		295	GPM
A-11	Flow	6/2/2014		262	GPM
A-11	Flow	7/21/2014		196	GPM
A-11	Flow	8/13/2014		219	GPM
A-11	Flow	9/9/2014		180	GPM
A-11	Flow	10/7/2014		178	GPM
A-11	Flow	11/3/2014		197	GPM
A-11	Flow	12/1/2014		176	GPM

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
A-11	Low Level Mercury	1/13/2014		0.00340	mG/L
A-11	Low Level Mercury	2/10/2014		0.00332	mG/L
A-11	Low Level Mercury	3/11/2014		0.00304	mG/L
A-11	Low Level Mercury	3/11/2014		0.00319	mG/L
A-11	Low Level Mercury	4/7/2014		0.00303	mG/L
A-11	Low Level Mercury	5/12/2014		0.00308	mG/L
A-11	Low Level Mercury	6/11/2014		0.00405	mG/L
A-11	Low Level Mercury	7/7/2014		0.00309	mG/L
A-11	Low Level Mercury	8/12/2014		0.00451	mG/L
A-11	Low Level Mercury	9/10/2014		0.00240	mG/L
A-11	Low Level Mercury	10/8/2014		0.00446	mG/L
A-11	Low Level Mercury	11/3/2014		0.00804	mG/L
A-11	Low Level Mercury	12/3/2014		0.00135	mG/L
A-11	pH	1/8/2014		7.0	SU
A-11	pH	2/10/2014		6.8	SU
A-11	pH	3/10/2014		7.1	SU
A-11	pH	4/7/2014		7.0	SU
A-11	pH	5/5/2014		6.9	SU
A-11	pH	6/2/2014		7.0	SU
A-11	pH	7/21/2014		7.1	SU
A-11	pH	8/13/2014		7.0	SU
A-11	pH	9/9/2014		7.4	SU
A-11	pH	10/7/2014		7.4	SU
A-11	pH	11/3/2014		7.3	SU
A-11	pH	12/1/2014		6.9	SU
A-11	Total Suspended Solids	1/9/2014	<	1.0	MG/L
A-11	Total Suspended Solids	1/9/2014	<	1.0	MG/L
A-11	Total Suspended Solids	2/11/2014	<	1.0	MG/L
A-11	Total Suspended Solids	3/11/2014	<	1.0	MG/L
A-11	Total Suspended Solids	4/8/2014	<	1.0	MG/L
A-11	Total Suspended Solids	5/6/2014	<	1.0	MG/L
A-11	Total Suspended Solids	6/3/2014	<	1.0	MG/L
A-11	Total Suspended Solids	6/3/2014	<	1.0	MG/L
A-11	Total Suspended Solids	7/22/2014	<	1.0	MG/L
A-11	Total Suspended Solids	7/22/2014		1.0	MG/L
A-11	Total Suspended Solids	8/13/2014	<	1.0	MG/L
A-11	Total Suspended Solids	9/10/2014	<	1.0	MG/L
A-11	Total Suspended Solids	10/8/2014	<	1.0	MG/L
A-11	Total Suspended Solids	11/4/2014	<	1.0	MG/L
A-11	Total Suspended Solids	12/2/2014	<	1.0	MG/L
A-1A	Flow	1/2/2014		0	GPM
A-1A	Flow	1/5/2014		0	GPM
A-1A	Flow	1/6/2014		0	GPM
A-1A	Flow	1/7/2014		0	GPM
A-1A	Flow	1/8/2014		0	GPM
A-1A	Flow	1/9/2014		0	GPM
A-1A	Flow	1/13/2014		0	GPM
A-1A	Flow	1/14/2014		0	GPM
A-1A	Flow	1/15/2014		0	GPM
A-1A	Flow	1/16/2014		232	GPM
A-1A	Flow	1/20/2014		0	GPM
A-1A	Flow	1/21/2014		0	GPM
A-1A	Flow	1/22/2014		0	GPM
A-1A	Flow	1/23/2014		0	GPM
A-1A	Flow	1/27/2014		0	GPM
A-1A	Flow	1/28/2014		0	GPM
A-1A	Flow	1/30/2014		0	GPM
A-1A	Flow	2/3/2014		0	GPM
A-1A	Flow	2/4/2014		0	GPM
A-1A	Flow	2/5/2014		0	GPM
A-1A	Flow	2/6/2014		0	GPM

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
A-1A	Flow	2/10/2014		269	GPM
A-1A	Flow	2/11/2014		0	GPM
A-1A	Flow	2/15/2014		0	GPM
A-1A	Flow	2/16/2014		0	GPM
A-1A	Flow	2/18/2014		0	GPM
A-1A	Flow	2/19/2014		0	GPM
A-1A	Flow	2/20/2014		0	GPM
A-1A	Flow	2/21/2014		0	GPM
A-1A	Flow	2/24/2014		0	GPM
A-1A	Flow	2/25/2014		0	GPM
A-1A	Flow	2/26/2014		0	GPM
A-1A	Flow	2/27/2014		0	GPM
A-1A	Flow	3/3/2014		0	GPM
A-1A	Flow	3/4/2014		0	GPM
A-1A	Flow	3/5/2014		0	GPM
A-1A	Flow	3/6/2014		0	GPM
A-1A	Flow	3/10/2014		0	GPM
A-1A	Flow	3/11/2014		0	GPM
A-1A	Flow	3/12/2014		0	GPM
A-1A	Flow	3/13/2014		0	GPM
A-1A	Flow	3/17/2014		0	GPM
A-1A	Flow	3/18/2014		0	GPM
A-1A	Flow	3/19/2014		0	GPM
A-1A	Flow	3/20/2014		0	GPM
A-1A	Flow	3/24/2014		0	GPM
A-1A	Flow	3/25/2014		0	GPM
A-1A	Flow	3/26/2014		0	GPM
A-1A	Flow	3/27/2014		0	GPM
A-1A	Flow	3/31/2014		0	GPM
A-1A	Flow	4/1/2014		0	GPM
A-1A	Flow	4/2/2014		0	GPM
A-1A	Flow	4/3/2014		0	GPM
A-1A	Flow	4/7/2014		0	GPM
A-1A	Flow	4/8/2014		0	GPM
A-1A	Flow	4/9/2014		0	GPM
A-1A	Flow	4/10/2014		0	GPM
A-1A	Flow	4/14/2014		225	GPM
A-1A	Flow	4/15/2014		0	GPM
A-1A	Flow	4/16/2014		0	GPM
A-1A	Flow	4/17/2014		0	GPM
A-1A	Flow	4/21/2014		0	GPM
A-1A	Flow	4/22/2014		0	GPM
A-1A	Flow	4/23/2014		0	GPM
A-1A	Flow	4/24/2014		0	GPM
A-1A	Flow	4/28/2014		0	GPM
A-1A	Flow	4/29/2014		0	GPM
A-1A	Flow	4/30/2014		0	GPM
A-1A	Flow	5/5/2014		0	GPM
A-1A	Flow	5/6/2014		0	GPM
A-1A	Flow	5/7/2014		0	GPM
A-1A	Flow	5/8/2014		0	GPM
A-1A	Flow	5/5/2014		0	GPM
A-1A	Flow	5/6/2014		0	GPM
A-1A	Flow	5/7/2014		0	GPM
A-1A	Flow	5/8/2014		0	GPM
A-1A	Flow	5/5/2014		0	GPM
A-1A	Flow	5/6/2014		0	GPM
A-1A	Flow	5/7/2014		0	GPM
A-1A	Flow	5/8/2014		0	GPM
A-1A	Flow	5/5/2014		0	GPM
A-1A	Flow	5/6/2014		0	GPM
A-1A	Flow	5/7/2014		0	GPM

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
A-1A	Flow	5/8/2014		0	GPM
A-1A	Flow	6/2/2014		0	GPM
A-1A	Flow	6/3/2014		0	GPM
A-1A	Flow	6/4/2014		0	GPM
A-1A	Flow	6/5/2014		0	GPM
A-1A	Flow	6/9/2014		0	GPM
A-1A	Flow	6/10/2014		0	GPM
A-1A	Flow	6/11/2014		0	GPM
A-1A	Flow	6/12/2014		0	GPM
A-1A	Flow	6/16/2014		0	GPM
A-1A	Flow	6/17/2014		0	GPM
A-1A	Flow	6/18/2014		0	GPM
A-1A	Flow	6/19/2014		0	GPM
A-1A	Flow	6/23/2014		0	GPM
A-1A	Flow	6/24/2014		0	GPM
A-1A	Flow	6/25/2014		0	GPM
A-1A	Flow	6/26/2014		0	GPM
A-1A	Flow	6/30/2014		0	GPM
A-1A	Flow	7/1/2014		0	GPM
A-1A	Flow	7/2/2014		0	GPM
A-1A	Flow	7/3/2014		0	GPM
A-1A	Flow	7/7/2014		0	GPM
A-1A	Flow	7/8/2014		0	GPM
A-1A	Flow	7/9/2014		0	GPM
A-1A	Flow	7/10/2014		0	GPM
A-1A	Flow	7/14/2014		0	GPM
A-1A	Flow	7/15/2014		0	GPM
A-1A	Flow	7/16/2014		0	GPM
A-1A	Flow	7/17/2014		0	GPM
A-1A	Flow	7/21/2014		0	GPM
A-1A	Flow	7/22/2014		0	GPM
A-1A	Flow	7/23/2014		0	GPM
A-1A	Flow	7/24/2014		0	GPM
A-1A	Flow	7/28/2014		0	GPM
A-1A	Flow	7/29/2014		0	GPM
A-1A	Flow	7/30/2014		0	GPM
A-1A	Flow	7/31/2014		0	GPM
A-1A	Flow	8/4/2014		185	GPM
A-1A	Flow	8/5/2014		0	GPM
A-1A	Flow	8/6/2014		0	GPM
A-1A	Flow	8/7/2014		0	GPM
A-1A	Flow	8/11/2014		0	GPM
A-1A	Flow	8/12/2014		0	GPM
A-1A	Flow	8/13/2014		0	GPM
A-1A	Flow	8/14/2014		0	GPM
A-1A	Flow	8/18/2014		0	GPM
A-1A	Flow	8/19/2014		0	GPM
A-1A	Flow	8/20/2014		0	GPM
A-1A	Flow	8/21/2014		0	GPM
A-1A	Flow	8/25/2014		0	GPM
A-1A	Flow	8/26/2014		0	GPM
A-1A	Flow	8/27/2014		0	GPM
A-1A	Flow	8/28/2014		0	GPM
A-1A	Flow	9/2/2014		0	GPM
A-1A	Flow	9/3/2014		0	GPM
A-1A	Flow	9/4/2014		0	GPM
A-1A	Flow	9/5/2014		0	GPM
A-1A	Flow	9/8/2014		0	GPM
A-1A	Flow	9/9/2014		0	GPM
A-1A	Flow	9/10/2014		0	GPM
A-1A	Flow	9/11/2014		0	GPM
A-1A	Flow	9/15/2014		0	GPM

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
A-1A	Flow	9/16/2014		0	GPM
A-1A	Flow	9/17/2014		0	GPM
A-1A	Flow	9/18/2014		0	GPM
A-1A	Flow	9/22/2014		0	GPM
A-1A	Flow	9/23/2014		0	GPM
A-1A	Flow	9/24/2014		0	GPM
A-1A	Flow	9/25/2014		0	GPM
A-1A	Flow	9/29/2014		0	GPM
A-1A	Flow	9/30/2014		0	GPM
A-1A	Flow	10/1/2014		0	GPM
A-1A	Flow	10/2/2014		0	GPM
A-1A	Flow	10/6/2014		0	GPM
A-1A	Flow	10/7/2014		0	GPM
A-1A	Flow	10/8/2014		0	GPM
A-1A	Flow	10/9/2014		0	GPM
A-1A	Flow	10/13/2014		0	GPM
A-1A	Flow	10/14/2014		0	GPM
A-1A	Flow	10/15/2014		0	GPM
A-1A	Flow	10/16/2014		0	GPM
A-1A	Flow	10/20/2014		0	GPM
A-1A	Flow	10/21/2014		0	GPM
A-1A	Flow	10/22/2014		0	GPM
A-1A	Flow	10/23/2014		0	GPM
A-1A	Flow	10/27/2014		0	GPM
A-1A	Flow	10/28/2014		185	GPM
A-1A	Flow	10/29/2014		0	GPM
A-1A	Flow	10/30/2014		0	GPM
A-1A	Flow	11/3/2014		0	GPM
A-1A	Flow	11/4/2014		0	GPM
A-1A	Flow	11/5/2014		0	GPM
A-1A	Flow	11/6/2014		0	GPM
A-1A	Flow	11/10/2014		0	GPM
A-1A	Flow	11/11/2014		0	GPM
A-1A	Flow	11/12/2014		184	GPM
A-1A	Flow	11/13/2014		0	GPM
A-1A	Flow	11/17/2014		0	GPM
A-1A	Flow	11/18/2014		0	GPM
A-1A	Flow	11/19/2014		0	GPM
A-1A	Flow	11/20/2014		0	GPM
A-1A	Flow	11/24/2014		0	GPM
A-1A	Flow	11/25/2014		0	GPM
A-1A	Flow	11/26/2014		0	GPM
A-1A	Flow	11/28/2014		0	GPM
A-1A	Flow	12/1/2014		148	GPM
A-1A	Flow	12/2/2014		0	GPM
A-1A	Flow	12/3/2014		0	GPM
A-1A	Flow	12/4/2014		0	GPM
A-1A	Flow	12/8/2014		0	GPM
A-1A	Flow	12/9/2014		0	GPM
A-1A	Flow	12/10/2014		0	GPM
A-1A	Flow	12/11/2014		0	GPM
A-1A	Flow	12/15/2014		0	GPM
A-1A	Flow	12/16/2014		0	GPM
A-1A	Flow	12/17/2014		0	GPM
A-1A	Flow	12/18/2014		0	GPM
A-1A	Flow	12/22/2014		0	GPM
A-1A	Flow	12/23/2014		0	GPM
A-1A	Flow	12/24/2014		0	GPM
A-1A	Flow	12/25/2014		0	GPM
A-1A	Flow	12/29/2014		0	GPM
A-1A	Flow	12/30/2014		0	GPM
A-1A	Flow	12/31/2014		0	GPM

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
A-1A	Tetrachloroethylene	1/16/2014	<	2	mG/L
A-1A	Tetrachloroethylene	2/10/2014	<	2	mG/L
A-1A	Tetrachloroethylene	3/11/2014		NF	mG/L
A-1A	Tetrachloroethylene	4/14/2014	<	2	mG/L
A-1A	Tetrachloroethylene	5/6/2014		NF	mG/L
A-1A	Tetrachloroethylene	6/9/2014		NF	mG/L
A-1A	Tetrachloroethylene	7/21/2014		NF	mG/L
A-1A	Tetrachloroethylene	8/4/2014	<	2	mG/L
A-1A	Tetrachloroethylene	9/3/2014		NF	mG/L
A-1A	Tetrachloroethylene	10/28/2014	<	2	mG/L
A-1A	Tetrachloroethylene	11/12/2014	<	2	mG/L
A-1A	Tetrachloroethylene	12/1/2014	<	2	mG/L
A-1A	Trichloroethylene	1/16/2014	<	2	mG/L
A-1A	Trichloroethylene	2/10/2014	<	2	mG/L
A-1A	Trichloroethylene	3/11/2014		NF	mG/L
A-1A	Trichloroethylene	4/14/2014	<	2	mG/L
A-1A	Trichloroethylene	5/6/2014		NF	mG/L
A-1A	Trichloroethylene	6/9/2014		NF	mG/L
A-1A	Trichloroethylene	7/21/2014		NF	mG/L
A-1A	Trichloroethylene	8/4/2014	<	2	mG/L
A-1A	Trichloroethylene	9/3/2014		NF	mG/L
A-1A	Trichloroethylene	10/28/2014	<	2	mG/L
A-1A	Trichloroethylene	11/12/2014	<	2	mG/L
A-1A	Trichloroethylene	12/1/2014	<	2	mG/L
D-01	Aluminum	1/2/2014		NF	MG/L
D-01	Aluminum	2/6/2014		NF	MG/L
D-01	Aluminum	3/6/2014		NF	MG/L
D-01	Aluminum	4/3/2014		NF	MG/L
D-01	Aluminum	5/1/2014		NF	MG/L
D-01	Aluminum	6/5/2014		NF	MG/L
D-01	Aluminum	7/1/2014		NF	MG/L
D-01	Aluminum	8/7/2014		0.1402	MG/L
D-01	Aluminum	9/4/2014		NF	MG/L
D-01	Aluminum	10/2/2014		NF	MG/L
D-01	Aluminum	11/6/2014		NF	MG/L
D-01	Aluminum	12/4/2014		NF	MG/L
D-01	Flow	1/2/2014		0	MGD
D-01	Flow	2/6/2014		0	MGD
D-01	Flow	3/6/2014		0	MGD
D-01	Flow	4/3/2014		0	MGD
D-01	Flow	5/1/2014		0	MGD
D-01	Flow	6/5/2014		0	MGD
D-01	Flow	7/1/2014		0	MGD
D-01	Flow	8/7/2014		1.5192	MGD
D-01	Flow	9/4/2014		0	MGD
D-01	Flow	10/2/2014		0	MGD
D-01	Flow	11/6/2014		0	MGD
D-01	Flow	12/4/2014		0	MGD
D-01	Manganese	1/2/2014		NF	MG/L
D-01	Manganese	2/6/2014		NF	MG/L
D-01	Manganese	3/6/2014		NF	MG/L
D-01	Manganese	4/3/2014		NF	MG/L
D-01	Manganese	5/1/2014		NF	MG/L
D-01	Manganese	6/5/2014		NF	MG/L
D-01	Manganese	7/1/2014		NF	MG/L
D-01	Manganese	8/7/2014		0.0695	MG/L
D-01	Manganese	9/4/2014		NF	MG/L
D-01	Manganese	10/2/2014		NF	MG/L
D-01	Manganese	11/6/2014		NF	MG/L
D-01	Manganese	12/4/2014		NF	MG/L
D-01	pH	1/2/2014		NF	SU
D-01	pH	2/6/2014		NF	SU

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
D-01	pH	3/6/2014		NF	SU
D-01	pH	4/3/2014		NF	SU
D-01	pH	5/1/2014		NF	SU
D-01	pH	6/5/2014		NF	SU
D-01	pH	7/1/2014		NF	SU
D-01	pH	8/7/2014		7.6	SU
D-01	pH	9/4/2014		NF	SU
D-01	pH	10/2/2014		NF	SU
D-01	pH	11/6/2014		NF	SU
D-01	pH	12/4/2014		NF	SU
D-01	Temperature	1/2/2014		N/A	°F
D-01	Temperature	2/6/2014		N/A	°F
D-01	Temperature	3/6/2014		N/A	°F
D-01	Temperature	4/3/2014		N/A	°F
D-01	Temperature	5/1/2014		N/A	°F
D-01	Temperature	6/5/2014		N/A	°F
D-01	Temperature	7/1/2014		N/A	°F
D-01	Temperature	8/7/2014		N/A	°F
D-01	Temperature	9/4/2014		N/A	°F
D-01	Temperature	10/2/2014		N/A	°F
D-01	Temperature	11/6/2014		N/A	°F
D-01	Temperature	12/4/2014		N/A	°F
D-01	Temperature Difference	1/2/2014		N/A	°F
D-01	Temperature Difference	2/6/2014		N/A	°F
D-01	Temperature Difference	3/6/2014		N/A	°F
D-01	Temperature Difference	4/3/2014		N/A	°F
D-01	Temperature Difference	5/1/2014		N/A	°F
D-01	Temperature Difference	6/5/2014		N/A	°F
D-01	Temperature Difference	7/1/2014		N/A	°F
D-01	Temperature Difference	8/7/2014		N/A	°F
D-01	Temperature Difference	9/4/2014		N/A	°F
D-01	Temperature Difference	10/2/2014		N/A	°F
D-01	Temperature Difference	11/6/2014		N/A	°F
D-01	Temperature Difference	12/4/2014		N/A	°F
D-01	Total Residual Chlorine	1/2/2014		N/A	MG/L
D-01	Total Residual Chlorine	2/6/2014		N/A	MG/L
D-01	Total Residual Chlorine	3/6/2014		N/A	MG/L
D-01	Total Residual Chlorine	4/3/2014		N/A	MG/L
D-01	Total Residual Chlorine	5/1/2014		N/A	MG/L
D-01	Total Residual Chlorine	6/5/2014		N/A	MG/L
D-01	Total Residual Chlorine	7/1/2014		N/A	MG/L
D-01	Total Residual Chlorine	8/7/2014		N/A	MG/L
D-01	Total Residual Chlorine	9/4/2014		N/A	MG/L
D-01	Total Residual Chlorine	10/2/2014		N/A	MG/L
D-01	Total Residual Chlorine	11/6/2014		N/A	MG/L
D-01	Total Residual Chlorine	12/4/2014		N/A	MG/L
D-01	Toxicity	3/6/2014		NF	Predicted % Reproduction Effect
D-01	Toxicity	3/6/2014		NF	Predicted % Survival Effect
D-01	Toxicity	4/3/2014		NF	Predicted % Reproduction Effect
D-01	Toxicity	4/3/2014		NF	Predicted % Survival Effect
D-01	Toxicity	7/8/2014		0	Predicted % Reproduction Effect
D-01	Toxicity	7/8/2014		29	Predicted % Survival Effect
D-01	Toxicity	7/21/2014		0	Predicted % Reproduction Effect
D-01	Toxicity	7/21/2014		10	Predicted % Survival Effect
D-01	Toxicity	10/2/2014		NF	Predicted % Reproduction Effect
D-01	Toxicity	10/2/2014		NF	Predicted % Survival Effect
D-02	Copper	6/30/2014	<	0.0050	MG/L
D-02	Copper	7/1/2014		NF	MG/L
D-02	Copper	10/2/2014		NF	MG/L
D-02	Flow	5/22/2014		0.03333	GPM
D-02	Flow	7/1/2014		0	GPM

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
D-02	Flow	10/2/2014		0	GPM
D-02	Nickel	6/30/2014	<	0.0100	MG/L
D-02	Nickel	7/1/2014		NF	MG/L
D-02	Nickel	10/2/2014		NF	MG/L
D-02	Oil & Grease	6/30/2014	<	4.8	MG/L
D-02	Oil & Grease	7/1/2014		NF	MG/L
D-02	Oil & Grease	10/2/2014		NF	MG/L
D-02	pH	6/30/2014		6.2	SU
D-02	pH	7/1/2014		NF	SU
D-02	pH	10/2/2014		NF	SU
D-02	Total Suspended Solids	6/30/2014		24.0	MG/L
D-02	Total Suspended Solids	7/1/2014		NF	MG/L
D-02	Total Suspended Solids	10/2/2014		NF	MG/L
D-02	Zinc	6/30/2014		0.0116	MG/L
D-02	Zinc	7/1/2014		NF	MG/L
D-02	Zinc	10/2/2014		NF	MG/L
D-02 (aka 002) first sampled 2nd quarter of 2014					
D-03 was rendered incapable of discharge in April 2009; no further discharges can be made. The following parameters were measured when a sample was collected at D-03: Aluminum, Copper, Flow, Nickel, Oil & Grease, pH, Total Residual Chlorine, Total Suspended Solids and Zinc. Since there was no flow from D-03 during 2014, no sample was collected.					
D-06 was rendered incapable of discharge in June 2012; no further discharges can be made. The following parameters were measured when a sample was collected at D-06: Aluminum, Copper, Flow, Nickel, Oil & Grease, pH, Total Residual Chlorine, Total Suspended Solids and Total Petroleum Hydrocarbons. Since there was no flow from D-06 during 2014, no sample was collected.					
The D-Area sanitary wastewater treatment plant was permanently closed in 2013 per a SCDHEC-approved closure plan. The following parameters were measured when a sample was collected at D-1A: Biological Oxygen Demand, Dissolved Oxygen, Fecal Coliform, Flow, pH and Total Suspended Solids. Since there was no flow from D-1A during 2014, no sample was collected.					
D-1B	Flow	1/2/2014		0	MGD
D-1B	Flow	2/6/2014		0	MGD
D-1B	Flow	3/6/2014		0	MGD
D-1B	Flow	4/3/2014		0	MGD
D-1B	Flow	5/1/2014		0	MGD
D-1B	Flow	6/5/2014		0	MGD
D-1B	Flow	7/1/2014		0	MGD
D-1B	Flow	8/7/2014		0	MGD
D-1B	Flow	9/8/2014		0	MGD
D-1B	Flow	10/2/2014		0	MGD
D-1B	Flow	11/6/2014		0	MGD
D-1B	Flow	12/4/2014		0	MGD
The following parameters are measured when a sample is collected at D-1B: Copper, Flow, Nickel, Oil & Grease, Total Suspended Solids and Zinc. Since there was no flow from D-1B during 2014, no sample was collected.					
D-1C	Flow	1/2/2014		0	MGD
D-1C	Flow	2/6/2014		0	MGD
D-1C	Flow	3/6/2014		0	MGD
D-1C	Flow	4/3/2014		0	MGD
D-1C	Flow	5/1/2014		0	MGD
D-1C	Flow	6/5/2014		0	MGD
D-1C	Flow	7/1/2014		0	MGD
D-1C	Flow	8/7/2014		1.5192	MGD
D-1C	Flow	9/4/2014		0	MGD
D-1C	Flow	10/2/2014		0	MGD
D-1C	Flow	11/6/2014		0	MGD
D-1C	Flow	12/4/2014		0	MGD
D-1C	Oil & Grease	1/2/2014		NF	MG/L
D-1C	Oil & Grease	2/6/2014		NF	MG/L
D-1C	Oil & Grease	3/6/2014		NF	MG/L
D-1C	Oil & Grease	4/3/2014		NF	MG/L
D-1C	Oil & Grease	5/1/2014		NF	MG/L

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
D-1C	Oil & Grease	6/5/2014		NF	MG/L
D-1C	Oil & Grease	7/1/2014		NF	MG/L
D-1C	Oil & Grease	8/7/2014	<	4.9	MG/L
D-1C	Oil & Grease	9/4/2014		NF	MG/L
D-1C	Oil & Grease	10/2/2014		NF	MG/L
D-1C	Oil & Grease	11/6/2014		NF	MG/L
D-1C	Oil & Grease	12/4/2014		NF	MG/L
D-1C	Total Suspended Solids	1/2/2014		NF	MG/L
D-1C	Total Suspended Solids	2/6/2014		NF	MG/L
D-1C	Total Suspended Solids	3/6/2014		NF	MG/L
D-1C	Total Suspended Solids	4/3/2014		NF	MG/L
D-1C	Total Suspended Solids	5/1/2014		NF	MG/L
D-1C	Total Suspended Solids	6/5/2014		NF	MG/L
D-1C	Total Suspended Solids	7/1/2014		NF	MG/L
D-1C	Total Suspended Solids	8/7/2014		2.0	MG/L
D-1C	Total Suspended Solids	9/4/2014		NF	MG/L
D-1C	Total Suspended Solids	10/2/2014		NF	MG/L
D-1C	Total Suspended Solids	11/6/2014		NF	MG/L
D-1C	Total Suspended Solids	12/4/2014		NF	MG/L
D-01D was rendered incapable of discharge in November 2013; no further discharges can be made. The following parameters were measured when a sample was collected at D-1D: Flow, Oil & Grease and Total Suspended Solids. Since there was no flow from D-1D during 2014, no sample was collected.					
F-01	Flow	1/27/2014		0	GPM
F-01	Flow	2/10/2014		0	GPM
F-01	Flow	3/4/2014		0	GPM
F-01	Flow	4/23/2014		0	GPM
F-01	Flow	5/28/2014		0	GPM
F-01	Flow	6/26/2014		0	GPM
F-01	Flow	7/23/2014		0	GPM
F-01	Flow	8/20/2014		0	GPM
F-01	Flow	9/3/2014		0	GPM
F-01	Flow	10/20/2014		0	GPM
F-01	Flow	11/20/2014		0	GPM
F-01	Flow	12/17/2014		0	GPM
The following parameters are measured when a sample is collected at F-01: Copper, Flow, pH, Total Suspended Solids and Zinc. Since there was no flow from F-01 during 2014, no sample was collected.					
F-02	Flow	1/27/2014		0	GPM
F-02	Flow	2/10/2014		0	GPM
F-02	Flow	3/4/2014		0	GPM
F-02	Flow	4/23/2014		0	GPM
F-02	Flow	5/28/2014		0	GPM
F-02	Flow	6/26/2014		0	GPM
F-02	Flow	7/23/2014		0	GPM
F-02	Flow	8/20/2014		0	GPM
F-02	Flow	9/3/2014		0	GPM
F-02	Flow	10/20/2014		0	GPM
F-02	Flow	11/20/2014		0	GPM
F-02	Flow	12/17/2014		0	GPM
The following parameters are measured when a sample is collected at F-02: Copper, Flow, pH and Zinc. Since there was no flow from F-02 during 2014, no sample was collected.					
F-05	Flow	1/27/2014		0	GPM
F-05	Flow	2/10/2014		0	GPM
F-05	Flow	3/4/2014		0	GPM
F-05	Flow	4/23/2014		0	GPM
F-05	Flow	5/28/2014		0	GPM
F-05	Flow	6/26/2014		0	GPM
F-05	Flow	7/23/2014		0	GPM
F-05	Flow	8/20/2014		0	GPM
F-05	Flow	9/3/2014		0	GPM
F-05	Flow	10/20/2014		0	GPM

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
F-05	Flow	11/20/2014		0	GPM
F-05	Flow	12/17/2014		0	GPM
The following parameters are measured when a sample is collected at F-05: Copper, Flow, Lead, Low-Level Mercury, pH, Total Suspended Solids and Zinc. Since there was no flow from F-05 during 2014, no sample was collected.					
F-08	Flow	1/22/2014		0	GPM
F-08	Flow	2/10/2014		0	GPM
F-08	Flow	3/19/2014		528.50	GPM
F-08	Flow	4/21/2014		20.07	GPM
F-08	Flow	5/12/2014		0	GPM
F-08	Flow	6/9/2014		15.42	GPM
F-08	Flow	7/23/2014		546.60	GPM
F-08	Flow	8/18/2014		0	GPM
F-08	Flow	9/16/2014		0	GPM
F-08	Flow	10/13/2014		0	GPM
F-08	Flow	11/18/2014		9.78	GPM
F-08	Flow	12/1/2014		46.55	GPM
F-08	Lead	1/22/2014		NF	MG/L
F-08	Lead	2/10/2014		NF	MG/L
F-08	Lead	3/20/2014	<	0.0020	MG/L
F-08	Lead	4/22/2014	<	0.0020	MG/L
F-08	Lead	5/12/2014		NF	MG/L
F-08	Lead	6/10/2014	<	0.0020	MG/L
F-08	Lead	7/24/2014	<	0.0020	MG/L
F-08	Lead	8/18/2014		NF	MG/L
F-08	Lead	9/16/2014		NF	MG/L
F-08	Lead	10/13/2014		NF	MG/L
F-08	Lead	11/19/2014	<	0.0020	MG/L
F-08	Lead	12/2/2014	<	0.0020	MG/L
F-08	pH	1/22/2014		NF	SU
F-08	pH	2/10/2014		NF	SU
F-08	pH	3/19/2014		7.7	SU
F-08	pH	4/21/2014		6.4	SU
F-08	pH	5/12/2014		NF	SU
F-08	pH	6/9/2014		6.3	SU
F-08	pH	7/23/2014		7.2	SU
F-08	pH	8/18/2014		NF	SU
F-08	pH	9/16/2014		NF	SU
F-08	pH	10/13/2014		NF	SU
F-08	pH	11/18/2014		6.7	SU
F-08	pH	12/1/2014		7.1	SU
F-08	Zinc	1/22/2014		NF	MG/L
F-08	Zinc	2/10/2014		NF	MG/L
F-08	Zinc	3/20/2014		0.2092	MG/L
F-08	Zinc	4/22/2014		0.1381	MG/L
F-08	Zinc	5/12/2014		NF	MG/L
F-08	Zinc	6/10/2014		0.0898	MG/L
F-08	Zinc	7/24/2014		0.0915	MG/L
F-08	Zinc	8/18/2014		NF	MG/L
F-08	Zinc	9/16/2014		NF	MG/L
F-08	Zinc	10/13/2014		NF	MG/L
F-08	Zinc	11/19/2014		0.0361	MG/L
F-08	Zinc	12/2/2014		0.0845	MG/L
G-10	Ammonia-Nitrogen	1/7/2014		0.31	MG/L
G-10	Ammonia-Nitrogen	1/14/2014		0.23	MG/L
G-10	Ammonia-Nitrogen	2/4/2014		0.17	MG/L
G-10	Ammonia-Nitrogen	2/11/2014		0.41	MG/L
G-10	Ammonia-Nitrogen	3/4/2014		0.51	MG/L
G-10	Ammonia-Nitrogen	3/11/2014		0.21	MG/L
G-10	Ammonia-Nitrogen	4/8/2014		0.32	MG/L
G-10	Ammonia-Nitrogen	4/15/2014		0.29	MG/L
G-10	Ammonia-Nitrogen	5/6/2014		0.13	MG/L

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
G-10	Ammonia-Nitrogen	5/13/2014		0.32	MG/L
G-10	Ammonia-Nitrogen	6/3/2014		0.15	MG/L
G-10	Ammonia-Nitrogen	6/10/2014		0.12	MG/L
G-10	Ammonia-Nitrogen	7/8/2014	<	0.10	MG/L
G-10	Ammonia-Nitrogen	7/15/2014	<	0.10	MG/L
G-10	Ammonia-Nitrogen	8/5/2014	<	0.10	MG/L
G-10	Ammonia-Nitrogen	8/12/2014	<	0.10	MG/L
G-10	Ammonia-Nitrogen	9/9/2014		0.33	MG/L
G-10	Ammonia-Nitrogen	9/16/2014		0.11	MG/L
G-10	Ammonia-Nitrogen	10/7/2014	<	0.10	MG/L
G-10	Ammonia-Nitrogen	10/14/2014	<	0.10	MG/L
G-10	Ammonia-Nitrogen	11/4/2014	<	0.10	MG/L
G-10	Ammonia-Nitrogen	11/11/2014	<	0.10	MG/L
G-10	Ammonia-Nitrogen	12/2/2014	<	0.10	MG/L
G-10	Ammonia-Nitrogen	12/9/2014	<	0.10	MG/L
G-10	Biochemical Oxygen Demand	1/7/2014	<	2.00	MG/L
G-10	Biochemical Oxygen Demand	1/14/2014	<	2.00	MG/L
G-10	Biochemical Oxygen Demand	2/4/2014		2.05	MG/L
G-10	Biochemical Oxygen Demand	2/11/2014	<	2.00	MG/L
G-10	Biochemical Oxygen Demand	3/4/2014	<	2.00	MG/L
G-10	Biochemical Oxygen Demand	3/11/2014	<	2.00	MG/L
G-10	Biochemical Oxygen Demand	4/8/2014		2.80	MG/L
G-10	Biochemical Oxygen Demand	4/15/2014		2.49	MG/L
G-10	Biochemical Oxygen Demand	5/6/2014	<	2.00	MG/L
G-10	Biochemical Oxygen Demand	5/13/2014	<	2.00	MG/L
G-10	Biochemical Oxygen Demand	6/3/2014	<	2.00	MG/L
G-10	Biochemical Oxygen Demand	6/10/2014	<	2.00	MG/L
G-10	Biochemical Oxygen Demand	7/8/2014	<	2.00	MG/L
G-10	Biochemical Oxygen Demand	7/15/2014	<	2.00	MG/L
G-10	Biochemical Oxygen Demand	8/5/2014		2.22	MG/L
G-10	Biochemical Oxygen Demand	8/12/2014	<	2.00	MG/L
G-10	Biochemical Oxygen Demand	9/9/2014		2.55	MG/L
G-10	Biochemical Oxygen Demand	9/16/2014	<	2.00	MG/L
G-10	Biochemical Oxygen Demand	10/7/2014	<	2.00	MG/L
G-10	Biochemical Oxygen Demand	10/14/2014	<	2.00	MG/L
G-10	Biochemical Oxygen Demand	11/4/2014		2.26	MG/L
G-10	Biochemical Oxygen Demand	11/11/2014		2.33	MG/L
G-10	Biochemical Oxygen Demand	12/2/2014	<	2.00	MG/L
G-10	Biochemical Oxygen Demand	12/9/2014		2.12	MG/L
G-10	Dissolved Oxygen	1/6/2014		11.04	MG/L
G-10	Dissolved Oxygen	1/13/2014		10.51	MG/L
G-10	Dissolved Oxygen	2/4/2014		9.92	MG/L
G-10	Dissolved Oxygen	2/10/2014		9.95	MG/L
G-10	Dissolved Oxygen	3/4/2014		9.68	MG/L
G-10	Dissolved Oxygen	3/10/2014		9.71	MG/L
G-10	Dissolved Oxygen	4/7/2014		8.70	MG/L
G-10	Dissolved Oxygen	4/17/2014		8.06	MG/L
G-10	Dissolved Oxygen	5/5/2014		8.72	MG/L
G-10	Dissolved Oxygen	5/13/2014		8.17	MG/L
G-10	Dissolved Oxygen	6/5/2014		7.40	MG/L
G-10	Dissolved Oxygen	6/11/2014		7.60	MG/L
G-10	Dissolved Oxygen	7/7/2014		7.73	MG/L
G-10	Dissolved Oxygen	7/23/2014		7.33	MG/L
G-10	Dissolved Oxygen	8/7/2014		7.61	MG/L
G-10	Dissolved Oxygen	8/15/2014		7.84	MG/L
G-10	Dissolved Oxygen	9/11/2014		7.72	MG/L
G-10	Dissolved Oxygen	9/18/2014		7.59	MG/L
G-10	Dissolved Oxygen	10/14/2014		7.88	MG/L
G-10	Dissolved Oxygen	10/21/2014		8.63	MG/L
G-10	Dissolved Oxygen	11/6/2014		9.14	MG/L
G-10	Dissolved Oxygen	11/13/2014		9.45	MG/L
G-10	Dissolved Oxygen	12/8/2014		9.86	MG/L

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
G-10	Dissolved Oxygen	12/15/2014		10.43	MG/L
G-10	Fecal Coliform	1/7/2014		4	COL/100ML
G-10	Fecal Coliform	1/13/2014	<	2	COL/100ML
G-10	Fecal Coliform	2/4/2014	<	2	COL/100ML
G-10	Fecal Coliform	2/10/2014		2	COL/100ML
G-10	Fecal Coliform	3/3/2014	<	2	COL/100ML
G-10	Fecal Coliform	3/10/2014		4	COL/100ML
G-10	Fecal Coliform	4/2/2014		2	COL/100ML
G-10	Fecal Coliform	4/7/2014		13	COL/100ML
G-10	Fecal Coliform	5/7/2014		23	COL/100ML
G-10	Fecal Coliform	5/12/2014		8	COL/100ML
G-10	Fecal Coliform	6/3/2014		2	COL/100ML
G-10	Fecal Coliform	6/9/2014	<	2	COL/100ML
G-10	Fecal Coliform	7/2/2014		2	COL/100ML
G-10	Fecal Coliform	7/8/2014		2	COL/100ML
G-10	Fecal Coliform	8/4/2014	<	2	COL/100ML
G-10	Fecal Coliform	8/11/2014	<	2	COL/100ML
G-10	Fecal Coliform	9/9/2014	<	2	COL/100ML
G-10	Fecal Coliform	9/16/2014	<	2	COL/100ML
G-10	Fecal Coliform	10/6/2014	<	2	COL/100ML
G-10	Fecal Coliform	10/13/2014	<	2	COL/100ML
G-10	Fecal Coliform	11/3/2014		2	COL/100ML
G-10	Fecal Coliform	11/10/2014		2	COL/100ML
G-10	Fecal Coliform	12/1/2014	<	2	COL/100ML
G-10	Fecal Coliform	12/8/2014		5	COL/100ML
G-10	Flow	1/1/2014		0.107	MGD
G-10	Flow	1/2/2014		0.209	MGD
G-10	Flow	1/3/2014		0.155	MGD
G-10	Flow	1/4/2014		0.132	MGD
G-10	Flow	1/5/2014		0.092	MGD
G-10	Flow	1/6/2014		0.224	MGD
G-10	Flow	1/7/2014		0.210	MGD
G-10	Flow	1/8/2014		0.239	MGD
G-10	Flow	1/9/2014		0.200	MGD
G-10	Flow	1/10/2014		0.223	MGD
G-10	Flow	1/11/2014		0.284	MGD
G-10	Flow	1/12/2014		0.148	MGD
G-10	Flow	1/13/2014		0.241	MGD
G-10	Flow	1/14/2014		0.244	MGD
G-10	Flow	1/15/2014		0.191	MGD
G-10	Flow	1/16/2014		0.197	MGD
G-10	Flow	1/17/2014		0.154	MGD
G-10	Flow	1/18/2014		0.111	MGD
G-10	Flow	1/19/2014		0.098	MGD
G-10	Flow	1/20/2014		0.117	MGD
G-10	Flow	1/21/2014		0.205	MGD
G-10	Flow	1/22/2014		0.185	MGD
G-10	Flow	1/23/2014		0.217	MGD
G-10	Flow	1/24/2014		0.129	MGD
G-10	Flow	1/25/2014		0.126	MGD
G-10	Flow	1/26/2014		0.134	MGD
G-10	Flow	1/27/2014		0.230	MGD
G-10	Flow	1/28/2014		0.226	MGD
G-10	Flow	1/29/2014		0.121	MGD
G-10	Flow	1/30/2014		0.186	MGD
G-10	Flow	1/31/2014		0.153	MGD
G-10	Flow	2/1/2014		0.115	MGD
G-10	Flow	2/2/2014		0.107	MGD
G-10	Flow	2/3/2014		0.168	MGD
G-10	Flow	2/4/2014		0.176	MGD
G-10	Flow	2/5/2014		0.148	MGD
G-10	Flow	2/6/2014		0.197	MGD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
G-10	Flow	2/7/2014		0.093	MGD
G-10	Flow	2/8/2014		0.082	MGD
G-10	Flow	2/9/2014		0.081	MGD
G-10	Flow	2/10/2014		0.202	MGD
G-10	Flow	2/11/2014		0.213	MGD
G-10	Flow	2/12/2014		0.340	MGD
G-10	Flow	2/13/2014		0.347	MGD
G-10	Flow	2/14/2014		0.301	MGD
G-10	Flow	2/15/2014		0.180	MGD
G-10	Flow	2/16/2014		0.143	MGD
G-10	Flow	2/17/2014		0.161	MGD
G-10	Flow	2/18/2014		0.208	MGD
G-10	Flow	2/19/2014		0.201	MGD
G-10	Flow	2/20/2014		0.193	MGD
G-10	Flow	2/21/2014		0.228	MGD
G-10	Flow	2/22/2014		0.148	MGD
G-10	Flow	2/23/2014		0.143	MGD
G-10	Flow	2/24/2014		0.194	MGD
G-10	Flow	2/25/2014		0.186	MGD
G-10	Flow	2/26/2014		0.237	MGD
G-10	Flow	2/27/2014		0.162	MGD
G-10	Flow	2/28/2014		0.138	MGD
G-10	Flow	3/1/2014		0.108	MGD
G-10	Flow	3/2/2014		0.091	MGD
G-10	Flow	3/3/2014		0.175	MGD
G-10	Flow	3/4/2014		0.156	MGD
G-10	Flow	3/5/2014		0.148	MGD
G-10	Flow	3/6/2014		0.225	MGD
G-10	Flow	3/7/2014		0.131	MGD
G-10	Flow	3/8/2014		0.117	MGD
G-10	Flow	3/9/2014		0.101	MGD
G-10	Flow	3/10/2014		0.173	MGD
G-10	Flow	3/11/2014		0.175	MGD
G-10	Flow	3/12/2014		0.180	MGD
G-10	Flow	3/13/2014		0.146	MGD
G-10	Flow	3/14/2014		0.139	MGD
G-10	Flow	3/15/2014		0.113	MGD
G-10	Flow	3/16/2014		0.225	MGD
G-10	Flow	3/17/2014		0.224	MGD
G-10	Flow	3/18/2014		0.227	MGD
G-10	Flow	3/19/2014		0.221	MGD
G-10	Flow	3/20/2014		0.200	MGD
G-10	Flow	3/21/2014		0.132	MGD
G-10	Flow	3/22/2014		0.073	MGD
G-10	Flow	3/23/2014		0.073	MGD
G-10	Flow	3/24/2014		0.178	MGD
G-10	Flow	3/25/2014		0.190	MGD
G-10	Flow	3/26/2014		0.160	MGD
G-10	Flow	3/27/2014		0.184	MGD
G-10	Flow	3/28/2014		0.139	MGD
G-10	Flow	3/29/2014		0.092	MGD
G-10	Flow	3/30/2014		0.088	MGD
G-10	Flow	3/31/2014		0.154	MGD
G-10	Flow	4/1/2014		0.165	MGD
G-10	Flow	4/2/2014		0.170	MGD
G-10	Flow	4/3/2014		0.168	MGD
G-10	Flow	4/4/2014		0.089	MGD
G-10	Flow	4/5/2014		0.067	MGD
G-10	Flow	4/6/2014		0.075	MGD
G-10	Flow	4/7/2014		0.234	MGD
G-10	Flow	4/8/2014		0.177	MGD
G-10	Flow	4/9/2014		0.157	MGD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
G-10	Flow	4/10/2014		0.146	MGD
G-10	Flow	4/11/2014		0.176	MGD
G-10	Flow	4/12/2014		0.058	MGD
G-10	Flow	4/13/2014		0.074	MGD
G-10	Flow	4/14/2014		0.146	MGD
G-10	Flow	4/15/2014		0.195	MGD
G-10	Flow	4/16/2014		0.169	MGD
G-10	Flow	4/17/2014		0.139	MGD
G-10	Flow	4/18/2014		0.225	MGD
G-10	Flow	4/19/2014		0.260	MGD
G-10	Flow	4/20/2014		0.120	MGD
G-10	Flow	4/21/2014		0.212	MGD
G-10	Flow	4/22/2014		0.207	MGD
G-10	Flow	4/23/2014		0.192	MGD
G-10	Flow	4/24/2014		0.182	MGD
G-10	Flow	4/25/2014		0.114	MGD
G-10	Flow	4/26/2014		0.075	MGD
G-10	Flow	4/27/2014		0.097	MGD
G-10	Flow	4/28/2014		0.207	MGD
G-10	Flow	4/29/2014		0.188	MGD
G-10	Flow	4/30/2014		0.199	MGD
G-10	Flow	5/1/2014		0.167	MGD
G-10	Flow	5/2/2014		0.115	MGD
G-10	Flow	5/3/2014		0.094	MGD
G-10	Flow	5/4/2014		0.087	MGD
G-10	Flow	5/5/2014		0.182	MGD
G-10	Flow	5/6/2014		0.144	MGD
G-10	Flow	5/7/2014		0.174	MGD
G-10	Flow	5/8/2014		0.179	MGD
G-10	Flow	5/9/2014		0.143	MGD
G-10	Flow	5/10/2014		0.121	MGD
G-10	Flow	5/11/2014		0.091	MGD
G-10	Flow	5/12/2014		0.182	MGD
G-10	Flow	5/13/2014		0.187	MGD
G-10	Flow	5/14/2014		0.203	MGD
G-10	Flow	5/15/2014		0.289	MGD
G-10	Flow	5/16/2014		0.214	MGD
G-10	Flow	5/17/2014		0.122	MGD
G-10	Flow	5/18/2014		0.068	MGD
G-10	Flow	5/19/2014		0.170	MGD
G-10	Flow	5/20/2014		0.169	MGD
G-10	Flow	5/21/2014		0.188	MGD
G-10	Flow	5/22/2014		0.175	MGD
G-10	Flow	5/23/2014		0.103	MGD
G-10	Flow	5/24/2014		0.096	MGD
G-10	Flow	5/25/2014		0.096	MGD
G-10	Flow	5/26/2014		0.093	MGD
G-10	Flow	5/27/2014		0.182	MGD
G-10	Flow	5/28/2014		0.201	MGD
G-10	Flow	5/29/2014		0.201	MGD
G-10	Flow	5/30/2014		0.120	MGD
G-10	Flow	5/31/2014		0.257	MGD
G-10	Flow	6/1/2014		0.151	MGD
G-10	Flow	6/2/2014		0.230	MGD
G-10	Flow	6/3/2014		0.247	MGD
G-10	Flow	6/4/2014		0.353	MGD
G-10	Flow	6/5/2014		0.196	MGD
G-10	Flow	6/6/2014		0.169	MGD
G-10	Flow	6/7/2014		0.216	MGD
G-10	Flow	6/8/2014		0.213	MGD
G-10	Flow	6/9/2014		0.218	MGD
G-10	Flow	6/10/2014		0.212	MGD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
G-10	Flow	6/11/2014		0.249	MGD
G-10	Flow	6/12/2014		0.298	MGD
G-10	Flow	6/13/2014		0.193	MGD
G-10	Flow	6/14/2014		0.111	MGD
G-10	Flow	6/15/2014		0.089	MGD
G-10	Flow	6/16/2014		0.197	MGD
G-10	Flow	6/17/2014		0.189	MGD
G-10	Flow	6/18/2014		0.176	MGD
G-10	Flow	6/19/2014		0.190	MGD
G-10	Flow	6/20/2014		0.109	MGD
G-10	Flow	6/21/2014		0.095	MGD
G-10	Flow	6/22/2014		0.085	MGD
G-10	Flow	6/23/2014		0.239	MGD
G-10	Flow	6/24/2014		0.166	MGD
G-10	Flow	6/25/2014		0.229	MGD
G-10	Flow	6/26/2014		0.160	MGD
G-10	Flow	6/27/2014		0.088	MGD
G-10	Flow	6/28/2014		0.131	MGD
G-10	Flow	6/29/2014		0.123	MGD
G-10	Flow	6/30/2014		0.152	MGD
G-10	Flow	7/1/2014		0.156	MGD
G-10	Flow	7/2/2014		0.169	MGD
G-10	Flow	7/3/2014		0.092	MGD
G-10	Flow	7/4/2014		0.077	MGD
G-10	Flow	7/5/2014		0.069	MGD
G-10	Flow	7/6/2014		0.069	MGD
G-10	Flow	7/7/2014		0.169	MGD
G-10	Flow	7/8/2014		0.148	MGD
G-10	Flow	7/9/2014		0.156	MGD
G-10	Flow	7/10/2014		0.238	MGD
G-10	Flow	7/11/2014		0.138	MGD
G-10	Flow	7/12/2014		0.094	MGD
G-10	Flow	7/13/2014		0.073	MGD
G-10	Flow	7/14/2014		0.174	MGD
G-10	Flow	7/15/2014		0.171	MGD
G-10	Flow	7/16/2014		0.171	MGD
G-10	Flow	7/17/2014		0.174	MGD
G-10	Flow	7/18/2014		0.086	MGD
G-10	Flow	7/19/2014		0.146	MGD
G-10	Flow	7/20/2014		0.101	MGD
G-10	Flow	7/21/2014		0.264	MGD
G-10	Flow	7/22/2014		0.228	MGD
G-10	Flow	7/23/2014		0.193	MGD
G-10	Flow	7/24/2014		0.176	MGD
G-10	Flow	7/25/2014		0.223	MGD
G-10	Flow	7/26/2014		0.107	MGD
G-10	Flow	7/27/2014		0.106	MGD
G-10	Flow	7/28/2014		0.198	MGD
G-10	Flow	7/29/2014		0.184	MGD
G-10	Flow	7/30/2014		0.169	MGD
G-10	Flow	7/31/2014		0.168	MGD
G-10	Flow	8/1/2014		0.109	MGD
G-10	Flow	8/2/2014		0.155	MGD
G-10	Flow	8/3/2014		0.105	MGD
G-10	Flow	8/4/2014		0.160	MGD
G-10	Flow	8/5/2014		0.209	MGD
G-10	Flow	8/6/2014		0.182	MGD
G-10	Flow	8/7/2014		0.180	MGD
G-10	Flow	8/8/2014		0.171	MGD
G-10	Flow	8/9/2014		0.162	MGD
G-10	Flow	8/10/2014		0.176	MGD
G-10	Flow	8/11/2014		0.247	MGD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
G-10	Flow	8/12/2014		0.222	MGD
G-10	Flow	8/13/2014		0.199	MGD
G-10	Flow	8/14/2014		0.180	MGD
G-10	Flow	8/15/2014		0.136	MGD
G-10	Flow	8/16/2014		0.105	MGD
G-10	Flow	8/17/2014		0.098	MGD
G-10	Flow	8/18/2014		0.202	MGD
G-10	Flow	8/19/2014		0.260	MGD
G-10	Flow	8/20/2014		0.191	MGD
G-10	Flow	8/21/2014		0.214	MGD
G-10	Flow	8/22/2014		0.121	MGD
G-10	Flow	8/23/2014		0.123	MGD
G-10	Flow	8/24/2014		0.084	MGD
G-10	Flow	8/25/2014		0.192	MGD
G-10	Flow	8/26/2014		0.220	MGD
G-10	Flow	8/27/2014		0.220	MGD
G-10	Flow	8/28/2014		0.187	MGD
G-10	Flow	8/29/2014		0.151	MGD
G-10	Flow	8/30/2014		0.084	MGD
G-10	Flow	8/31/2014		0.080	MGD
G-10	Flow	9/1/2014		0.114	MGD
G-10	Flow	9/2/2014		0.180	MGD
G-10	Flow	9/3/2014		0.217	MGD
G-10	Flow	9/4/2014		0.184	MGD
G-10	Flow	9/5/2014		0.114	MGD
G-10	Flow	9/6/2014		0.129	MGD
G-10	Flow	9/7/2014		0.160	MGD
G-10	Flow	9/8/2014		0.229	MGD
G-10	Flow	9/9/2014		0.197	MGD
G-10	Flow	9/10/2014		0.175	MGD
G-10	Flow	9/11/2014		0.182	MGD
G-10	Flow	9/12/2014		0.163	MGD
G-10	Flow	9/13/2014		0.119	MGD
G-10	Flow	9/14/2014		0.151	MGD
G-10	Flow	9/15/2014		0.204	MGD
G-10	Flow	9/16/2014		0.247	MGD
G-10	Flow	9/17/2014		0.228	MGD
G-10	Flow	9/18/2014		0.207	MGD
G-10	Flow	9/19/2014		0.135	MGD
G-10	Flow	9/20/2014		0.114	MGD
G-10	Flow	9/21/2014		0.099	MGD
G-10	Flow	9/22/2014		0.204	MGD
G-10	Flow	9/23/2014		0.198	MGD
G-10	Flow	9/24/2014		0.179	MGD
G-10	Flow	9/25/2014		0.204	MGD
G-10	Flow	9/26/2014		0.145	MGD
G-10	Flow	9/27/2014		0.109	MGD
G-10	Flow	9/28/2014		0.090	MGD
G-10	Flow	9/29/2014		0.179	MGD
G-10	Flow	9/30/2014		0.194	MGD
G-10	Flow	10/1/2014		0.160	MGD
G-10	Flow	10/2/2014		0.154	MGD
G-10	Flow	10/3/2014		0.118	MGD
G-10	Flow	10/4/2014		0.092	MGD
G-10	Flow	10/5/2014		0.067	MGD
G-10	Flow	10/6/2014		0.148	MGD
G-10	Flow	10/7/2014		0.169	MGD
G-10	Flow	10/8/2014		0.172	MGD
G-10	Flow	10/9/2014		0.176	MGD
G-10	Flow	10/10/2014		0.111	MGD
G-10	Flow	10/11/2014		0.079	MGD
G-10	Flow	10/12/2014		0.092	MGD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
G-10	Flow	10/13/2014		0.155	MGD
G-10	Flow	10/14/2014		0.212	MGD
G-10	Flow	10/15/2014		0.186	MGD
G-10	Flow	10/16/2014		0.159	MGD
G-10	Flow	10/17/2014		0.096	MGD
G-10	Flow	10/18/2014		0.068	MGD
G-10	Flow	10/19/2014		0.075	MGD
G-10	Flow	10/20/2014		0.156	MGD
G-10	Flow	10/21/2014		0.154	MGD
G-10	Flow	10/22/2014		0.181	MGD
G-10	Flow	10/23/2014		0.178	MGD
G-10	Flow	10/24/2014		0.096	MGD
G-10	Flow	10/25/2014		0.070	MGD
G-10	Flow	10/26/2014		0.087	MGD
G-10	Flow	10/27/2014		0.189	MGD
G-10	Flow	10/28/2014		0.184	MGD
G-10	Flow	10/29/2014		0.183	MGD
G-10	Flow	10/30/2014		0.187	MGD
G-10	Flow	10/31/2014		0.093	MGD
G-10	Flow	11/1/2014		0.120	MGD
G-10	Flow	11/2/2014		0.088	MGD
G-10	Flow	11/3/2014		0.200	MGD
G-10	Flow	11/4/2014		0.219	MGD
G-10	Flow	11/5/2014		0.194	MGD
G-10	Flow	11/6/2014		0.229	MGD
G-10	Flow	11/7/2014		0.150	MGD
G-10	Flow	11/8/2014		0.116	MGD
G-10	Flow	11/9/2014		0.117	MGD
G-10	Flow	11/10/2014		0.191	MGD
G-10	Flow	11/11/2014		0.312	MGD
G-10	Flow	11/12/2014		0.216	MGD
G-10	Flow	11/13/2014		0.196	MGD
G-10	Flow	11/14/2014		0.163	MGD
G-10	Flow	11/15/2014		0.153	MGD
G-10	Flow	11/16/2014		0.128	MGD
G-10	Flow	11/17/2014		0.241	MGD
G-10	Flow	11/18/2014		0.285	MGD
G-10	Flow	11/19/2014		0.273	MGD
G-10	Flow	11/20/2014		0.288	MGD
G-10	Flow	11/21/2014		0.187	MGD
G-10	Flow	11/22/2014		0.152	MGD
G-10	Flow	11/23/2014		0.354	MGD
G-10	Flow	11/24/2014		0.348	MGD
G-10	Flow	11/25/2014		0.308	MGD
G-10	Flow	11/26/2014		0.383	MGD
G-10	Flow	11/27/2014		0.205	MGD
G-10	Flow	11/28/2014		0.161	MGD
G-10	Flow	11/29/2014		0.127	MGD
G-10	Flow	11/30/2014		0.118	MGD
G-10	Flow	12/1/2014		0.240	MGD
G-10	Flow	12/2/2014		0.232	MGD
G-10	Flow	12/3/2014		0.254	MGD
G-10	Flow	12/4/2014		0.239	MGD
G-10	Flow	12/5/2014		0.183	MGD
G-10	Flow	12/6/2014		0.129	MGD
G-10	Flow	12/7/2014		0.149	MGD
G-10	Flow	12/8/2014		0.223	MGD
G-10	Flow	12/9/2014		0.200	MGD
G-10	Flow	12/10/2014		0.251	MGD
G-10	Flow	12/11/2014		0.227	MGD
G-10	Flow	12/12/2014		0.189	MGD
G-10	Flow	12/13/2014		0.140	MGD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
G-10	Flow	12/14/2014		0.135	MGD
G-10	Flow	12/15/2014		0.245	MGD
G-10	Flow	12/16/2014		0.225	MGD
G-10	Flow	12/17/2014		0.254	MGD
G-10	Flow	12/18/2014		0.223	MGD
G-10	Flow	12/19/2014		0.182	MGD
G-10	Flow	12/20/2014		0.131	MGD
G-10	Flow	12/21/2014		0.174	MGD
G-10	Flow	12/22/2014		0.242	MGD
G-10	Flow	12/23/2014		0.320	MGD
G-10	Flow	12/24/2014		0.645	MGD
G-10	Flow	12/25/2014		0.377	MGD
G-10	Flow	12/26/2014		0.387	MGD
G-10	Flow	12/27/2014		0.286	MGD
G-10	Flow	12/28/2014		0.206	MGD
G-10	Flow	12/29/2014		0.292	MGD
G-10	Flow	12/30/2014		0.240	MGD
G-10	Flow	12/31/2014		0.346	MGD
G-10	pH	1/6/2014		7.86	SU
G-10	pH	1/13/2014		7.44	SU
G-10	pH	2/4/2014		7.56	SU
G-10	pH	2/10/2014		7.40	SU
G-10	pH	3/4/2014		7.80	SU
G-10	pH	3/10/2014		7.25	SU
G-10	pH	4/7/2014		7.48	SU
G-10	pH	4/17/2014		7.19	SU
G-10	pH	5/5/2014		7.16	SU
G-10	pH	5/13/2014		7.58	SU
G-10	pH	6/5/2014		7.35	SU
G-10	pH	6/11/2014		7.52	SU
G-10	pH	7/7/2014		7.70	SU
G-10	pH	7/23/2014		7.37	SU
G-10	pH	8/7/2014		7.70	SU
G-10	pH	8/15/2014		7.38	SU
G-10	pH	9/11/2014		7.56	SU
G-10	pH	9/18/2014		7.62	SU
G-10	pH	10/14/2014		7.17	SU
G-10	pH	10/21/2014		7.18	SU
G-10	pH	11/6/2014		7.38	SU
G-10	pH	11/13/2014		6.87	SU
G-10	pH	12/8/2014		7.30	SU
G-10	pH	12/15/2014		7.33	SU
G-10	Total Suspended Solids	1/7/2014		2.5	MG/L
G-10	Total Suspended Solids	1/14/2014		2.7	MG/L
G-10	Total Suspended Solids	2/4/2014		2.1	MG/L
G-10	Total Suspended Solids	2/11/2014		4.3	MG/L
G-10	Total Suspended Solids	3/4/2014		1.8	MG/L
G-10	Total Suspended Solids	3/11/2014		3.9	MG/L
G-10	Total Suspended Solids	4/8/2014		11.8	MG/L
G-10	Total Suspended Solids	4/15/2014		3.7	MG/L
G-10	Total Suspended Solids	5/6/2014		2.8	MG/L
G-10	Total Suspended Solids	5/13/2014		3.0	MG/L
G-10	Total Suspended Solids	6/3/2014		7.9	MG/L
G-10	Total Suspended Solids	6/10/2014		2.2	MG/L
G-10	Total Suspended Solids	7/8/2014		2.7	MG/L
G-10	Total Suspended Solids	7/15/2014		2.6	MG/L
G-10	Total Suspended Solids	8/5/2014		1.4	MG/L
G-10	Total Suspended Solids	8/12/2014		3.2	MG/L
G-10	Total Suspended Solids	9/9/2014		6.4	MG/L
G-10	Total Suspended Solids	9/16/2014	<	1.0	MG/L
G-10	Total Suspended Solids	10/7/2014		3.5	MG/L
G-10	Total Suspended Solids	10/14/2014		3.4	MG/L

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
G-10	Total Suspended Solids	11/4/2014		6.5	MG/L
G-10	Total Suspended Solids	11/11/2014		3.3	MG/L
G-10	Total Suspended Solids	12/2/2014		5.7	MG/L
G-10	Total Suspended Solids	12/9/2014		3.8	MG/L
H-02	Copper	1/23/2014		0.0069	MG/L
H-02	Copper	2/11/2014		0.0069	MG/L
H-02	Copper	3/20/2014		0.0080	MG/L
H-02	Copper	4/22/2014		0.0094	MG/L
H-02	Copper	5/13/2014		0.0110	MG/L
H-02	Copper	6/10/2014		0.0075	MG/L
H-02	Copper	7/24/2014		0.0051	MG/L
H-02	Copper	8/19/2014	<	0.0050	MG/L
H-02	Copper	8/19/2014	<	0.0050	MG/L
H-02	Copper	9/18/2014	<	0.0050	MG/L
H-02	Copper	9/18/2014	<	0.0050	MG/L
H-02	Copper	10/14/2014		0.0061	MG/L
H-02	Copper	11/19/2014	<	0.0050	MG/L
H-02	Copper	12/2/2014		0.0051	MG/L
H-02	Flow	1/1/2014		221,900	GPD
H-02	Flow	1/2/2014		206,900	GPD
H-02	Flow	1/3/2014		318,300	GPD
H-02	Flow	1/4/2014		162,200	GPD
H-02	Flow	1/5/2014		150,300	GPD
H-02	Flow	1/6/2014		149,000	GPD
H-02	Flow	1/7/2014		144,600	GPD
H-02	Flow	1/8/2014		129,000	GPD
H-02	Flow	1/9/2014		105,800	GPD
H-02	Flow	1/10/2014		170,100	GPD
H-02	Flow	1/11/2014		313,600	GPD
H-02	Flow	1/12/2014		682,200	GPD
H-02	Flow	1/13/2014		214,800	GPD
H-02	Flow	1/14/2014		166,400	GPD
H-02	Flow	1/15/2014		141,600	GPD
H-02	Flow	1/16/2014		83,400	GPD
H-02	Flow	1/17/2014		73,600	GPD
H-02	Flow	1/18/2014		166,100	GPD
H-02	Flow	1/19/2014		134,200	GPD
H-02	Flow	1/20/2014		77,400	GPD
H-02	Flow	1/21/2014		55,900	GPD
H-02	Flow	1/22/2014		138,400	GPD
H-02	Flow	1/23/2014		120,800	GPD
H-02	Flow	1/24/2014		101,200	GPD
H-02	Flow	1/25/2014		94,700	GPD
H-02	Flow	1/26/2014		67,000	GPD
H-02	Flow	1/27/2014		74,000	GPD
H-02	Flow	1/28/2014		56,100	GPD
H-02	Flow	1/29/2014		106,700	GPD
H-02	Flow	1/30/2014		132,700	GPD
H-02	Flow	1/31/2014		109,400	GPD
H-02	Flow	2/3/2014		117,133	GPD
H-02	Flow	2/4/2014		91,800	GPD
H-02	Flow	2/5/2014		139,900	GPD
H-02	Flow	2/6/2014		108,100	GPD
H-02	Flow	2/7/2014		104,800	GPD
H-02	Flow	2/10/2014		98,033	GPD
H-02	Flow	2/11/2014		107,600	GPD
H-02	Flow	2/12/2014		Bad weather	GPD
H-02	Flow	2/13/2014		Bad weather	GPD
H-02	Flow	2/14/2014		755,200	GPD
H-02	Flow	2/15/2014		498,700	GPD
H-02	Flow	2/16/2014		288,600	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
H-02	Flow	2/17/2014		211,200	GPD
H-02	Flow	2/18/2014		136,900	GPD
H-02	Flow	2/19/2014		95,600	GPD
H-02	Flow	2/20/2014		84,300	GPD
H-02	Flow	2/21/2014		133,700	GPD
H-02	Flow	2/24/2014		284,933	GPD
H-02	Flow	2/25/2014		204,800	GPD
H-02	Flow	2/26/2014		160,900	GPD
H-02	Flow	2/27/2014		312,400	GPD
H-02	Flow	2/28/2014		197,300	GPD
H-02	Flow	3/3/2014		155,800	GPD
H-02	Flow	3/4/2014		144,000	GPD
H-02	Flow	3/5/2014		190,400	GPD
H-02	Flow	3/6/2014		174,400	GPD
H-02	Flow	3/7/2014		518,400	GPD
H-02	Flow	3/10/2014		324,100	GPD
H-02	Flow	3/11/2014		133,900	GPD
H-02	Flow	3/12/2014		123,600	GPD
H-02	Flow	3/13/2014		162,800	GPD
H-02	Flow	3/14/2014		161,700	GPD
H-02	Flow	3/17/2014		362,933	GPD
H-02	Flow	3/18/2014		581,600	GPD
H-02	Flow	3/19/2014		467,700	GPD
H-02	Flow	3/20/2014		175,200	GPD
H-02	Flow	3/21/2014		88,400	GPD
H-02	Flow	3/24/2014		84,533	GPD
H-02	Flow	3/25/2014		66,800	GPD
H-02	Flow	3/26/2014		97,900	GPD
H-02	Flow	3/27/2014		109,900	GPD
H-02	Flow	3/28/2014		95,600	GPD
H-02	Flow	3/31/2014		127,233	GPD
H-02	Flow	4/1/2014		84,300	GPD
H-02	Flow	4/2/2014		66,400	GPD
H-02	Flow	4/3/2014		57,900	GPD
H-02	Flow	4/4/2014		64,600	GPD
H-02	Flow	4/7/2014		84,200	GPD
H-02	Flow	4/8/2014		632,300	GPD
H-02	Flow	4/9/2014		249,500	GPD
H-02	Flow	4/10/2014		117,800	GPD
H-02	Flow	4/11/2014		65,400	GPD
H-02	Flow	4/14/2014		67,200	GPD
H-02	Flow	4/15/2014		84,100	GPD
H-02	Flow	4/16/2014		129,900	GPD
H-02	Flow	4/17/2014		75,000	GPD
H-02	Flow	4/18/2014		67,300	GPD
H-02	Flow	4/21/2014		557,767	GPD
H-02	Flow	4/22/2014		202,500	GPD
H-02	Flow	4/23/2014		145,200	GPD
H-02	Flow	4/24/2014		101,800	GPD
H-02	Flow	4/25/2014		101,800	GPD
H-02	Flow	4/28/2014		76,167	GPD
H-02	Flow	4/29/2014		82,700	GPD
H-02	Flow	4/30/2014		119,000	GPD
H-02	Flow	5/1/2014		106,200	GPD
H-02	Flow	5/2/2014		118,600	GPD
H-02	Flow	5/5/2014		79,067	GPD
H-02	Flow	5/6/2014		40,500	GPD
H-02	Flow	5/7/2014		47,400	GPD
H-02	Flow	5/8/2014		50,208	GPD
H-02	Flow	5/9/2014		60,000	GPD
H-02	Flow	5/12/2014		96,600	GPD
H-02	Flow	5/13/2014		91,700	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
H-02	Flow	5/14/2014		81,800	GPD
H-02	Flow	5/15/2014		192,700	GPD
H-02	Flow	5/16/2014		444,600	GPD
H-02	Flow	5/19/2014		166,100	GPD
H-02	Flow	5/20/2014		76,600	GPD
H-02	Flow	5/21/2014		68,700	GPD
H-02	Flow	5/22/2014		54,500	GPD
H-02	Flow	5/23/2014		58,200	GPD
H-02	Flow	5/26/2014		195,900	GPD
H-02	Flow	5/27/2014		261,200	GPD
H-02	Flow	5/28/2014		220,992	GPD
H-02	Flow	5/29/2014		144,835	GPD
H-02	Flow	5/30/2014		123,300	GPD
H-02	Flow	6/2/2014		290,900	GPD
H-02	Flow	6/3/2014		168,480	GPD
H-02	Flow	6/4/2014		105,200	GPD
H-02	Flow	6/5/2014		70,122	GPD
H-02	Flow	6/6/2014		112,800	GPD
H-02	Flow	6/9/2014		211,667	GPD
H-02	Flow	6/10/2014		164,500	GPD
H-02	Flow	6/11/2014		129,700	GPD
H-02	Flow	6/12/2014		210,300	GPD
H-02	Flow	6/13/2014		464,300	GPD
H-02	Flow	6/16/2014		201,467	GPD
H-02	Flow	6/17/2014		98,300	GPD
H-02	Flow	6/18/2014		83,600	GPD
H-02	Flow	6/19/2014		75,900	GPD
H-02	Flow	6/20/2014		68,000	GPD
H-02	Flow	6/23/2014		68,567	GPD
H-02	Flow	6/24/2014		205,500	GPD
H-02	Flow	6/25/2014		157,200	GPD
H-02	Flow	6/26/2014		110,100	GPD
H-02	Flow	6/27/2014		95,400	GPD
H-02	Flow	6/30/2014		102,267	GPD
H-02	Flow	7/1/2014		83,300	GPD
H-02	Flow	7/2/2014		87,900	GPD
H-02	Flow	7/3/2014		90,200	GPD
H-02	Flow	7/7/2014		73,475	GPD
H-02	Flow	7/8/2014		243,600	GPD
H-02	Flow	7/9/2014		212,600	GPD
H-02	Flow	7/10/2014		92,500	GPD
H-02	Flow	7/11/2014		467,200	GPD
H-02	Flow	7/14/2014		269,767	GPD
H-02	Flow	7/15/2014		90,600	GPD
H-02	Flow	7/16/2014		120,500	GPD
H-02	Flow	7/17/2014		104,800	GPD
H-02	Flow	7/18/2014		92,700	GPD
H-02	Flow	7/21/2014		285,433	GPD
H-02	Flow	7/22/2014		499,700	GPD
H-02	Flow	7/23/2014		282,800	GPD
H-02	Flow	7/24/2014		157,300	GPD
H-02	Flow	7/25/2014		102,900	GPD
H-02	Flow	7/28/2014		281,500	GPD
H-02	Flow	7/29/2014		97,800	GPD
H-02	Flow	7/30/2014		71,000	GPD
H-02	Flow	7/31/2014		79,400	GPD
H-02	Flow	8/1/2014		113,100	GPD
H-02	Flow	8/4/2014		333,200	GPD
H-02	Flow	8/5/2014		196,300	GPD
H-02	Flow	8/6/2014		128,000	GPD
H-02	Flow	8/7/2014		93,200	GPD
H-02	Flow	8/8/2014		81,200	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
H-02	Flow	8/11/2014		165,100	GPD
H-02	Flow	8/12/2014		164,308	GPD
H-02	Flow	8/13/2014		166,643	GPD
H-02	Flow	8/14/2014		136,383	GPD
H-02	Flow	8/15/2014		111,692	GPD
H-02	Flow	8/18/2014		77,383	GPD
H-02	Flow	8/19/2014		82,200	GPD
H-02	Flow	8/20/2014		79,900	GPD
H-02	Flow	8/21/2014		72,600	GPD
H-02	Flow	8/22/2014		72,700	GPD
H-02	Flow	8/25/2014		71,566	GPD
H-02	Flow	8/26/2014		63,000	GPD
H-02	Flow	8/27/2014		118,573	GPD
H-02	Flow	8/28/2014		121,200	GPD
H-02	Flow	8/29/2014		105,415	GPD
H-02	Flow	9/1/2014		171,737	GPD
H-02	Flow	9/2/2014		150,700	GPD
H-02	Flow	9/3/2014		152,123	GPD
H-02	Flow	9/4/2014		150,218	GPD
H-02	Flow	9/5/2014		141,100	GPD
H-02	Flow	9/8/2014		222,600	GPD
H-02	Flow	9/9/2014		458,600	GPD
H-02	Flow	9/10/2014		327,900	GPD
H-02	Flow	9/11/2014		177,400	GPD
H-02	Flow	9/12/2014		175,200	GPD
H-02	Flow	9/15/2014		302,133	GPD
H-02	Flow	9/16/2014		255,000	GPD
H-02	Flow	9/17/2014		186,500	GPD
H-02	Flow	9/18/2014		127,100	GPD
H-02	Flow	9/19/2014		129,800	GPD
H-02	Flow	9/22/2014		115,066	GPD
H-02	Flow	9/23/2014		180,200	GPD
H-02	Flow	9/24/2014		152,100	GPD
H-02	Flow	9/25/2014		127,900	GPD
H-02	Flow	9/26/2014		112,800	GPD
H-02	Flow	9/29/2014		88,967	GPD
H-02	Flow	9/30/2014		119,100	GPD
H-02	Flow	10/1/2014		87,500	GPD
H-02	Flow	10/2/2014		77,300	GPD
H-02	Flow	10/3/2014		75,100	GPD
H-02	Flow	10/6/2014		84,800	GPD
H-02	Flow	10/7/2014		112,900	GPD
H-02	Flow	10/8/2014		126,200	GPD
H-02	Flow	10/9/2014		111,800	GPD
H-02	Flow	10/10/2014		123,400	GPD
H-02	Flow	10/13/2014		130,800	GPD
H-02	Flow	10/14/2014		106,200	GPD
H-02	Flow	10/15/2014		160,500	GPD
H-02	Flow	10/16/2014		162,600	GPD
H-02	Flow	10/17/2014		112,600	GPD
H-02	Flow	10/20/2014		70,767	GPD
H-02	Flow	10/21/2014		74,700	GPD
H-02	Flow	10/22/2014		55,300	GPD
H-02	Flow	10/23/2014		70,000	GPD
H-02	Flow	10/24/2014		61,500	GPD
H-02	Flow	10/27/2014		64,533	GPD
H-02	Flow	10/28/2014		67,500	GPD
H-02	Flow	10/29/2014		64,500	GPD
H-02	Flow	10/30/2014		78,369	GPD
H-02	Flow	10/31/2014		69,164	GPD
H-02	Flow	11/3/2014		97,900	GPD
H-02	Flow	11/4/2014		77,800	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
H-02	Flow	11/5/2014		78,000	GPD
H-02	Flow	11/6/2014		72,600	GPD
H-02	Flow	11/7/2014		71,700	GPD
H-02	Flow	11/10/2014		80,067	GPD
H-02	Flow	11/11/2014		72,700	GPD
H-02	Flow	11/12/2014		62,300	GPD
H-02	Flow	11/13/2014		72,200	GPD
H-02	Flow	11/14/2014		102,200	GPD
H-02	Flow	11/17/2014		88,400	GPD
H-02	Flow	11/18/2014		135,300	GPD
H-02	Flow	11/19/2014		240,181	GPD
H-02	Flow	11/20/2014		248,595	GPD
H-02	Flow	11/21/2014		193,200	GPD
H-02	Flow	11/24/2014		472,500	GPD
H-02	Flow	11/25/2014		329,300	GPD
H-02	Flow	11/26/2014		511,200	GPD
H-02	Flow	11/28/2014		218,650	GPD
H-02	Flow	12/1/2014		109,133	GPD
H-02	Flow	12/2/2014		227,500	GPD
H-02	Flow	12/3/2014		156,894	GPD
H-02	Flow	12/4/2014		113,707	GPD
H-02	Flow	12/5/2014		133,800	GPD
H-02	Flow	12/8/2014		95,600	GPD
H-02	Flow	12/9/2014		149,584	GPD
H-02	Flow	12/10/2014		118,672	GPD
H-02	Flow	12/11/2014		98,100	GPD
H-02	Flow	12/12/2014		90,500	GPD
H-02	Flow	12/15/2014		68,700	GPD
H-02	Flow	12/16/2014		211,100	GPD
H-02	Flow	12/17/2014		264,900	GPD
H-02	Flow	12/18/2014		281,500	GPD
H-02	Flow	12/19/2014		264,700	GPD
H-02	Flow	12/22/2014		292,600	GPD
H-02	Flow	12/23/2014		570,500	GPD
H-02	Flow	12/24/2014		1,546,000	GPD
H-02	Flow	12/25/2014		1,830,700	GPD
H-02	Flow	12/26/2014		942,300	GPD
H-02	Flow	12/29/2014		795,267	GPD
H-02	Flow	12/30/2014		458,800	GPD
H-02	Flow	12/31/2014		342,500	GPD
H-02	Lead	1/23/2014	<	0.0020	MG/L
H-02	Lead	2/11/2014	<	0.0020	MG/L
H-02	Lead	3/20/2014	<	0.0020	MG/L
H-02	Lead	4/22/2014	<	0.0020	MG/L
H-02	Lead	5/13/2014	<	0.0020	MG/L
H-02	Lead	6/10/2014	<	0.0020	MG/L
H-02	Lead	7/24/2014	<	0.0020	MG/L
H-02	Lead	8/19/2014	<	0.0020	MG/L
H-02	Lead	8/19/2014	<	0.0020	MG/L
H-02	Lead	9/18/2014	<	0.0020	MG/L
H-02	Lead	9/18/2014	<	0.0020	MG/L
H-02	Lead	10/14/2014	<	0.0020	MG/L
H-02	Lead	11/19/2014	<	0.0020	MG/L
H-02	Lead	12/2/2014	<	0.0020	MG/L
H-02	pH	1/22/2014		6.6	SU
H-02	pH	2/10/2014		6.5	SU
H-02	pH	3/19/2014		6.9	SU
H-02	pH	4/21/2014		6.8	SU
H-02	pH	5/12/2014		6.5	SU
H-02	pH	6/9/2014		6.8	SU
H-02	pH	7/23/2014		6.9	SU
H-02	pH	8/19/2014		7.0	SU

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
H-02	pH	9/17/2014		6.6	SU
H-02	pH	10/13/2014		6.9	SU
H-02	pH	11/18/2014		6.7	SU
H-02	pH	12/1/2014		6.7	SU
H-02	Zinc	1/23/2014	<	0.0100	MG/L
H-02	Zinc	2/11/2014	<	0.0100	MG/L
H-02	Zinc	3/20/2014	<	0.0100	MG/L
H-02	Zinc	4/22/2014	<	0.0100	MG/L
H-02	Zinc	5/13/2014	<	0.0100	MG/L
H-02	Zinc	6/10/2014	<	0.0010	MG/L
H-02	Zinc	7/24/2014	<	0.0100	MG/L
H-02	Zinc	8/19/2014	<	0.0100	MG/L
H-02	Zinc	8/19/2014		0.0133	MG/L
H-02	Zinc	9/18/2014	<	0.0100	MG/L
H-02	Zinc	9/18/2014	<	0.0100	MG/L
H-02	Zinc	10/14/2014	<	0.0100	MG/L
H-02	Zinc	11/19/2014	<	0.0100	MG/L
H-02	Zinc	12/2/2014	<	0.0100	MG/L
H-07	Flow	3/4/2014		0	GPM
H-07	Flow	6/4/2014		12.0	GPM
H-07	Flow	8/26/2014		0	GPM
H-07	Flow	10/6/2014		0	GPM
H-07	pH	3/4/2014		NF	SU
H-07	pH	6/4/2014		6.2	SU
H-07	pH	8/26/2014		NF	SU
H-07	pH	10/6/2014		NF	SU
H-07	Total Suspended Solids	3/4/2014		NF	MG/L
H-07	Total Suspended Solids	6/5/2014		9.0	MG/L
H-07	Total Suspended Solids	6/5/2014		10.0	MG/L
H-07	Total Suspended Solids	8/26/2014		NF	MG/L
H-07	Total Suspended Solids	10/6/2014		NF	MG/L
H-12	Copper	1/23/2014		0.0108	MG/L
H-12	Copper	2/11/2014		0.0086	MG/L
H-12	Copper	2/11/2014		0.0081	MG/L
H-12	Copper	3/20/2014		0.0064	MG/L
H-12	Copper	4/22/2014	<	0.0050	MG/L
H-12	Copper	5/13/2014		0.0051	MG/L
H-12	Copper	6/10/2014		0.0062	MG/L
H-12	Copper	6/10/2014		0.0061	MG/L
H-12	Copper	7/24/2014		0.0053	MG/L
H-12	Copper	8/19/2014		0.0053	MG/L
H-12	Copper	9/18/2014		0.0056	MG/L
H-12	Copper	10/14/2014	<	0.0050	MG/L
H-12	Copper	11/19/2014		0.0052	MG/L
H-12	Copper	12/2/2014	<	0.0050	MG/L
H-12	Flow	1/22/2014		65.1	GPM
H-12	Flow	2/10/2014		303.9	GPM
H-12	Flow	3/19/2014		262.8	GPM
H-12	Flow	4/21/2014		231.6	GPM
H-12	Flow	5/12/2014		172.0	GPM
H-12	Flow	6/10/2014		249.5	GPM
H-12	Flow	7/23/2014		479.1	GPM
H-12	Flow	8/19/2014		218.1	GPM
H-12	Flow	9/17/2014		78.7	GPM
H-12	Flow	10/14/2014		1,970.2	GPM
H-12	Flow	11/19/2014		563.0	GPM
H-12	Flow	12/1/2014		505.5	GPM
H-12	pH	1/22/2014		6.8	SU
H-12	pH	2/10/2014		6.2	SU
H-12	pH	3/19/2014		6.4	SU
H-12	pH	4/21/2014		6.7	SU

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
H-12	pH	5/12/2014		6.5	SU
H-12	pH	6/9/2014		6.4	SU
H-12	pH	7/23/2014		7.0	SU
H-12	pH	8/19/2014		6.8	SU
H-12	pH	9/17/2014		6.9	SU
H-12	pH	10/13/2014		6.8	SU
H-12	pH	11/19/2014		7.9	SU
H-12	pH	12/1/2014		6.8	SU
H-12	Zinc	1/23/2014		0.0150	MG/L
H-12	Zinc	2/11/2014		0.0569	MG/L
H-12	Zinc	2/11/2014		0.0564	MG/L
H-12	Zinc	3/20/2014		0.1463	MG/L
H-12	Zinc	4/22/2014		0.0428	MG/L
H-12	Zinc	5/13/2014		0.0380	MG/L
H-12	Zinc	6/10/2014		0.0175	MG/L
H-12	Zinc	6/10/2014		0.0178	MG/L
H-12	Zinc	7/24/2014		0.0121	MG/L
H-12	Zinc	8/19/2014	<	0.0100	MG/L
H-12	Zinc	9/18/2014	<	0.0100	MG/L
H-12	Zinc	10/14/2014		0.0253	MG/L
H-12	Zinc	11/19/2014		0.0273	MG/L
H-12	Zinc	12/2/2014		0.0253	MG/L
H-16	Biochemical Oxygen Demand	1/6/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	1/6/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	1/8/2014		NF	MG/L
H-16	Biochemical Oxygen Demand	1/15/2014		NF	MG/L
H-16	Biochemical Oxygen Demand	1/22/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	2/3/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	2/11/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	2/18/2014		2.5	MG/L
H-16	Biochemical Oxygen Demand	2/24/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	3/3/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	3/10/2014		NF	MG/L
H-16	Biochemical Oxygen Demand	3/17/2014		NF	MG/L
H-16	Biochemical Oxygen Demand	3/27/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	4/1/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	4/8/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	4/15/2014		3.0	MG/L
H-16	Biochemical Oxygen Demand	4/22/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	5/5/2014 ^a		INVALID	MG/L
H-16	Biochemical Oxygen Demand	5/12/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	5/19/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	5/27/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	6/2/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	6/9/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	6/16/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	6/23/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	7/1/2014		NF	MG/L
H-16	Biochemical Oxygen Demand	7/9/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	7/15/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	7/22/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	8/4/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	8/11/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	8/20/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	8/25/2014		NF	MG/L
H-16	Biochemical Oxygen Demand	9/7/2014		NF	MG/L
H-16	Biochemical Oxygen Demand	9/14/2014		NF	MG/L
H-16	Biochemical Oxygen Demand	9/21/2014		NF	MG/L
H-16	Biochemical Oxygen Demand	9/28/2014		NF	MG/L
H-16	Biochemical Oxygen Demand	10/1/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	10/8/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	10/15/2014		NF	MG/L

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
H-16	Biochemical Oxygen Demand	10/22/2014		NF	MG/L
H-16	Biochemical Oxygen Demand	11/3/2014		NF	MG/L
H-16	Biochemical Oxygen Demand	11/10/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	11/17/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	11/24/2014		NF	MG/L
H-16	Biochemical Oxygen Demand	12/1/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	12/8/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	12/15/2014	<	2.0	MG/L
H-16	Biochemical Oxygen Demand	12/22/2014	<	2.0	MG/L
H-16	Cadmium	1/6/2014	<	0.0001	MG/L
H-16	Cadmium	1/8/2014		NF	MG/L
H-16	Cadmium	1/15/2014		NF	MG/L
H-16	Cadmium	1/22/2014	<	0.0001	MG/L
H-16	Cadmium	2/3/2014	<	0.0001	MG/L
H-16	Cadmium	2/11/2014	<	0.0001	MG/L
H-16	Cadmium	2/18/2014	<	0.0001	MG/L
H-16	Cadmium	2/24/2014	<	0.0001	MG/L
H-16	Cadmium	3/3/2014	<	0.0001	MG/L
H-16	Cadmium	3/10/2014		NF	MG/L
H-16	Cadmium	3/17/2014		NF	MG/L
H-16	Cadmium	3/27/2014	<	0.0001	MG/L
H-16	Cadmium	4/1/2014	<	0.0001	MG/L
H-16	Cadmium	4/8/2014	<	0.0001	MG/L
H-16	Cadmium	4/15/2014	<	0.0001	MG/L
H-16	Cadmium	4/15/2014	<	0.0001	MG/L
H-16	Cadmium	4/22/2014	<	0.0001	MG/L
H-16	Cadmium	5/5/2014	<	0.0001	MG/L
H-16	Cadmium	5/12/2014	<	0.0001	MG/L
H-16	Cadmium	5/19/2014	<	0.0001	MG/L
H-16	Cadmium	5/27/2014	<	0.0001	MG/L
H-16	Cadmium	6/2/2014	<	0.0001	MG/L
H-16	Cadmium	6/9/2014	<	0.0001	MG/L
H-16	Cadmium	6/16/2014	<	0.0001	MG/L
H-16	Cadmium	6/23/2014	<	0.0001	MG/L
H-16	Cadmium	7/1/2014		NF	MG/L
H-16	Cadmium	7/9/2014	<	0.0001	MG/L
H-16	Cadmium	7/15/2014	<	0.0001	MG/L
H-16	Cadmium	7/22/2014	<	0.0001	MG/L
H-16	Cadmium	8/4/2014	<	0.0001	MG/L
H-16	Cadmium	8/11/2014	<	0.0001	MG/L
H-16	Cadmium	8/11/2014	<	0.0001	MG/L
H-16	Cadmium	8/20/2014	<	0.0001	MG/L
H-16	Cadmium	8/25/2014		NF	MG/L
H-16	Cadmium	9/7/2014		NF	MG/L
H-16	Cadmium	9/14/2014		NF	MG/L
H-16	Cadmium	9/21/2014		NF	MG/L
H-16	Cadmium	9/28/2014		NF	MG/L
H-16	Cadmium	10/1/2014	<	0.0001	MG/L
H-16	Cadmium	10/8/2014	<	0.0001	MG/L
H-16	Cadmium	10/15/2014		NF	MG/L
H-16	Cadmium	10/22/2014		NF	MG/L
H-16	Cadmium	11/3/2014		NF	MG/L
H-16	Cadmium	11/10/2014	<	0.0001	MG/L
H-16	Cadmium	11/17/2014	<	0.0001	MG/L
H-16	Cadmium	11/24/2014		NF	MG/L
H-16	Cadmium	12/1/2014	<	0.0001	MG/L
H-16	Cadmium	12/8/2014	<	0.0001	MG/L
H-16	Cadmium	12/15/2014	<	0.0001	MG/L
H-16	Cadmium	12/22/2014	<	0.0001	MG/L
H-16	Chromium	1/6/2014	<	0.0050	MG/L
H-16	Chromium	1/8/2014		NF	MG/L
H-16	Chromium	1/15/2014		NF	MG/L

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than ($<$)	Result	Unit
H-16	Chromium	1/22/2014	$<$	0.0050	MG/L
H-16	Chromium	2/3/2014	$<$	0.0050	MG/L
H-16	Chromium	2/11/2014	$<$	0.0050	MG/L
H-16	Chromium	2/18/2014	$<$	0.0050	MG/L
H-16	Chromium	2/24/2014	$<$	0.0050	MG/L
H-16	Chromium	3/3/2014	$<$	0.0050	MG/L
H-16	Chromium	3/10/2014		NF	MG/L
H-16	Chromium	3/17/2014		NF	MG/L
H-16	Chromium	3/27/2014	$<$	0.0050	MG/L
H-16	Chromium	4/1/2014	$<$	0.0050	MG/L
H-16	Chromium	4/8/2014	$<$	0.0050	MG/L
H-16	Chromium	4/15/2014	$<$	0.0050	MG/L
H-16	Chromium	4/15/2014	$<$	0.0050	MG/L
H-16	Chromium	4/22/2014	$<$	0.0050	MG/L
H-16	Chromium	5/5/2014	$<$	0.0050	MG/L
H-16	Chromium	5/12/2014	$<$	0.0050	MG/L
H-16	Chromium	5/19/2014	$<$	0.0050	MG/L
H-16	Chromium	5/27/2014	$<$	0.0050	MG/L
H-16	Chromium	6/2/2014	$<$	0.0050	MG/L
H-16	Chromium	6/9/2014	$<$	0.0050	MG/L
H-16	Chromium	6/16/2014	$<$	0.0050	MG/L
H-16	Chromium	6/23/2014	$<$	0.0050	MG/L
H-16	Chromium	7/1/2014		NF	MG/L
H-16	Chromium	7/15/2014	$<$	0.0050	MG/L
H-16	Chromium	7/22/2014	$<$	0.0050	MG/L
H-16	Chromium	8/4/2014	$<$	0.0050	MG/L
H-16	Chromium	8/11/2014	$<$	0.0050	MG/L
H-16	Chromium	8/11/2014	$<$	0.0050	MG/L
H-16	Chromium	8/20/2014	$<$	0.0050	MG/L
H-16	Chromium	8/25/2014		NF	MG/L
H-16	Chromium	9/7/2014		NF	MG/L
H-16	Chromium	9/14/2014		NF	MG/L
H-16	Chromium	9/21/2014		NF	MG/L
H-16	Chromium	9/28/2014		NF	MG/L
H-16	Chromium	10/1/2014	$<$	0.0050	MG/L
H-16	Chromium	10/8/2014	$<$	0.0050	MG/L
H-16	Chromium	10/15/2014		NF	MG/L
H-16	Chromium	10/22/2014		NF	MG/L
H-16	Chromium	11/3/2014		NF	MG/L
H-16	Chromium	11/10/2014	$<$	0.0050	MG/L
H-16	Chromium	11/17/2014	$<$	0.0050	MG/L
H-16	Chromium	11/24/2014		NF	MG/L
H-16	Chromium	12/1/2014	$<$	0.0050	MG/L
H-16	Chromium	12/8/2014	$<$	0.0050	MG/L
H-16	Chromium	12/15/2014	$<$	0.0050	MG/L
H-16	Chromium	12/22/2014	$<$	0.0050	MG/L
H-16	Copper	1/6/2014	$<$	0.0050	MG/L
H-16	Copper	1/8/2014		NF	MG/L
H-16	Copper	1/15/2014		NF	MG/L
H-16	Copper	1/22/2014	$<$	0.0050	MG/L
H-16	Copper	2/3/2014	$<$	0.0050	MG/L
H-16	Copper	2/11/2014	$<$	0.0050	MG/L
H-16	Copper	2/18/2014	$<$	0.0050	MG/L
H-16	Copper	2/24/2014	$<$	0.0050	MG/L
H-16	Copper	3/3/2014	$<$	0.0050	MG/L
H-16	Copper	3/10/2014		NF	MG/L
H-16	Copper	3/17/2014		NF	MG/L
H-16	Copper	3/27/2014	$<$	0.0050	MG/L
H-16	Copper	4/1/2014	$<$	0.0050	MG/L
H-16	Copper	4/8/2014	$<$	0.0050	MG/L
H-16	Copper	4/15/2014	$<$	0.0050	MG/L
H-16	Copper	4/15/2014	$<$	0.0050	MG/L

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
H-16	Copper	4/22/2014	<	0.0050	MG/L
H-16	Copper	5/5/2014	<	0.0050	MG/L
H-16	Copper	5/12/2014	<	0.0050	MG/L
H-16	Copper	5/19/2014	<	0.0050	MG/L
H-16	Copper	5/27/2014	<	0.0050	MG/L
H-16	Copper	6/2/2014	<	0.0050	MG/L
H-16	Copper	6/9/2014	<	0.0050	MG/L
H-16	Copper	6/16/2014	<	0.0050	MG/L
H-16	Copper	6/23/2014	<	0.0050	MG/L
H-16	Copper	7/1/2014		NF	MG/L
H-16	Copper	7/9/2014	<	0.0050	MG/L
H-16	Copper	7/15/2014	<	0.0050	MG/L
H-16	Copper	7/22/2014	<	0.0050	MG/L
H-16	Copper	8/4/2014	<	0.0050	MG/L
H-16	Copper	8/11/2014	<	0.0050	MG/L
H-16	Copper	8/11/2014	<	0.0050	MG/L
H-16	Copper	8/20/2014	<	0.0050	MG/L
H-16	Copper	8/25/2014		NF	MG/L
H-16	Copper	9/7/2014		NF	MG/L
H-16	Copper	9/14/2014		NF	MG/L
H-16	Copper	9/21/2014		NF	MG/L
H-16	Copper	9/28/2014		NF	MG/L
H-16	Copper	10/1/2014	<	0.0050	MG/L
H-16	Copper	10/8/2014	<	0.0050	MG/L
H-16	Copper	10/15/2014		NF	MG/L
H-16	Copper	10/22/2014		NF	MG/L
H-16	Copper	11/3/2014		NF	MG/L
H-16	Copper	11/10/2014	<	0.0050	MG/L
H-16	Copper	11/17/2014	<	0.0050	MG/L
H-16	Copper	11/24/2014		NF	MG/L
H-16	Copper	12/1/2014	<	0.0050	MG/L
H-16	Copper	12/8/2014	<	0.0050	MG/L
H-16	Copper	12/15/2014	<	0.0050	MG/L
H-16	Copper	12/22/2014	<	0.0050	MG/L
H-16	Flow	1/6/2014		175	GPM
H-16	Flow	1/8/2014		0	GPM
H-16	Flow	1/15/2014		0	GPM
H-16	Flow	1/22/2014		175	GPM
H-16	Flow	2/3/2014		174	GPM
H-16	Flow	2/11/2014		195	GPM
H-16	Flow	2/18/2014		185	GPM
H-16	Flow	2/24/2014		174	GPM
H-16	Flow	3/3/2014		175	GPM
H-16	Flow	3/10/2014		0	GPM
H-16	Flow	3/17/2014		0	GPM
H-16	Flow	3/27/2014		165	GPM
H-16	Flow	4/1/2014		163	GPM
H-16	Flow	4/8/2014		135	GPM
H-16	Flow	4/15/2014		100	GPM
H-16	Flow	4/22/2014		82	GPM
H-16	Flow	5/5/2014		175	GPM
H-16	Flow	5/12/2014		200	GPM
H-16	Flow	5/19/2014		191	GPM
H-16	Flow	5/27/2014		174	GPM
H-16	Flow	6/2/2014		174	GPM
H-16	Flow	6/9/2014		182	GPM
H-16	Flow	6/16/2014		168	GPM
H-16	Flow	6/23/2014		180	GPM
H-16	Flow	7/1/2014		0	GPM
H-16	Flow	7/9/2014		190	GPM
H-16	Flow	7/15/2014		172	GPM
H-16	Flow	7/22/2014		179	GPM

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
H-16	Flow	8/4/2014		173	GPM
H-16	Flow	8/11/2014		173	GPM
H-16	Flow	8/20/2014		174	GPM
H-16	Flow	8/25/2014		0	GPM
H-16	Flow	9/7/2014		0	GPM
H-16	Flow	9/14/2014		0	GPM
H-16	Flow	9/21/2014		0	GPM
H-16	Flow	9/28/2014		0	GPM
H-16	Flow	10/1/2014		171	GPM
H-16	Flow	10/8/2014		172	GPM
H-16	Flow	10/15/2014		0	GPM
H-16	Flow	10/22/2014		0	GPM
H-16	Flow	11/3/2014		0	GPM
H-16	Flow	11/10/2014		169	GPM
H-16	Flow	11/17/2014		168	GPM
H-16	Flow	11/24/2014		0	GPM
H-16	Flow	12/1/2014		169	GPM
H-16	Flow	12/8/2014		171	GPM
H-16	Flow	12/15/2014		169	GPM
H-16	Flow	12/22/2014		170	GPM
H-16	Lead	1/6/2014	<	0.0020	MG/L
H-16	Lead	1/8/2014		NF	MG/L
H-16	Lead	1/15/2014		NF	MG/L
H-16	Lead	1/22/2014	<	0.0020	MG/L
H-16	Lead	2/3/2014	<	0.0020	MG/L
H-16	Lead	2/11/2014	<	0.0020	MG/L
H-16	Lead	2/18/2014	<	0.0020	MG/L
H-16	Lead	2/24/2014	<	0.0020	MG/L
H-16	Lead	3/3/2014	<	0.0020	MG/L
H-16	Lead	3/10/2014		NF	MG/L
H-16	Lead	3/17/2014		NF	MG/L
H-16	Lead	3/27/2014	<	0.0020	MG/L
H-16	Lead	4/1/2014	<	0.0020	MG/L
H-16	Lead	4/8/2014	<	0.0020	MG/L
H-16	Lead	4/15/2014	<	0.0020	MG/L
H-16	Lead	4/15/2014	<	0.0020	MG/L
H-16	Lead	4/22/2014	<	0.0020	MG/L
H-16	Lead	5/5/2014	<	0.0020	MG/L
H-16	Lead	5/12/2014	<	0.0020	MG/L
H-16	Lead	5/19/2014	<	0.0020	MG/L
H-16	Lead	5/27/2014	<	0.0020	MG/L
H-16	Lead	6/2/2014	<	0.0020	MG/L
H-16	Lead	6/9/2014	<	0.0020	MG/L
H-16	Lead	6/16/2014	<	0.0020	MG/L
H-16	Lead	6/23/2014	<	0.0020	MG/L
H-16	Lead	7/1/2014		NF	MG/L
H-16	Lead	7/9/2014	<	0.0020	MG/L
H-16	Lead	7/15/2014	<	0.0020	MG/L
H-16	Lead	7/22/2014	<	0.0020	MG/L
H-16	Lead	8/4/2014	<	0.0020	MG/L
H-16	Lead	8/11/2014	<	0.0020	MG/L
H-16	Lead	8/11/2014	<	0.0020	MG/L
H-16	Lead	8/20/2014	<	0.0020	MG/L
H-16	Lead	8/25/2014		NF	MG/L
H-16	Lead	9/7/2014		NF	MG/L
H-16	Lead	9/14/2014		NF	MG/L
H-16	Lead	9/21/2014		NF	MG/L
H-16	Lead	9/28/2014		NF	MG/L
H-16	Lead	10/1/2014	<	0.0020	MG/L
H-16	Lead	10/8/2014	<	0.0020	MG/L
H-16	Lead	10/15/2014		NF	MG/L
H-16	Lead	10/22/2014		NF	MG/L

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
H-16	Lead	11/3/2014		NF	MG/L
H-16	Lead	11/10/2014	<	0.0020	MG/L
H-16	Lead	11/17/2014	<	0.0020	MG/L
H-16	Lead	11/24/2014		NF	MG/L
H-16	Lead	12/1/2014	<	0.0020	MG/L
H-16	Lead	12/8/2014	<	0.0020	MG/L
H-16	Lead	12/15/2014	<	0.0020	MG/L
H-16	Lead	12/22/2014	<	0.0020	MG/L
H-16	Mercury	1/6/2014	<	0.0001	MG/L
H-16	Mercury	1/8/2014		NF	MG/L
H-16	Mercury	1/15/2014		NF	MG/L
H-16	Mercury	1/22/2014	<	0.0001	MG/L
H-16	Mercury	2/3/2014	<	0.0001	MG/L
H-16	Mercury	2/11/2014	<	0.0001	MG/L
H-16	Mercury	2/18/2014	<	0.0001	MG/L
H-16	Mercury	2/24/2014	<	0.0001	MG/L
H-16	Mercury	3/3/2014	<	0.0001	MG/L
H-16	Mercury	3/10/2014		NF	MG/L
H-16	Mercury	3/17/2014		NF	MG/L
H-16	Mercury	3/27/2014	<	0.0001	MG/L
H-16	Mercury	4/1/2014	<	0.0001	MG/L
H-16	Mercury	4/8/2014	<	0.0001	MG/L
H-16	Mercury	4/15/2014	<	0.0001	MG/L
H-16	Mercury	4/15/2014	<	0.0001	MG/L
H-16	Mercury	4/22/2014	<	0.0001	MG/L
H-16	Mercury	5/5/2014	<	0.0001	MG/L
H-16	Mercury	5/12/2014	<	0.0001	MG/L
H-16	Mercury	5/19/2014	<	0.0001	MG/L
H-16	Mercury	5/27/2014	<	0.0001	MG/L
H-16	Mercury	6/2/2014	<	0.0001	MG/L
H-16	Mercury	6/9/2014	<	0.0001	MG/L
H-16	Mercury	6/16/2014		0.00012	MG/L
H-16	Mercury	6/23/2014		0.00016	MG/L
H-16	Mercury	7/1/2014		NF	MG/L
H-16	Mercury	7/9/2014	<	0.0001	MG/L
H-16	Mercury	7/15/2014	<	0.0001	MG/L
H-16	Mercury	7/22/2014	<	0.0001	MG/L
H-16	Mercury	8/4/2014	<	0.0001	MG/L
H-16	Mercury	8/11/2014	<	0.0001	MG/L
H-16	Mercury	8/11/2014	<	0.0001	MG/L
H-16	Mercury	8/20/2014	<	0.0001	MG/L
H-16	Mercury	8/25/2014		NF	MG/L
H-16	Mercury	9/7/2014		NF	MG/L
H-16	Mercury	9/14/2014		NF	MG/L
H-16	Mercury	9/21/2014		NF	MG/L
H-16	Mercury	9/28/2014		NF	MG/L
H-16	Mercury	10/1/2014	<	0.0001	MG/L
H-16	Mercury	10/8/2014	<	0.0001	MG/L
H-16	Mercury	10/15/2014		NF	MG/L
H-16	Mercury	10/22/2014		NF	MG/L
H-16	Mercury	11/3/2014		NF	MG/L
H-16	Mercury	11/10/2014	<	0.0001	MG/L
H-16	Mercury	11/17/2014	<	0.0001	MG/L
H-16	Mercury	11/24/2014		NF	MG/L
H-16	Mercury	12/1/2014		0.0001	MG/L
H-16	Mercury	12/8/2014	<	0.0001	MG/L
H-16	Mercury	12/15/2014	<	0.0001	MG/L
H-16	Mercury	12/22/2014	<	0.0001	MG/L
H-16	Nickel	1/6/2014	<	0.0100	MG/L
H-16	Nickel	1/8/2014		NF	MG/L
H-16	Nickel	1/15/2014		NF	MG/L
H-16	Nickel	1/22/2014	<	0.0100	MG/L

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
H-16	Nickel	2/3/2014	<	0.0100	MG/L
H-16	Nickel	2/11/2014	<	0.0100	MG/L
H-16	Nickel	2/18/2014	<	0.0100	MG/L
H-16	Nickel	2/24/2014	<	0.0100	MG/L
H-16	Nickel	3/3/2014	<	0.0100	MG/L
H-16	Nickel	3/10/2014		NF	MG/L
H-16	Nickel	3/17/2014		NF	MG/L
H-16	Nickel	3/27/2014	<	0.0100	MG/L
H-16	Nickel	4/1/2014	<	0.0100	MG/L
H-16	Nickel	4/8/2014	<	0.0100	MG/L
H-16	Nickel	4/15/2014	<	0.0100	MG/L
H-16	Nickel	4/15/2014	<	0.0100	MG/L
H-16	Nickel	4/22/2014	<	0.0100	MG/L
H-16	Nickel	5/5/2014	<	0.0100	MG/L
H-16	Nickel	5/12/2014	<	0.0100	MG/L
H-16	Nickel	5/19/2014	<	0.0100	MG/L
H-16	Nickel	5/27/2014	<	0.0100	MG/L
H-16	Nickel	6/2/2014	<	0.0100	MG/L
H-16	Nickel	6/9/2014	<	0.0100	MG/L
H-16	Nickel	6/16/2014	<	0.0100	MG/L
H-16	Nickel	6/23/2014	<	0.0100	MG/L
H-16	Nickel	7/1/2014		NF	MG/L
H-16	Nickel	7/9/2014	<	0.0100	MG/L
H-16	Nickel	7/15/2014	<	0.0100	MG/L
H-16	Nickel	7/22/2014	<	0.0100	MG/L
H-16	Nickel	8/4/2014	<	0.0100	MG/L
H-16	Nickel	8/11/2014	<	0.0100	MG/L
H-16	Nickel	8/11/2014	<	0.0100	MG/L
H-16	Nickel	8/20/2014	<	0.0100	MG/L
H-16	Nickel	8/25/2014		NF	MG/L
H-16	Nickel	9/7/2014		NF	MG/L
H-16	Nickel	9/14/2014		NF	MG/L
H-16	Nickel	9/21/2014		NF	MG/L
H-16	Nickel	9/28/2014		NF	MG/L
H-16	Nickel	10/1/2014	<	0.0100	MG/L
H-16	Nickel	10/8/2014	<	0.0100	MG/L
H-16	Nickel	10/15/2014		NF	MG/L
H-16	Nickel	10/22/2014		NF	MG/L
H-16	Nickel	11/3/2014		NF	MG/L
H-16	Nickel	11/10/2014	<	0.0100	MG/L
H-16	Nickel	11/17/2014	<	0.0100	MG/L
H-16	Nickel	11/24/2014		NF	MG/L
H-16	Nickel	12/1/2014	<	0.0100	MG/L
H-16	Nickel	12/8/2014	<	0.0100	MG/L
H-16	Nickel	12/15/2014	<	0.0100	MG/L
H-16	Nickel	12/22/2014	<	0.0100	MG/L
H-16	pH	1/6/2014		6.9	SU
H-16	pH	1/8/2014		NF	SU
H-16	pH	1/15/2014		NF	SU
H-16	pH	1/22/2014		6.8	SU
H-16	pH	2/3/2014		7.1	SU
H-16	pH	2/11/2014		6.9	SU
H-16	pH	2/18/2014		7.1	SU
H-16	pH	2/24/2014		7.7	SU
H-16	pH	3/3/2014		7.3	SU
H-16	pH	3/10/2014		NF	SU
H-16	pH	3/17/2014		NF	SU
H-16	pH	3/27/2014		7.7	SU
H-16	pH	4/1/2014		7.1	SU
H-16	pH	4/8/2014		7.8	SU
H-16	pH	4/15/2014		6.9	SU
H-16	pH	4/22/2014		7.3	SU

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
H-16	pH	5/5/2014		6.8	SU
H-16	pH	5/12/2014		6.9	SU
H-16	pH	5/19/2014		7.5	SU
H-16	pH	5/27/2014		7.5	SU
H-16	pH	6/2/2014		6.5	SU
H-16	pH	6/9/2014		7.4	SU
H-16	pH	6/16/2014		7.4	SU
H-16	pH	6/23/2014		6.8	SU
H-16	pH	7/1/2014		NF	SU
H-16	pH	7/9/2014		7.0	SU
H-16	pH	7/15/2014		7.6	SU
H-16	pH	7/22/2014		7.2	SU
H-16	pH	8/4/2014		7.0	SU
H-16	pH	8/11/2014		7.6	SU
H-16	pH	8/20/2014		7.3	SU
H-16	pH	8/25/2014		NF	SU
H-16	pH	9/7/2014		NF	SU
H-16	pH	9/14/2014		NF	SU
H-16	pH	9/21/2014		NF	SU
H-16	pH	9/28/2014		NF	SU
H-16	pH	10/1/2014		7.5	SU
H-16	pH	10/8/2014		6.9	SU
H-16	pH	10/15/2014		NF	SU
H-16	pH	10/22/2014		NF	SU
H-16	pH	11/3/2014		NF	SU
H-16	pH	11/10/2014		7.6	SU
H-16	pH	11/17/2014		7.6	SU
H-16	pH	11/24/2014		NF	SU
H-16	pH	12/1/2014		6.8	SU
H-16	pH	12/8/2014		7.7	SU
H-16	pH	12/15/2014		8.0	SU
H-16	pH	12/22/2014		7.0	SU
H-16	Silver	1/6/2014	<	0.0050	MG/L
H-16	Silver	1/8/2014		NF	MG/L
H-16	Silver	1/15/2014		NF	MG/L
H-16	Silver	1/22/2014	<	0.0050	MG/L
H-16	Silver	2/3/2014	<	0.0050	MG/L
H-16	Silver	2/11/2014	<	0.0050	MG/L
H-16	Silver	2/18/2014	<	0.0050	MG/L
H-16	Silver	2/24/2014	<	0.0050	MG/L
H-16	Silver	3/3/2014	<	0.0050	MG/L
H-16	Silver	3/10/2014		NF	MG/L
H-16	Silver	3/17/2014		NF	MG/L
H-16	Silver	3/27/2014	<	0.0050	MG/L
H-16	Silver	4/1/2014	<	0.0050	MG/L
H-16	Silver	4/8/2014	<	0.0050	MG/L
H-16	Silver	4/15/2014	<	0.0050	MG/L
H-16	Silver	4/15/2014	<	0.0050	MG/L
H-16	Silver	4/22/2014	<	0.0050	MG/L
H-16	Silver	5/5/2014	<	0.0050	MG/L
H-16	Silver	5/12/2014	<	0.0050	MG/L
H-16	Silver	5/19/2014	<	0.0050	MG/L
H-16	Silver	5/27/2014	<	0.0050	MG/L
H-16	Silver	6/2/2014	<	0.0050	MG/L
H-16	Silver	6/9/2014	<	0.0050	MG/L
H-16	Silver	6/16/2014	<	0.0050	MG/L
H-16	Silver	6/23/2014	<	0.0050	MG/L
H-16	Silver	7/1/2014		NF	MG/L
H-16	Silver	7/9/2014	<	0.0050	MG/L
H-16	Silver	7/15/2014	<	0.0050	MG/L
H-16	Silver	7/22/2014	<	0.0050	MG/L
H-16	Silver	8/4/2014	<	0.0050	MG/L

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
H-16	Silver	8/11/2014	<	0.0050	MG/L
H-16	Silver	8/11/2014	<	0.0050	MG/L
H-16	Silver	8/20/2014	<	0.0050	MG/L
H-16	Silver	8/25/2014		NF	MG/L
H-16	Silver	9/7/2014		NF	MG/L
H-16	Silver	9/14/2014		NF	MG/L
H-16	Silver	9/21/2014		NF	MG/L
H-16	Silver	9/28/2014		NF	MG/L
H-16	Silver	10/1/2014	<	0.0050	MG/L
H-16	Silver	10/8/2014	<	0.0050	MG/L
H-16	Silver	10/15/2014		NF	MG/L
H-16	Silver	10/22/2014		NF	MG/L
H-16	Silver	11/3/2014		NF	MG/L
H-16	Silver	11/10/2014	<	0.0050	MG/L
H-16	Silver	11/17/2014	<	0.0050	MG/L
H-16	Silver	11/24/2014		NF	MG/L
H-16	Silver	12/1/2014	<	0.0050	MG/L
H-16	Silver	12/8/2014	<	0.0050	MG/L
H-16	Silver	12/15/2014	<	0.0050	MG/L
H-16	Silver	12/22/2014	<	0.0050	MG/L
H-16	Total Suspended Solids	1/6/2014	<	1.0	MG/L
H-16	Total Suspended Solids	1/6/2014	<	1.0	MG/L
H-16	Total Suspended Solids	1/8/2014		NF	MG/L
H-16	Total Suspended Solids	1/15/2014		NF	MG/L
H-16	Total Suspended Solids	1/22/2014	<	1.0	MG/L
H-16	Total Suspended Solids	2/3/2014	<	1.0	MG/L
H-16	Total Suspended Solids	2/11/2014	<	1.0	MG/L
H-16	Total Suspended Solids	2/18/2014	<	1.0	MG/L
H-16	Total Suspended Solids	2/24/2014	<	1.0	MG/L
H-16	Total Suspended Solids	3/3/2014	<	1.0	MG/L
H-16	Total Suspended Solids	3/10/2014		NF	MG/L
H-16	Total Suspended Solids	3/17/2014		NF	MG/L
H-16	Total Suspended Solids	3/27/2014	<	1.0	MG/L
H-16	Total Suspended Solids	4/1/2014	<	1.0	MG/L
H-16	Total Suspended Solids	4/8/2014		1.0	MG/L
H-16	Total Suspended Solids	4/15/2014	<	1.0	MG/L
H-16	Total Suspended Solids	4/22/2014	<	1.0	MG/L
H-16	Total Suspended Solids	5/5/2014	<	1.0	MG/L
H-16	Total Suspended Solids	5/12/2014	<	1.0	MG/L
H-16	Total Suspended Solids	5/19/2014	<	1.0	MG/L
H-16	Total Suspended Solids	5/27/2014	<	1.0	MG/L
H-16	Total Suspended Solids	6/2/2014		2.4	MG/L
H-16	Total Suspended Solids	6/9/2014	<	1.0	MG/L
H-16	Total Suspended Solids	6/16/2014	<	1.0	MG/L
H-16	Total Suspended Solids	6/23/2014	<	1.0	MG/L
H-16	Total Suspended Solids	7/1/2014		NF	MG/L
H-16	Total Suspended Solids	7/9/2014	<	1.0	MG/L
H-16	Total Suspended Solids	7/15/2014	<	1.0	MG/L
H-16	Total Suspended Solids	7/22/2014	<	1.0	MG/L
H-16	Total Suspended Solids	8/4/2014	<	1.0	MG/L
H-16	Total Suspended Solids	8/11/2014	<	1.0	MG/L
H-16	Total Suspended Solids	8/20/2014	<	1.0	MG/L
H-16	Total Suspended Solids	8/25/2014		NF	MG/L
H-16	Total Suspended Solids	9/7/2014		NF	MG/L
H-16	Total Suspended Solids	9/14/2014		NF	MG/L
H-16	Total Suspended Solids	9/21/2014		NF	MG/L
H-16	Total Suspended Solids	9/28/2014		NF	MG/L
H-16	Total Suspended Solids	10/1/2014	<	1.0	MG/L
H-16	Total Suspended Solids	10/8/2014	<	1.0	MG/L
H-16	Total Suspended Solids	10/15/2014		NF	MG/L
H-16	Total Suspended Solids	10/22/2014		NF	MG/L
H-16	Total Suspended Solids	11/3/2014		NF	MG/L

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
H-16	Total Suspended Solids	11/10/2014	<	1.0	MG/L
H-16	Total Suspended Solids	11/17/2014	<	1.0	MG/L
H-16	Total Suspended Solids	11/24/2014		NF	MG/L
H-16	Total Suspended Solids	12/1/2014	<	1.0	MG/L
H-16	Total Suspended Solids	12/8/2014	<	1.0	MG/L
H-16	Total Suspended Solids	12/15/2014	<	1.0	MG/L
H-16	Total Suspended Solids	12/22/2014	<	1.0	MG/L
H-16	Zinc	1/6/2014	<	0.0050	MG/L
H-16	Zinc	1/8/2014		NF	MG/L
H-16	Zinc	1/15/2014		NF	MG/L
H-16	Zinc	1/22/2014	<	0.0050	MG/L
H-16	Zinc	2/3/2014		0.0061	MG/L
H-16	Zinc	2/11/2014	<	0.0050	MG/L
H-16	Zinc	2/18/2014	<	0.0050	MG/L
H-16	Zinc	2/24/2014	<	0.0050	MG/L
H-16	Zinc	3/3/2014	<	0.0050	MG/L
H-16	Zinc	3/10/2014		NF	MG/L
H-16	Zinc	3/17/2014		NF	MG/L
H-16	Zinc	3/27/2014	<	0.0050	MG/L
H-16	Zinc	4/1/2014	<	0.0050	MG/L
H-16	Zinc	4/8/2014	<	0.0050	MG/L
H-16	Zinc	4/15/2014	<	0.0050	MG/L
H-16	Zinc	4/15/2014	<	0.0050	MG/L
H-16	Zinc	4/22/2014	<	0.0050	MG/L
H-16	Zinc	5/5/2014	<	0.0050	MG/L
H-16	Zinc	5/12/2014	<	0.0050	MG/L
H-16	Zinc	5/19/2014	<	0.0050	MG/L
H-16	Zinc	5/27/2014	<	0.0050	MG/L
H-16	Zinc	6/2/2014	<	0.0050	MG/L
H-16	Zinc	6/9/2014	<	0.0050	MG/L
H-16	Zinc	6/16/2014	<	0.0050	MG/L
H-16	Zinc	6/23/2014	<	0.0050	MG/L
H-16	Zinc	7/1/2014		NF	MG/L
H-16	Zinc	7/9/2014	<	0.0050	MG/L
H-16	Zinc	7/15/2014	<	0.0050	MG/L
H-16	Zinc	7/22/2014	<	0.0050	MG/L
H-16	Zinc	8/4/2014		0.0083	MG/L
H-16	Zinc	8/11/2014		0.0064	MG/L
H-16	Zinc	8/11/2014		0.0063	MG/L
H-16	Zinc	8/20/2014		0.0057	MG/L
H-16	Zinc	8/25/2014		NF	MG/L
H-16	Zinc	9/7/2014		NF	MG/L
H-16	Zinc	9/14/2014		NF	MG/L
H-16	Zinc	9/21/2014		NF	MG/L
H-16	Zinc	9/28/2014		NF	MG/L
H-16	Zinc	10/1/2014		0.0120	MG/L
H-16	Zinc	10/8/2014		0.0120	MG/L
H-16	Zinc	10/15/2014		NF	MG/L
H-16	Zinc	10/22/2014		NF	MG/L
H-16	Zinc	11/3/2014		NF	MG/L
H-16	Zinc	11/10/2014		0.0110	MG/L
H-16	Zinc	11/17/2014	<	0.0050	MG/L
H-16	Zinc	11/24/2014		NF	MG/L
H-16	Zinc	12/1/2014		0.0069	MG/L
H-16	Zinc	12/8/2014	<	0.0050	MG/L
H-16	Zinc	12/15/2014	<	0.0050	MG/L
H-16	Zinc	12/22/2014		0.0067	MG/L
K-06	Flow	1/27/2014		0	GPM
K-06	Flow	2/10/2014		0	GPM
K-06	Flow	3/19/2014		0	GPM
K-06	Flow	4/23/2014		0	GPM

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
K-06	Flow	5/28/2014		0	GPM
K-06	Flow	6/4/2014		0	GPM
K-06	Flow	7/23/2014		0	GPM
K-06	Flow	8/20/2014		0	GPM
K-06	Flow	9/15/2014		0	GPM
K-06	Flow	10/20/2014		0	GPM
K-06	Flow	11/20/2014		0	GPM
K-06	Flow	12/17/2014		0	GPM
The following parameters are measured when a sample is collected at K-06: Copper, Flow, Lead, Low-Level Mercury, pH and Zinc. Since there was no flow from K-06 during 2014, no sample was collected.					
K-12	Biochemical Oxygen Demand	1/7/2014		5.98	MG/L
K-12	Biochemical Oxygen Demand	2/4/2014		2.99	MG/L
K-12	Biochemical Oxygen Demand	3/4/2014		4.16	MG/L
K-12	Biochemical Oxygen Demand	4/8/2014	<	2.00	MG/L
K-12	Biochemical Oxygen Demand	5/6/2014		4.31	MG/L
K-12	Biochemical Oxygen Demand	6/3/2014		2.85	MG/L
K-12	Biochemical Oxygen Demand	7/8/2014	<	2.00	MG/L
K-12	Biochemical Oxygen Demand	8/12/2014		2.16	MG/L
K-12	Biochemical Oxygen Demand	9/9/2014	<	2.00	MG/L
K-12	Biochemical Oxygen Demand	10/7/2014	<	2.00	MG/L
K-12	Biochemical Oxygen Demand	11/4/2014	<	2.00	MG/L
K-12	Biochemical Oxygen Demand	12/2/2014	<	2.00	MG/L
K-12	Dissolved Oxygen	1/22/2014		5.40	MG/L
K-12	Dissolved Oxygen	2/24/2014		7.79	MG/L
K-12	Dissolved Oxygen	3/20/2014		4.41	MG/L
K-12	Dissolved Oxygen	4/7/2014		3.26	MG/L
K-12	Dissolved Oxygen	5/21/2014		2.25	MG/L
K-12	Dissolved Oxygen	6/9/2014		1.55	MG/L
K-12	Dissolved Oxygen	7/16/2014		1.95	MG/L
K-12	Dissolved Oxygen	8/20/2014		2.56	MG/L
K-12	Dissolved Oxygen	9/22/2014		2.11	MG/L
K-12	Dissolved Oxygen	10/21/2014		4.52	MG/L
K-12	Dissolved Oxygen	11/17/2014		4.56	MG/L
K-12	Dissolved Oxygen	12/10/2014		4.94	MG/L
K-12	Fecal Coliform	1/6/2014	<	2	COL/100ML
K-12	Fecal Coliform	2/3/2014	<	2	COL/100ML
K-12	Fecal Coliform	3/4/2014	<	2	COL/100ML
K-12	Fecal Coliform	4/8/2014	<	2	COL/100ML
K-12	Fecal Coliform	5/6/2014	<	2	COL/100ML
K-12	Fecal Coliform	6/2/2014		13	COL/100ML
K-12	Fecal Coliform	7/7/2014	<	2	COL/100ML
K-12	Fecal Coliform	8/5/2014	<	2	COL/100ML
K-12	Fecal Coliform	9/8/2014	<	2	COL/100ML
K-12	Fecal Coliform	10/6/2014	<	2	COL/100ML
K-12	Fecal Coliform	11/3/2014	<	2	COL/100ML
K-12	Fecal Coliform	12/1/2014	<	2	COL/100ML
K-12	Flow	1/1/2014		1,438	GPD
K-12	Flow	1/2/2014		1,966	GPD
K-12	Flow	1/3/2014		0	GPD
K-12	Flow	1/4/2014		0	GPD
K-12	Flow	1/5/2014		1,219	GPD
K-12	Flow	1/6/2014		787	GPD
K-12	Flow	1/7/2014		1,959	GPD
K-12	Flow	1/8/2014		1,615	GPD
K-12	Flow	1/9/2014		16	GPD
K-12	Flow	1/10/2014		2,712	GPD
K-12	Flow	1/11/2014		5,003	GPD
K-12	Flow	1/12/2014		0	GPD
K-12	Flow	1/13/2014		1,940	GPD
K-12	Flow	1/14/2014		2,134	GPD
K-12	Flow	1/15/2014		80	GPD
K-12	Flow	1/16/2014		2,107	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
K-12	Flow	1/17/2014		0	GPD
K-12	Flow	1/18/2014		873	GPD
K-12	Flow	1/19/2014		565	GPD
K-12	Flow	1/20/2014		0	GPD
K-12	Flow	1/21/2014		1,819	GPD
K-12	Flow	1/22/2014		2,246	GPD
K-12	Flow	1/23/2014		2,063	GPD
K-12	Flow	1/24/2014		1,538	GPD
K-12	Flow	1/25/2014		128	GPD
K-12	Flow	1/26/2014		2,100	GPD
K-12	Flow	1/27/2014		1,653	GPD
K-12	Flow	1/28/2014		2,897	GPD
K-12	Flow	1/29/2014		1,403	GPD
K-12	Flow	1/30/2014		2,010	GPD
K-12	Flow	1/31/2014		0	GPD
K-12	Flow	2/1/2014		1,653	GPD
K-12	Flow	2/2/2014		0	GPD
K-12	Flow	2/3/2014		2,598	GPD
K-12	Flow	2/4/2014		1,935	GPD
K-12	Flow	2/5/2014		1,042	GPD
K-12	Flow	2/6/2014		24	GPD
K-12	Flow	2/7/2014		1,773	GPD
K-12	Flow	2/8/2014		0	GPD
K-12	Flow	2/9/2014		0	GPD
K-12	Flow	2/10/2014		1,699	GPD
K-12	Flow	2/11/2014		2,207	GPD
K-12	Flow	2/12/2014		11,713	GPD
K-12	Flow	2/13/2014		7,797	GPD
K-12	Flow	2/14/2014		198	GPD
K-12	Flow	2/15/2014		1,907	GPD
K-12	Flow	2/16/2014		1,514	GPD
K-12	Flow	2/17/2014		64	GPD
K-12	Flow	2/18/2014		1,711	GPD
K-12	Flow	2/19/2014		7	GPD
K-12	Flow	2/20/2014		2,273	GPD
K-12	Flow	2/21/2014		4,987	GPD
K-12	Flow	2/22/2014		930	GPD
K-12	Flow	2/23/2014		0	GPD
K-12	Flow	2/24/2014		1,373	GPD
K-12	Flow	2/25/2014		1,044	GPD
K-12	Flow	2/26/2014		1,306	GPD
K-12	Flow	2/27/2014		1,340	GPD
K-12	Flow	2/28/2014		0	GPD
K-12	Flow	3/1/2014		895	GPD
K-12	Flow	3/2/2014		0	GPD
K-12	Flow	3/3/2014		1,935	GPD
K-12	Flow	3/4/2014		982	GPD
K-12	Flow	3/5/2014		1,272	GPD
K-12	Flow	3/6/2014		848	GPD
K-12	Flow	3/7/2014		4,131	GPD
K-12	Flow	3/8/2014		1,322	GPD
K-12	Flow	3/9/2014		0	GPD
K-12	Flow	3/10/2014		1,100	GPD
K-12	Flow	3/11/2014		1,158	GPD
K-12	Flow	3/12/2014		1,540	GPD
K-12	Flow	3/13/2014		1,029	GPD
K-12	Flow	3/14/2014		0	GPD
K-12	Flow	3/15/2014		1,092	GPD
K-12	Flow	3/16/2014		3,466	GPD
K-12	Flow	3/17/2014		3,123	GPD
K-12	Flow	3/18/2014		1,218	GPD
K-12	Flow	3/19/2014		1,532	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
K-12	Flow	3/20/2014		1,623	GPD
K-12	Flow	3/21/2014		1,155	GPD
K-12	Flow	3/22/2014		0	GPD
K-12	Flow	3/23/2014		492	GPD
K-12	Flow	3/24/2014		935	GPD
K-12	Flow	3/25/2014		2,119	GPD
K-12	Flow	3/26/2014		763	GPD
K-12	Flow	3/27/2014		1,066	GPD
K-12	Flow	3/28/2014		689	GPD
K-12	Flow	3/29/2014		716	GPD
K-12	Flow	3/30/2014		616	GPD
K-12	Flow	3/31/2014		1,158	GPD
K-12	Flow	4/1/2014		1,010	GPD
K-12	Flow	4/2/2014		136	GPD
K-12	Flow	4/3/2014		1,418	GPD
K-12	Flow	4/4/2014		722	GPD
K-12	Flow	4/5/2014		0	GPD
K-12	Flow	4/6/2014		618	GPD
K-12	Flow	4/7/2014		2,683	GPD
K-12	Flow	4/8/2014		883	GPD
K-12	Flow	4/9/2014		944	GPD
K-12	Flow	4/10/2014		629	GPD
K-12	Flow	4/11/2014		572	GPD
K-12	Flow	4/12/2014		505	GPD
K-12	Flow	4/13/2014		0	GPD
K-12	Flow	4/14/2014		1,379	GPD
K-12	Flow	4/15/2014		1,258	GPD
K-12	Flow	4/16/2014		866	GPD
K-12	Flow	4/17/2014		574	GPD
K-12	Flow	4/18/2014		6,464	GPD
K-12	Flow	4/19/2014		4,417	GPD
K-12	Flow	4/20/2014		645	GPD
K-12	Flow	4/21/2014		1,214	GPD
K-12	Flow	4/22/2014		1,909	GPD
K-12	Flow	4/23/2014		912	GPD
K-12	Flow	4/24/2014		2,139	GPD
K-12	Flow	4/25/2014		859	GPD
K-12	Flow	4/26/2014		0	GPD
K-12	Flow	4/27/2014		742	GPD
K-12	Flow	4/28/2014		1,856	GPD
K-12	Flow	4/29/2014		942	GPD
K-12	Flow	4/30/2014		1,736	GPD
K-12	Flow	5/1/2014		980	GPD
K-12	Flow	5/2/2014		1,238	GPD
K-12	Flow	5/3/2014		840	GPD
K-12	Flow	5/4/2014		540	GPD
K-12	Flow	5/5/2014		1,579	GPD
K-12	Flow	5/6/2014		1,680	GPD
K-12	Flow	5/7/2014		1,006	GPD
K-12	Flow	5/8/2014		1,052	GPD
K-12	Flow	5/9/2014		905	GPD
K-12	Flow	5/10/2014		933	GPD
K-12	Flow	5/11/2014		363	GPD
K-12	Flow	5/12/2014		1,169	GPD
K-12	Flow	5/13/2014		1,603	GPD
K-12	Flow	5/14/2014		2,235	GPD
K-12	Flow	5/15/2014		2,690	GPD
K-12	Flow	5/16/2014		780	GPD
K-12	Flow	5/17/2014		0	GPD
K-12	Flow	5/18/2014		852	GPD
K-12	Flow	5/19/2014		1,702	GPD
K-12	Flow	5/20/2014		1,008	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
K-12	Flow	5/21/2014		1,127	GPD
K-12	Flow	5/22/2014		1,179	GPD
K-12	Flow	5/23/2014		969	GPD
K-12	Flow	5/24/2014		929	GPD
K-12	Flow	5/25/2014		967	GPD
K-12	Flow	5/26/2014		722	GPD
K-12	Flow	5/27/2014		1,377	GPD
K-12	Flow	5/28/2014		1,917	GPD
K-12	Flow	5/29/2014		528	GPD
K-12	Flow	5/30/2014		1,049	GPD
K-12	Flow	5/31/2014		5,653	GPD
K-12	Flow	6/1/2014		955	GPD
K-12	Flow	6/2/2014		2,960	GPD
K-12	Flow	6/3/2014		1,814	GPD
K-12	Flow	6/4/2014		1,792	GPD
K-12	Flow	6/5/2014		1,673	GPD
K-12	Flow	6/6/2014		1,006	GPD
K-12	Flow	6/7/2014		975	GPD
K-12	Flow	6/8/2014		876	GPD
K-12	Flow	6/9/2014		1,274	GPD
K-12	Flow	6/10/2014		957	GPD
K-12	Flow	6/11/2014		1,817	GPD
K-12	Flow	6/12/2014		1,698	GPD
K-12	Flow	6/13/2014		2,554	GPD
K-12	Flow	6/14/2014		831	GPD
K-12	Flow	6/15/2014		904	GPD
K-12	Flow	6/16/2014		980	GPD
K-12	Flow	6/17/2014		2,003	GPD
K-12	Flow	6/18/2014		1,257	GPD
K-12	Flow	6/19/2014		2,152	GPD
K-12	Flow	6/20/2014		992	GPD
K-12	Flow	6/21/2014		0	GPD
K-12	Flow	6/22/2014		759	GPD
K-12	Flow	6/23/2014		1,002	GPD
K-12	Flow	6/24/2014		3,928	GPD
K-12	Flow	6/25/2014		1,052	GPD
K-12	Flow	6/26/2014		1,630	GPD
K-12	Flow	6/27/2014		946	GPD
K-12	Flow	6/28/2014		7,269	GPD
K-12	Flow	6/29/2014		832	GPD
K-12	Flow	6/30/2014		1,004	GPD
K-12	Flow	7/1/2014		2,281	GPD
K-12	Flow	7/2/2014		976	GPD
K-12	Flow	7/3/2014		981	GPD
K-12	Flow	7/4/2014		0	GPD
K-12	Flow	7/5/2014		894	GPD
K-12	Flow	7/6/2014		906	GPD
K-12	Flow	7/7/2014		3,492	GPD
K-12	Flow	7/8/2014		2,053	GPD
K-12	Flow	7/9/2014		838	GPD
K-12	Flow	7/10/2014		5,021	GPD
K-12	Flow	7/11/2014		7,672	GPD
K-12	Flow	7/12/2014		1,593	GPD
K-12	Flow	7/13/2014		2,867	GPD
K-12	Flow	7/14/2014		7,044	GPD
K-12	Flow	7/15/2014		1,332	GPD
K-12	Flow	7/16/2014		1,514	GPD
K-12	Flow	7/17/2014		968	GPD
K-12	Flow	7/18/2014		1,032	GPD
K-12	Flow	7/19/2014		1,939	GPD
K-12	Flow	7/20/2014		1,003	GPD
K-12	Flow	7/21/2014		7,712	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
K-12	Flow	7/22/2014		3,284	GPD
K-12	Flow	7/23/2014		1,694	GPD
K-12	Flow	7/24/2014		1,280	GPD
K-12	Flow	7/25/2014		5,541	GPD
K-12	Flow	7/26/2014		910	GPD
K-12	Flow	7/27/2014		1,043	GPD
K-12	Flow	7/28/2014		1,959	GPD
K-12	Flow	7/29/2014		992	GPD
K-12	Flow	7/30/2014		1,332	GPD
K-12	Flow	7/31/2014		2,193	GPD
K-12	Flow	8/1/2014		638	GPD
K-12	Flow	8/2/2014		1,015	GPD
K-12	Flow	8/3/2014		823	GPD
K-12	Flow	8/4/2014		1,365	GPD
K-12	Flow	8/5/2014		1,413	GPD
K-12	Flow	8/6/2014		1,550	GPD
K-12	Flow	8/7/2014		941	GPD
K-12	Flow	8/8/2014		7,843	GPD
K-12	Flow	8/9/2014		1,323	GPD
K-12	Flow	8/10/2014		1,242	GPD
K-12	Flow	8/11/2014		1,652	GPD
K-12	Flow	8/12/2014		3,079	GPD
K-12	Flow	8/13/2014		2,681	GPD
K-12	Flow	8/14/2014		1,756	GPD
K-12	Flow	8/15/2014		1,523	GPD
K-12	Flow	8/16/2014		951	GPD
K-12	Flow	8/17/2014		831	GPD
K-12	Flow	8/18/2014		631	GPD
K-12	Flow	8/19/2014		1,595	GPD
K-12	Flow	8/20/2014		1,239	GPD
K-12	Flow	8/21/2014		1,556	GPD
K-12	Flow	8/22/2014		637	GPD
K-12	Flow	8/23/2014		939	GPD
K-12	Flow	8/24/2014		723	GPD
K-12	Flow	8/25/2014		1,168	GPD
K-12	Flow	8/26/2014		1,261	GPD
K-12	Flow	8/27/2014		1,193	GPD
K-12	Flow	8/28/2014		1,279	GPD
K-12	Flow	8/29/2014		830	GPD
K-12	Flow	8/30/2014		848	GPD
K-12	Flow	8/31/2014		0	GPD
K-12	Flow	9/1/2014		745	GPD
K-12	Flow	9/2/2014		1,061	GPD
K-12	Flow	9/3/2014		1,759	GPD
K-12	Flow	9/4/2014		625	GPD
K-12	Flow	9/5/2014		834	GPD
K-12	Flow	9/6/2014		858	GPD
K-12	Flow	9/7/2014		1,985	GPD
K-12	Flow	9/8/2014		3,036	GPD
K-12	Flow	9/9/2014		1,271	GPD
K-12	Flow	9/10/2014		990	GPD
K-12	Flow	9/11/2014		1,082	GPD
K-12	Flow	9/12/2014		973	GPD
K-12	Flow	9/13/2014		955	GPD
K-12	Flow	9/14/2014		831	GPD
K-12	Flow	9/15/2014		2,479	GPD
K-12	Flow	9/16/2014		1,245	GPD
K-12	Flow	9/17/2014		1,345	GPD
K-12	Flow	9/18/2014		1,790	GPD
K-12	Flow	9/19/2014		978	GPD
K-12	Flow	9/20/2014		0	GPD
K-12	Flow	9/21/2014		837	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
K-12	Flow	9/22/2014		2,463	GPD
K-12	Flow	9/23/2014		2,164	GPD
K-12	Flow	9/24/2014		1,766	GPD
K-12	Flow	9/25/2014		1,526	GPD
K-12	Flow	9/26/2014		0	GPD
K-12	Flow	9/27/2014		921	GPD
K-12	Flow	9/28/2014		491	GPD
K-12	Flow	9/29/2014		1,498	GPD
K-12	Flow	9/30/2014		1,388	GPD
K-12	Flow	10/1/2014		640	GPD
K-12	Flow	10/2/2014		1,100	GPD
K-12	Flow	10/3/2014		921	GPD
K-12	Flow	10/4/2014		766	GPD
K-12	Flow	10/5/2014		225	GPD
K-12	Flow	10/6/2014		4,331	GPD
K-12	Flow	10/7/2014		1,383	GPD
K-12	Flow	10/8/2014		1,040	GPD
K-12	Flow	10/9/2014		1,150	GPD
K-12	Flow	10/10/2014		695	GPD
K-12	Flow	10/11/2014		757	GPD
K-12	Flow	10/12/2014		866	GPD
K-12	Flow	10/13/2014		895	GPD
K-12	Flow	10/14/2014		2,027	GPD
K-12	Flow	10/15/2014		1,669	GPD
K-12	Flow	10/16/2014		1,102	GPD
K-12	Flow	10/17/2014		772	GPD
K-12	Flow	10/18/2014		0	GPD
K-12	Flow	10/19/2014		710	GPD
K-12	Flow	10/20/2014		5,409	GPD
K-12	Flow	10/21/2014		1,325	GPD
K-12	Flow	10/22/2014		2,045	GPD
K-12	Flow	10/23/2014		1,045	GPD
K-12	Flow	10/24/2014		743	GPD
K-12	Flow	10/25/2014		678	GPD
K-12	Flow	10/26/2014		0	GPD
K-12	Flow	10/27/2014		1,791	GPD
K-12	Flow	10/28/2014		1,801	GPD
K-12	Flow	10/29/2014		1,634	GPD
K-12	Flow	10/30/2014		1,202	GPD
K-12	Flow	10/31/2014		817	GPD
K-12	Flow	11/1/2014		0	GPD
K-12	Flow	11/2/2014		696	GPD
K-12	Flow	11/3/2014		2,205	GPD
K-12	Flow	11/4/2014		1,983	GPD
K-12	Flow	11/5/2014		2,535	GPD
K-12	Flow	11/6/2014		1,904	GPD
K-12	Flow	11/7/2014		668	GPD
K-12	Flow	11/8/2014		728	GPD
K-12	Flow	11/9/2014		662	GPD
K-12	Flow	11/10/2014		921	GPD
K-12	Flow	11/11/2014		846	GPD
K-12	Flow	11/12/2014		2,053	GPD
K-12	Flow	11/13/2014		1,275	GPD
K-12	Flow	11/14/2014		0	GPD
K-12	Flow	11/15/2014		696	GPD
K-12	Flow	11/16/2014		858	GPD
K-12	Flow	11/17/2014		1,349	GPD
K-12	Flow	11/18/2014		1,945	GPD
K-12	Flow	11/19/2014		1,785	GPD
K-12	Flow	11/20/2014		1,916	GPD
K-12	Flow	11/21/2014		928	GPD
K-12	Flow	11/22/2014		0	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
K-12	Flow	11/23/2014		11,088	GPD
K-12	Flow	11/24/2014		5,689	GPD
K-12	Flow	11/25/2014		4,211	GPD
K-12	Flow	11/26/2014		5,949	GPD
K-12	Flow	11/27/2014		1,352	GPD
K-12	Flow	11/28/2014		1,013	GPD
K-12	Flow	11/29/2014		680	GPD
K-12	Flow	11/30/2014		135	GPD
K-12	Flow	12/1/2014		1,822	GPD
K-12	Flow	12/2/2014		2,060	GPD
K-12	Flow	12/3/2014		813	GPD
K-12	Flow	12/4/2014		1,459	GPD
K-12	Flow	12/5/2014		983	GPD
K-12	Flow	12/6/2014		838	GPD
K-12	Flow	12/7/2014		735	GPD
K-12	Flow	12/8/2014		2,144	GPD
K-12	Flow	12/9/2014		1,444	GPD
K-12	Flow	12/10/2014		2,083	GPD
K-12	Flow	12/11/2014		1,034	GPD
K-12	Flow	12/12/2014		780	GPD
K-12	Flow	12/13/2014		918	GPD
K-12	Flow	12/14/2014		914	GPD
K-12	Flow	12/15/2014		752	GPD
K-12	Flow	12/16/2014		2,145	GPD
K-12	Flow	12/17/2014		1,449	GPD
K-12	Flow	12/18/2014		821	GPD
K-12	Flow	12/19/2014		922	GPD
K-12	Flow	12/20/2014		901	GPD
K-12	Flow	12/21/2014		785	GPD
K-12	Flow	12/22/2014		1,630	GPD
K-12	Flow	12/23/2014		5,845	GPD
K-12	Flow	12/24/2014		27,479	GPD
K-12	Flow	12/25/2014		5,053	GPD
K-12	Flow	12/26/2014		748	GPD
K-12	Flow	12/27/2014		798	GPD
K-12	Flow	12/28/2014		795	GPD
K-12	Flow	12/29/2014		1,562	GPD
K-12	Flow	12/30/2014		827	GPD
K-12	Flow	12/31/2014		1,458	GPD
K-12	pH	1/22/2014		7.4	SU
K-12	pH	2/24/2014		7.7	SU
K-12	pH	3/20/2014		7.8	SU
K-12	pH	4/7/2014		7.4	SU
K-12	pH	5/21/2014		7.6	SU
K-12	pH	6/9/2014		7.6	SU
K-12	pH	7/16/2014		7.4	SU
K-12	pH	8/20/2014		7.1	SU
K-12	pH	9/22/2014		7.4	SU
K-12	pH	10/21/2014		7.3	SU
K-12	pH	11/17/2014		7.3	SU
K-12	pH	12/10/2014		7.7	SU
K-12	Total Suspended Solids	1/7/2014		1.7	MG/L
K-12	Total Suspended Solids	2/4/2014		6.5	MG/L
K-12	Total Suspended Solids	3/4/2014		5.5	MG/L
K-12	Total Suspended Solids	4/8/2014		3.3	MG/L
K-12	Total Suspended Solids	5/6/2014		2.8	MG/L
K-12	Total Suspended Solids	6/3/2014		2.2	MG/L
K-12	Total Suspended Solids	7/8/2014		4.0	MG/L
K-12	Total Suspended Solids	8/12/2014	<	1.0	MG/L
K-12	Total Suspended Solids	9/9/2014		4.0	MG/L
K-12	Total Suspended Solids	10/7/2014		2.5	MG/L
K-12	Total Suspended Solids	11/4/2014		5.2	MG/L

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
K-12	Total Suspended Solids	12/2/2014		3.4	MG/L
K-18	Flow	3/19/2014		944	GPM
K-18	Flow	6/4/2014		425	GPM
K-18	Flow	9/15/2014		544	GPM
K-18	Flow	10/6/2014		192	GPM
K-18	pH	3/19/2014		6.9	SU
K-18	pH	3/19/2014		6.9	SU
K-18	pH	6/4/2014		6.8	SU
K-18	pH	6/4/2014		7.0	SU
K-18	pH	9/15/2014		6.6	SU
K-18	pH	9/15/2014		6.6	SU
K-18	pH	10/6/2014		6.9	SU
K-18	Total Suspended Solids	3/20/2014		3.0	MG/L
K-18	Total Suspended Solids	6/5/2014		1.0	MG/L
K-18	Total Suspended Solids	6/5/2014		1.0	MG/L
K-18	Total Suspended Solids	9/15/2014		2.0	MG/L
K-18	Total Suspended Solids	10/7/2014		1.0	MG/L
L-07	Flow	1/6/2014		6,869.39	GPM
L-07	Flow	1/13/2014		6,564.08	GPM
L-07	Flow	1/21/2014		7,067.84	GPM
L-07	Flow	1/27/2014		6,365.63	GPM
L-07	Flow	2/3/2014		6,365.63	GPM
L-07	Flow	2/10/2014		6,472.49	GPM
L-07	Flow	2/18/2014		6,564.08	GPM
L-07	Flow	2/24/2014		5,129.14	GPM
L-07	Flow	3/3/2014		6,564.08	GPM
L-07	Flow	3/10/2014		5,373.39	GPM
L-07	Flow	3/17/2014		5,174.94	GPM
L-07	Flow	3/24/2014		5,571.84	GPM
L-07	Flow	3/31/2014		5,770.29	GPM
L-07	Flow	4/7/2014		5,770.29	GPM
L-07	Flow	4/14/2014		1,022.78	GPM
L-07	Flow	4/21/2014		1,022.78	GPM
L-07	Flow	4/28/2014		914.39	GPM
L-07	Flow	5/5/2014		610.61	GPM
L-07	Flow	5/12/2014		702.20	GPM
L-07	Flow	5/19/2014		682.36	GPM
L-07	Flow	5/27/2014		4,182.69	GPM
L-07	Flow	6/2/2014		7,800.57	GPM
L-07	Flow	6/9/2014		5,373.39	GPM
L-07	Flow	6/16/2014		6,915.18	GPM
L-07	Flow	6/23/2014		6,869.39	GPM
L-07	Flow	6/30/2014		5,968.73	GPM
L-07	Flow	7/7/2014		6,564.08	GPM
L-07	Flow	7/14/2014		6,365.63	GPM
L-07	Flow	7/21/2014		6,365.63	GPM
L-07	Flow	7/28/2014		6,365.63	GPM
L-07	Flow	8/4/2014		6,365.63	GPM
L-07	Flow	8/11/2014		6,472.49	GPM
L-07	Flow	8/18/2014		6,808.33	GPM
L-07	Flow	8/25/2014		6,564.08	GPM
L-07	Flow	9/2/2014		6,365.63	GPM
L-07	Flow	9/8/2014		6,472.49	GPM
L-07	Flow	9/15/2014		6,014.53	GPM
L-07	Flow	9/22/2014		6,869.39	GPM
L-07	Flow	9/29/2014		6,472.49	GPM
L-07	Flow	10/6/2014		6,670.94	GPM
L-07	Flow	10/13/2014		6,365.63	GPM
L-07	Flow	10/20/2014		6,716.73	GPM
L-07	Flow	10/27/2014		6,670.94	GPM
L-07	Flow	11/3/2014		7,800.57	GPM

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
L-07	Flow	11/10/2014		6,564.08	GPM
L-07	Flow	11/17/2014		6,472.49	GPM
L-07	Flow	11/24/2014		6,258.78	GPM
L-07	Flow	12/1/2014		6,365.63	GPM
L-07	Flow	12/8/2014		7,357.88	GPM
L-07	Flow	12/15/2014		6,258.78	GPM
L-07	Flow	12/22/2014		6,564.08	GPM
L-07	Flow	12/29/2014		6,762.53	GPM
L-07	pH	3/19/2014		7.0	SU
L-07	pH	3/19/2014		7.0	SU
L-07	pH	6/4/2014		6.9	SU
L-07	pH	6/4/2014		7.1	SU
L-07	pH	9/15/2014		7.3	SU
L-07	pH	9/15/2014		7.4	SU
L-07	pH	10/6/2014		7.1	SU
L-07	Total Suspended Solids	3/20/2014		2.0	MG/L
L-07	Total Suspended Solids	6/5/2014	<	1.0	MG/L
L-07	Total Suspended Solids	6/5/2014		1.0	MG/L
L-07	Total Suspended Solids	9/16/2014	<	1.0	MG/L
L-07	Total Suspended Solids	10/7/2014		1.0	MG/L
L-7A	Biochemical Oxygen Demand	1/7/2014	<	2.00	MG/L
L-7A	Biochemical Oxygen Demand	2/4/2014		2.11	MG/L
L-7A	Biochemical Oxygen Demand	3/4/2014	<	2.00	MG/L
L-7A	Biochemical Oxygen Demand	4/8/2014	<	2.00	MG/L
L-7A	Biochemical Oxygen Demand	5/7/2014	<	2.00	MG/L
L-7A	Biochemical Oxygen Demand	6/3/2014	<	2.00	MG/L
L-7A	Biochemical Oxygen Demand	7/8/2014		2.35	MG/L
L-7A	Biochemical Oxygen Demand	8/12/2014	<	2.00	MG/L
L-7A	Biochemical Oxygen Demand	9/9/2014	<	2.00	MG/L
L-7A	Biochemical Oxygen Demand	10/7/2014	<	2.00	MG/L
L-7A	Biochemical Oxygen Demand	11/4/2014	<	2.00	MG/L
L-7A	Biochemical Oxygen Demand	12/2/2014	<	2.00	MG/L
L-7A	Dissolved Oxygen	1/22/2014		7.75	MG/L
L-7A	Dissolved Oxygen	2/24/2014		8.52	MG/L
L-7A	Dissolved Oxygen	3/20/2014		7.08	MG/L
L-7A	Dissolved Oxygen	4/7/2014		5.43	MG/L
L-7A	Dissolved Oxygen	5/21/2014		4.72	MG/L
L-7A	Dissolved Oxygen	6/9/2014		4.54	MG/L
L-7A	Dissolved Oxygen	7/16/2014		5.35	MG/L
L-7A	Dissolved Oxygen	8/20/2014		4.32	MG/L
L-7A	Dissolved Oxygen	9/22/2014		5.37	MG/L
L-7A	Dissolved Oxygen	10/21/2014		4.82	MG/L
L-7A	Dissolved Oxygen	11/17/2014		5.71	MG/L
L-7A	Dissolved Oxygen	12/10/2014		6.67	MG/L
L-7A	Fecal Coliform	1/6/2014	<	2	COL/100ML
L-7A	Fecal Coliform	2/3/2014	<	2	COL/100ML
L-7A	Fecal Coliform	3/4/2014		30	COL/100ML
L-7A	Fecal Coliform	4/8/2014	<	2	COL/100ML
L-7A	Fecal Coliform	5/6/2014	<	2	COL/100ML
L-7A	Fecal Coliform	6/2/2014	<	2	COL/100ML
L-7A	Fecal Coliform	7/7/2014	<	2	COL/100ML
L-7A	Fecal Coliform	8/5/2014	<	2	COL/100ML
L-7A	Fecal Coliform	9/8/2014	<	2	COL/100ML
L-7A	Fecal Coliform	10/6/2014		14	COL/100ML
L-7A	Fecal Coliform	11/3/2014	<	2	COL/100ML
L-7A	Fecal Coliform	12/1/2014	<	2	COL/100ML
L-7A	Flow	1/1/2014		85	GPD
L-7A	Flow	1/2/2014		4,401	GPD
L-7A	Flow	1/3/2014		98	GPD
L-7A	Flow	1/4/2014		2,721	GPD
L-7A	Flow	1/5/2014		284	GPD
L-7A	Flow	1/6/2014		486	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
L-7A	Flow	1/7/2014		1,973	GPD
L-7A	Flow	1/8/2014		2,241	GPD
L-7A	Flow	1/9/2014		239	GPD
L-7A	Flow	1/10/2014		3,308	GPD
L-7A	Flow	1/11/2014		8,569	GPD
L-7A	Flow	1/12/2014		3,074	GPD
L-7A	Flow	1/13/2014		3,822	GPD
L-7A	Flow	1/14/2014		1,175	GPD
L-7A	Flow	1/15/2014		3,243	GPD
L-7A	Flow	1/16/2014		2,558	GPD
L-7A	Flow	1/17/2014		91	GPD
L-7A	Flow	1/18/2014		1,984	GPD
L-7A	Flow	1/19/2014		997	GPD
L-7A	Flow	1/20/2014		1,610	GPD
L-7A	Flow	1/21/2014		1,664	GPD
L-7A	Flow	1/22/2014		537	GPD
L-7A	Flow	1/23/2014		2,406	GPD
L-7A	Flow	1/24/2014		14	GPD
L-7A	Flow	1/25/2014		2,053	GPD
L-7A	Flow	1/26/2014		0	GPD
L-7A	Flow	1/27/2014		2,101	GPD
L-7A	Flow	1/28/2014		1,877	GPD
L-7A	Flow	1/29/2014		847	GPD
L-7A	Flow	1/30/2014		2,639	GPD
L-7A	Flow	1/31/2014		67	GPD
L-7A	Flow	2/1/2014		2,299	GPD
L-7A	Flow	2/2/2014		14	GPD
L-7A	Flow	2/3/2014		3,402	GPD
L-7A	Flow	2/4/2014		2,173	GPD
L-7A	Flow	2/5/2014		2,539	GPD
L-7A	Flow	2/6/2014		4,145	GPD
L-7A	Flow	2/7/2014		13	GPD
L-7A	Flow	2/8/2014		2	GPD
L-7A	Flow	2/9/2014		0	GPD
L-7A	Flow	2/10/2014		2,256	GPD
L-7A	Flow	2/11/2014		2,465	GPD
L-7A	Flow	2/12/2014		10,524	GPD
L-7A	Flow	2/13/2014		5,987	GPD
L-7A	Flow	2/14/2014		2,328	GPD
L-7A	Flow	2/15/2014		2,321	GPD
L-7A	Flow	2/16/2014		2,098	GPD
L-7A	Flow	2/17/2014		58	GPD
L-7A	Flow	2/18/2014		3,005	GPD
L-7A	Flow	2/19/2014		1,489	GPD
L-7A	Flow	2/20/2014		631	GPD
L-7A	Flow	2/21/2014		4,179	GPD
L-7A	Flow	2/22/2014		99	GPD
L-7A	Flow	2/23/2014		2,603	GPD
L-7A	Flow	2/24/2014		125	GPD
L-7A	Flow	2/25/2014		2,334	GPD
L-7A	Flow	2/26/2014		2,092	GPD
L-7A	Flow	2/27/2014		4	GPD
L-7A	Flow	2/28/2014		0	GPD
L-7A	Flow	3/1/2014		0	GPD
L-7A	Flow	3/2/2014		0	GPD
L-7A	Flow	3/3/2014		2,264	GPD
L-7A	Flow	3/4/2014		173	GPD
L-7A	Flow	3/5/2014		3,777	GPD
L-7A	Flow	3/6/2014		3,020	GPD
L-7A	Flow	3/7/2014		3,526	GPD
L-7A	Flow	3/8/2014		34	GPD
L-7A	Flow	3/9/2014		1,851	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
L-7A	Flow	3/10/2014		2,255	GPD
L-7A	Flow	3/11/2014		2,011	GPD
L-7A	Flow	3/12/2014		72	GPD
L-7A	Flow	3/13/2014		1,975	GPD
L-7A	Flow	3/14/2014		0	GPD
L-7A	Flow	3/15/2014		0	GPD
L-7A	Flow	3/16/2014		5,798	GPD
L-7A	Flow	3/17/2014		4,260	GPD
L-7A	Flow	3/18/2014		2,108	GPD
L-7A	Flow	3/19/2014		5,432	GPD
L-7A	Flow	3/20/2014		116	GPD
L-7A	Flow	3/21/2014		3,174	GPD
L-7A	Flow	3/22/2014		0	GPD
L-7A	Flow	3/23/2014		1,628	GPD
L-7A	Flow	3/24/2014		89	GPD
L-7A	Flow	3/25/2014		896	GPD
L-7A	Flow	3/26/2014		1,496	GPD
L-7A	Flow	3/27/2014		0	GPD
L-7A	Flow	3/28/2014		2,366	GPD
L-7A	Flow	3/29/2014		66	GPD
L-7A	Flow	3/30/2014		0	GPD
L-7A	Flow	3/31/2014		2,111	GPD
L-7A	Flow	4/1/2014		29	GPD
L-7A	Flow	4/2/2014		1,696	GPD
L-7A	Flow	4/3/2014		1,974	GPD
L-7A	Flow	4/4/2014		44	GPD
L-7A	Flow	4/5/2014		0	GPD
L-7A	Flow	4/6/2014		30	GPD
L-7A	Flow	4/7/2014		5,180	GPD
L-7A	Flow	4/8/2014		423	GPD
L-7A	Flow	4/9/2014		2,847	GPD
L-7A	Flow	4/10/2014		114	GPD
L-7A	Flow	4/11/2014		0	GPD
L-7A	Flow	4/12/2014		0	GPD
L-7A	Flow	4/13/2014		2,958	GPD
L-7A	Flow	4/14/2014		572	GPD
L-7A	Flow	4/15/2014		1,638	GPD
L-7A	Flow	4/16/2014		2,716	GPD
L-7A	Flow	4/17/2014		0	GPD
L-7A	Flow	4/18/2014		7,517	GPD
L-7A	Flow	4/19/2014		4,822	GPD
L-7A	Flow	4/20/2014		3,400	GPD
L-7A	Flow	4/21/2014		2,638	GPD
L-7A	Flow	4/22/2014		1,781	GPD
L-7A	Flow	4/23/2014		585	GPD
L-7A	Flow	4/24/2014		2,130	GPD
L-7A	Flow	4/25/2014		2	GPD
L-7A	Flow	4/26/2014		0	GPD
L-7A	Flow	4/27/2014		1,088	GPD
L-7A	Flow	4/28/2014		679	GPD
L-7A	Flow	4/29/2014		22	GPD
L-7A	Flow	4/30/2014		2,035	GPD
L-7A	Flow	5/1/2014		41	GPD
L-7A	Flow	5/2/2014		2	GPD
L-7A	Flow	5/3/2014		2,176	GPD
L-7A	Flow	5/4/2014		0	GPD
L-7A	Flow	5/5/2014		52	GPD
L-7A	Flow	5/6/2014		3,356	GPD
L-7A	Flow	5/7/2014		183	GPD
L-7A	Flow	5/8/2014		3,209	GPD
L-7A	Flow	5/9/2014		0	GPD
L-7A	Flow	5/10/2014		0	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
L-7A	Flow	5/11/2014		1,554	GPD
L-7A	Flow	5/12/2014		160	GPD
L-7A	Flow	5/13/2014		0	GPD
L-7A	Flow	5/14/2014		1,707	GPD
L-7A	Flow	5/15/2014		2,774	GPD
L-7A	Flow	5/16/2014		0	GPD
L-7A	Flow	5/17/2014		0	GPD
L-7A	Flow	5/18/2014		0	GPD
L-7A	Flow	5/19/2014		3,183	GPD
L-7A	Flow	5/20/2014		147	GPD
L-7A	Flow	5/21/2014		309	GPD
L-7A	Flow	5/22/2014		3,572	GPD
L-7A	Flow	5/23/2014		0	GPD
L-7A	Flow	5/24/2014		0	GPD
L-7A	Flow	5/25/2014		0	GPD
L-7A	Flow	5/26/2014		1,630	GPD
L-7A	Flow	5/27/2014		22	GPD
L-7A	Flow	5/28/2014		2,821	GPD
L-7A	Flow	5/29/2014		3,387	GPD
L-7A	Flow	5/30/2014		208	GPD
L-7A	Flow	5/31/2014		5,733	GPD
L-7A	Flow	6/1/2014		3,693	GPD
L-7A	Flow	6/2/2014		4,754	GPD
L-7A	Flow	6/3/2014		4,838	GPD
L-7A	Flow	6/4/2014		4,871	GPD
L-7A	Flow	6/5/2014		1,745	GPD
L-7A	Flow	6/6/2014		6,197	GPD
L-7A	Flow	6/7/2014		3,284	GPD
L-7A	Flow	6/8/2014		15,393	GPD
L-7A	Flow	6/9/2014		1,547	GPD
L-7A	Flow	6/10/2014		1,364	GPD
L-7A	Flow	6/11/2014		5,093	GPD
L-7A	Flow	6/12/2014		710	GPD
L-7A	Flow	6/13/2014		6,147	GPD
L-7A	Flow	6/14/2014		2,635	GPD
L-7A	Flow	6/15/2014		2,176	GPD
L-7A	Flow	6/16/2014		2,330	GPD
L-7A	Flow	6/17/2014		206	GPD
L-7A	Flow	6/18/2014		2,905	GPD
L-7A	Flow	6/19/2014		0	GPD
L-7A	Flow	6/20/2014		1,946	GPD
L-7A	Flow	6/21/2014		0	GPD
L-7A	Flow	6/22/2014		0	GPD
L-7A	Flow	6/23/2014		1,743	GPD
L-7A	Flow	6/24/2014		3,680	GPD
L-7A	Flow	6/25/2014		4,115	GPD
L-7A	Flow	6/26/2014		2,502	GPD
L-7A	Flow	6/27/2014		1,907	GPD
L-7A	Flow	6/28/2014		2,434	GPD
L-7A	Flow	6/29/2014		3	GPD
L-7A	Flow	6/30/2014		2,386	GPD
L-7A	Flow	7/1/2014		1,974	GPD
L-7A	Flow	7/2/2014		2,457	GPD
L-7A	Flow	7/3/2014		1	GPD
L-7A	Flow	7/4/2014		0	GPD
L-7A	Flow	7/5/2014		1,777	GPD
L-7A	Flow	7/6/2014		0	GPD
L-7A	Flow	7/7/2014		2,674	GPD
L-7A	Flow	7/8/2014		2,238	GPD
L-7A	Flow	7/9/2014		1,676	GPD
L-7A	Flow	7/10/2014		223	GPD
L-7A	Flow	7/11/2014		2,671	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
L-7A	Flow	7/12/2014		2,055	GPD
L-7A	Flow	7/13/2014		0	GPD
L-7A	Flow	7/14/2014		2,516	GPD
L-7A	Flow	7/15/2014		1,670	GPD
L-7A	Flow	7/16/2014		251	GPD
L-7A	Flow	7/17/2014		8	GPD
L-7A	Flow	7/18/2014		2,539	GPD
L-7A	Flow	7/19/2014		52	GPD
L-7A	Flow	7/20/2014		0	GPD
L-7A	Flow	7/21/2014		2,574	GPD
L-7A	Flow	7/22/2014		2,209	GPD
L-7A	Flow	7/23/2014		2,091	GPD
L-7A	Flow	7/24/2014		9	GPD
L-7A	Flow	7/25/2014		4,832	GPD
L-7A	Flow	7/26/2014		3,725	GPD
L-7A	Flow	7/27/2014		100	GPD
L-7A	Flow	7/28/2014		2,056	GPD
L-7A	Flow	7/29/2014		1,955	GPD
L-7A	Flow	7/30/2014		2,294	GPD
L-7A	Flow	7/31/2014		0	GPD
L-7A	Flow	8/1/2014		2,100	GPD
L-7A	Flow	8/2/2014		216	GPD
L-7A	Flow	8/3/2014		1,924	GPD
L-7A	Flow	8/4/2014		2,278	GPD
L-7A	Flow	8/5/2014		264	GPD
L-7A	Flow	8/6/2014		2,624	GPD
L-7A	Flow	8/7/2014		18	GPD
L-7A	Flow	8/8/2014		400	GPD
L-7A	Flow	8/9/2014		3,399	GPD
L-7A	Flow	8/10/2014		2,180	GPD
L-7A	Flow	8/11/2014		2,402	GPD
L-7A	Flow	8/12/2014		1,410	GPD
L-7A	Flow	8/13/2014		2,180	GPD
L-7A	Flow	8/14/2014		1,894	GPD
L-7A	Flow	8/15/2014		0	GPD
L-7A	Flow	8/16/2014		39	GPD
L-7A	Flow	8/17/2014		2,567	GPD
L-7A	Flow	8/18/2014		51	GPD
L-7A	Flow	8/19/2014		2,304	GPD
L-7A	Flow	8/20/2014		351	GPD
L-7A	Flow	8/21/2014		0	GPD
L-7A	Flow	8/22/2014		2,128	GPD
L-7A	Flow	8/23/2014		4	GPD
L-7A	Flow	8/24/2014		707	GPD
L-7A	Flow	8/25/2014		44	GPD
L-7A	Flow	8/26/2014		2,238	GPD
L-7A	Flow	8/27/2014		2,902	GPD
L-7A	Flow	8/28/2014		37	GPD
L-7A	Flow	8/29/2014		0	GPD
L-7A	Flow	8/30/2014		2,057	GPD
L-7A	Flow	8/31/2014		2,108	GPD
L-7A	Flow	9/1/2014		2	GPD
L-7A	Flow	9/2/2014		2,200	GPD
L-7A	Flow	9/3/2014		43	GPD
L-7A	Flow	9/4/2014		2,942	GPD
L-7A	Flow	9/5/2014		1,773	GPD
L-7A	Flow	9/6/2014		1,826	GPD
L-7A	Flow	9/7/2014		191	GPD
L-7A	Flow	9/8/2014		2,704	GPD
L-7A	Flow	9/9/2014		518	GPD
L-7A	Flow	9/10/2014		971	GPD
L-7A	Flow	9/11/2014		4,999	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
L-7A	Flow	9/12/2014		1	GPD
L-7A	Flow	9/13/2014		7	GPD
L-7A	Flow	9/14/2014		1,072	GPD
L-7A	Flow	9/15/2014		1,093	GPD
L-7A	Flow	9/16/2014		24	GPD
L-7A	Flow	9/17/2014		2,394	GPD
L-7A	Flow	9/18/2014		41	GPD
L-7A	Flow	9/19/2014		6	GPD
L-7A	Flow	9/20/2014		2,349	GPD
L-7A	Flow	9/21/2014		84	GPD
L-7A	Flow	9/22/2014		817	GPD
L-7A	Flow	9/23/2014		134	GPD
L-7A	Flow	9/24/2014		3,698	GPD
L-7A	Flow	9/25/2014		116	GPD
L-7A	Flow	9/26/2014		2,977	GPD
L-7A	Flow	9/27/2014		106	GPD
L-7A	Flow	9/28/2014		88	GPD
L-7A	Flow	9/29/2014		1,837	GPD
L-7A	Flow	9/30/2014		1,993	GPD
L-7A	Flow	10/1/2014		2,856	GPD
L-7A	Flow	10/2/2014		150	GPD
L-7A	Flow	10/3/2014		1	GPD
L-7A	Flow	10/4/2014		1,008	GPD
L-7A	Flow	10/5/2014		0	GPD
L-7A	Flow	10/6/2014		1,268	GPD
L-7A	Flow	10/7/2014		1,438	GPD
L-7A	Flow	10/8/2014		2,657	GPD
L-7A	Flow	10/9/2014		237	GPD
L-7A	Flow	10/10/2014		25	GPD
L-7A	Flow	10/11/2014		1,312	GPD
L-7A	Flow	10/12/2014		0	GPD
L-7A	Flow	10/13/2014		1,297	GPD
L-7A	Flow	10/14/2014		1,531	GPD
L-7A	Flow	10/15/2014		1,528	GPD
L-7A	Flow	10/16/2014		1,860	GPD
L-7A	Flow	10/17/2014		1,805	GPD
L-7A	Flow	10/18/2014		0	GPD
L-7A	Flow	10/19/2014		0	GPD
L-7A	Flow	10/20/2014		1,855	GPD
L-7A	Flow	10/21/2014		249	GPD
L-7A	Flow	10/22/2014		0	GPD
L-7A	Flow	10/23/2014		3,808	GPD
L-7A	Flow	10/24/2014		4	GPD
L-7A	Flow	10/25/2014		0	GPD
L-7A	Flow	10/26/2014		0	GPD
L-7A	Flow	10/27/2014		2,353	GPD
L-7A	Flow	10/28/2014		100	GPD
L-7A	Flow	10/29/2014		3,078	GPD
L-7A	Flow	10/30/2014		3,588	GPD
L-7A	Flow	10/31/2014		90	GPD
L-7A	Flow	11/1/2014		129	GPD
L-7A	Flow	11/2/2014		67	GPD
L-7A	Flow	11/3/2014		8,679	GPD
L-7A	Flow	11/4/2014		12,325	GPD
L-7A	Flow	11/5/2014		3,822	GPD
L-7A	Flow	11/6/2014		341	GPD
L-7A	Flow	11/7/2014		133	GPD
L-7A	Flow	11/8/2014		209	GPD
L-7A	Flow	11/9/2014		783	GPD
L-7A	Flow	11/10/2014		1,527	GPD
L-7A	Flow	11/11/2014		4	GPD
L-7A	Flow	11/12/2014		2,246	GPD

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
L-7A	Flow	11/13/2014		192	GPD
L-7A	Flow	11/14/2014		3,451	GPD
L-7A	Flow	11/15/2014		53	GPD
L-7A	Flow	11/16/2014		31	GPD
L-7A	Flow	11/17/2014		531	GPD
L-7A	Flow	11/18/2014		0	GPD
L-7A	Flow	11/19/2014		2,929	GPD
L-7A	Flow	11/20/2014		9	GPD
L-7A	Flow	11/21/2014		0	GPD
L-7A	Flow	11/22/2014		0	GPD
L-7A	Flow	11/23/2014		4,931	GPD
L-7A	Flow	11/24/2014		2,728	GPD
L-7A	Flow	11/25/2014		3,615	GPD
L-7A	Flow	11/26/2014		5,428	GPD
L-7A	Flow	11/27/2014		356	GPD
L-7A	Flow	11/28/2014		5,199	GPD
L-7A	Flow	11/29/2014		3,295	GPD
L-7A	Flow	11/30/2014		1,246	GPD
L-7A	Flow	12/1/2014		2,670	GPD
L-7A	Flow	12/2/2014		1,149	GPD
L-7A	Flow	12/3/2014		2,343	GPD
L-7A	Flow	12/4/2014		3,261	GPD
L-7A	Flow	12/5/2014		18	GPD
L-7A	Flow	12/6/2014		27	GPD
L-7A	Flow	12/7/2014		25	GPD
L-7A	Flow	12/8/2014		3,286	GPD
L-7A	Flow	12/9/2014		95	GPD
L-7A	Flow	12/10/2014		508	GPD
L-7A	Flow	12/11/2014		1,198	GPD
L-7A	Flow	12/12/2014		6,520	GPD
L-7A	Flow	12/13/2014		121	GPD
L-7A	Flow	12/14/2014		102	GPD
L-7A	Flow	12/15/2014		134	GPD
L-7A	Flow	12/16/2014		4,196	GPD
L-7A	Flow	12/17/2014		534	GPD
L-7A	Flow	12/18/2014		1,029	GPD
L-7A	Flow	12/19/2014		827	GPD
L-7A	Flow	12/20/2014		1,347	GPD
L-7A	Flow	12/21/2014		7,505	GPD
L-7A	Flow	12/22/2014		3,266	GPD
L-7A	Flow	12/23/2014		13,707	GPD
L-7A	Flow	12/24/2014		26,309	GPD
L-7A	Flow	12/25/2014		4,303	GPD
L-7A	Flow	12/26/2014		2,801	GPD
L-7A	Flow	12/27/2014		4,549	GPD
L-7A	Flow	12/28/2014		10	GPD
L-7A	Flow	12/29/2014		1,388	GPD
L-7A	Flow	12/30/2014		6	GPD
L-7A	Flow	12/31/2014		0	GPD
L-7A	pH	1/22/2014		7.2	SU
L-7A	pH	2/24/2014		7.9	SU
L-7A	pH	3/20/2014		7.2	SU
L-7A	pH	4/7/2014		7.5	SU
L-7A	pH	5/21/2014		7.3	SU
L-7A	pH	6/9/2014		7.3	SU
L-7A	pH	7/16/2014		7.5	SU
L-7A	pH	8/20/2014		8.0	SU
L-7A	pH	9/22/2014		7.8	SU
L-7A	pH	10/21/2014		7.1	SU
L-7A	pH	11/17/2014		7.8	SU
L-7A	pH	12/10/2014		8.2	SU
L-7A	Total Suspended Solids	1/7/2014		13.0	MG/L

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
L-7A	Total Suspended Solids	2/4/2014		5.0	MG/L
L-7A	Total Suspended Solids	3/4/2014		6.9	MG/L
L-7A	Total Suspended Solids	4/8/2014		3.3	MG/L
L-7A	Total Suspended Solids	5/7/2014		2.2	MG/L
L-7A	Total Suspended Solids	6/3/2014		6.7	MG/L
L-7A	Total Suspended Solids	7/8/2014		2.0	MG/L
L-7A	Total Suspended Solids	8/12/2014		3.5	MG/L
L-7A	Total Suspended Solids	9/9/2014		8.3	MG/L
L-7A	Total Suspended Solids	10/7/2014		12.6	MG/L
L-7A	Total Suspended Solids	11/4/2014		3.9	MG/L
L-7A	Total Suspended Solids	12/2/2014		9.8	MG/L
M-05	Flow	1/2/2014		400	GPM
M-05	Flow	1/5/2014		400	GPM
M-05	Flow	1/6/2014		500	GPM
M-05	Flow	1/7/2014		0	GPM
M-05	Flow	1/8/2014		0	GPM
M-05	Flow	1/9/2014		400	GPM
M-05	Flow	1/13/2014		410	GPM
M-05	Flow	1/14/2014		410	GPM
M-05	Flow	1/15/2014		410	GPM
M-05	Flow	1/16/2014		410	GPM
M-05	Flow	1/20/2014		460	GPM
M-05	Flow	1/21/2014		440	GPM
M-05	Flow	1/22/2014		0	GPM
M-05	Flow	1/23/2014		440	GPM
M-05	Flow	1/27/2014		440	GPM
M-05	Flow	1/28/2014		440	GPM
M-05	Flow	1/30/2014		0	GPM
M-05	Flow	2/3/2014		0	GPM
M-05	Flow	2/4/2014		0	GPM
M-05	Flow	2/5/2014		0	GPM
M-05	Flow	2/6/2014		0	GPM
M-05	Flow	2/10/2014		440	GPM
M-05	Flow	2/11/2014		450	GPM
M-05	Flow	2/15/2014		450	GPM
M-05	Flow	2/16/2014		450	GPM
M-05	Flow	2/18/2014		440	GPM
M-05	Flow	2/19/2014		440	GPM
M-05	Flow	2/20/2014		440	GPM
M-05	Flow	2/21/2014		440	GPM
M-05	Flow	2/24/2014		450	GPM
M-05	Flow	2/25/2014		450	GPM
M-05	Flow	2/26/2014		450	GPM
M-05	Flow	2/27/2014		450	GPM
M-05	Flow	3/3/2014		440	GPM
M-05	Flow	3/4/2014		440	GPM
M-05	Flow	3/5/2014		450	GPM
M-05	Flow	3/6/2014		450	GPM
M-05	Flow	3/10/2014		450	GPM
M-05	Flow	3/11/2014		450	GPM
M-05	Flow	3/12/2014		450	GPM
M-05	Flow	3/13/2014		450	GPM
M-05	Flow	3/17/2014		450	GPM
M-05	Flow	3/18/2014		400	GPM
M-05	Flow	3/19/2014		410	GPM
M-05	Flow	3/20/2014		410	GPM
M-05	Flow	3/24/2014		400	GPM
M-05	Flow	3/25/2014		400	GPM
M-05	Flow	3/26/2014		400	GPM
M-05	Flow	3/27/2014		400	GPM
M-05	Flow	3/31/2014		400	GPM
M-05	Flow	4/1/2014		400	GPM

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
M-05	Flow	4/2/2014		400	GPM
M-05	Flow	4/3/2014		400	GPM
M-05	Flow	4/7/2014		440	GPM
M-05	Flow	4/8/2014		440	GPM
M-05	Flow	4/9/2014		440	GPM
M-05	Flow	4/10/2014		440	GPM
M-05	Flow	4/14/2014		440	GPM
M-05	Flow	4/15/2014		440	GPM
M-05	Flow	4/16/2014		440	GPM
M-05	Flow	4/17/2014		440	GPM
M-05	Flow	4/21/2014		430	GPM
M-05	Flow	4/22/2014		0	GPM
M-05	Flow	4/23/2014		0	GPM
M-05	Flow	4/24/2014		430	GPM
M-05	Flow	4/28/2014		440	GPM
M-05	Flow	4/29/2014		440	GPM
M-05	Flow	4/30/2014		440	GPM
M-05	Flow	5/5/2014		440	GPM
M-05	Flow	5/6/2014		440	GPM
M-05	Flow	5/7/2014		440	GPM
M-05	Flow	5/8/2014		440	GPM
M-05	Flow	5/5/2014		440	GPM
M-05	Flow	5/6/2014		430	GPM
M-05	Flow	5/7/2014		440	GPM
M-05	Flow	5/8/2014		440	GPM
M-05	Flow	5/5/2014		440	GPM
M-05	Flow	5/6/2014		440	GPM
M-05	Flow	5/7/2014		440	GPM
M-05	Flow	5/8/2014		440	GPM
M-05	Flow	5/5/2014		440	GPM
M-05	Flow	5/6/2014		440	GPM
M-05	Flow	5/7/2014		440	GPM
M-05	Flow	5/8/2014		440	GPM
M-05	Flow	6/2/2014		440	GPM
M-05	Flow	6/3/2014		440	GPM
M-05	Flow	6/4/2014		440	GPM
M-05	Flow	6/5/2014		440	GPM
M-05	Flow	6/9/2014		440	GPM
M-05	Flow	6/10/2014		440	GPM
M-05	Flow	6/11/2014		440	GPM
M-05	Flow	6/12/2014		480	GPM
M-05	Flow	6/16/2014		440	GPM
M-05	Flow	6/17/2014		440	GPM
M-05	Flow	6/18/2014		440	GPM
M-05	Flow	6/19/2014		440	GPM
M-05	Flow	6/23/2014		440	GPM
M-05	Flow	6/24/2014		0	GPM
M-05	Flow	6/25/2014		440	GPM
M-05	Flow	6/26/2014		440	GPM
M-05	Flow	6/30/2014		435	GPM
M-05	Flow	7/1/2014		440	GPM
M-05	Flow	7/2/2014		440	GPM
M-05	Flow	7/3/2014		440	GPM
M-05	Flow	7/7/2014		440	GPM
M-05	Flow	7/8/2014		440	GPM
M-05	Flow	7/9/2014		440	GPM
M-05	Flow	7/10/2014		440	GPM
M-05	Flow	7/14/2014		440	GPM
M-05	Flow	7/15/2014		440	GPM
M-05	Flow	7/16/2014		440	GPM
M-05	Flow	7/17/2014		440	GPM
M-05	Flow	7/21/2014		440	GPM

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
M-05	Flow	7/22/2014		380	GPM
M-05	Flow	7/23/2014		380	GPM
M-05	Flow	7/24/2014		380	GPM
M-05	Flow	7/28/2014		440	GPM
M-05	Flow	7/29/2014		440	GPM
M-05	Flow	7/30/2014		440	GPM
M-05	Flow	7/31/2014		440	GPM
M-05	Flow	8/4/2014		440	GPM
M-05	Flow	8/5/2014		440	GPM
M-05	Flow	8/6/2014		440	GPM
M-05	Flow	8/7/2014		440	GPM
M-05	Flow	8/11/2014		440	GPM
M-05	Flow	8/12/2014		440	GPM
M-05	Flow	8/13/2014		440	GPM
M-05	Flow	8/14/2014		445	GPM
M-05	Flow	8/18/2014		440	GPM
M-05	Flow	8/19/2014		440	GPM
M-05	Flow	8/20/2014		440	GPM
M-05	Flow	8/21/2014		440	GPM
M-05	Flow	8/25/2014		440	GPM
M-05	Flow	8/26/2014		440	GPM
M-05	Flow	8/27/2014		440	GPM
M-05	Flow	8/28/2014		440	GPM
M-05	Flow	9/2/2014		440	GPM
M-05	Flow	9/3/2014		440	GPM
M-05	Flow	9/4/2014		440	GPM
M-05	Flow	9/5/2014		440	GPM
M-05	Flow	9/8/2014		480	GPM
M-05	Flow	9/9/2014		440	GPM
M-05	Flow	9/10/2014		440	GPM
M-05	Flow	9/11/2014		440	GPM
M-05	Flow	9/15/2014		440	GPM
M-05	Flow	9/16/2014		440	GPM
M-05	Flow	9/17/2014		400	GPM
M-05	Flow	9/18/2014		400	GPM
M-05	Flow	9/22/2014		440	GPM
M-05	Flow	9/23/2014		440	GPM
M-05	Flow	9/24/2014		440	GPM
M-05	Flow	9/25/2014		440	GPM
M-05	Flow	9/29/2014		440	GPM
M-05	Flow	9/30/2014		440	GPM
M-05	Flow	10/1/2014		440	GPM
M-05	Flow	10/2/2014		440	GPM
M-05	Flow	10/6/2014		440	GPM
M-05	Flow	10/7/2014		340	GPM
M-05	Flow	10/8/2014		320	GPM
M-05	Flow	10/9/2014		320	GPM
M-05	Flow	10/13/2014		320	GPM
M-05	Flow	10/14/2014		320	GPM
M-05	Flow	10/15/2014		320	GPM
M-05	Flow	10/16/2014		320	GPM
M-05	Flow	10/20/2014		300	GPM
M-05	Flow	10/21/2014		300	GPM
M-05	Flow	10/22/2014		300	GPM
M-05	Flow	10/23/2014		300	GPM
M-05	Flow	10/27/2014		300	GPM
M-05	Flow	10/28/2014		310	GPM
M-05	Flow	10/29/2014		310	GPM
M-05	Flow	10/30/2014		310	GPM
M-05	Flow	11/3/2014		300	GPM
M-05	Flow	11/4/2014		440	GPM
M-05	Flow	11/5/2014		440	GPM

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters	GPM-gallons per minute	NF-no flow			
°F-degrees Fahrenheit	MG/L-milligrams per liter	SU- standard units			
GPD-gallons per day	MGD-million gallons per day	mG/L-micrograms per liter			
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
M-05	Flow	11/6/2014		440	GPM
M-05	Flow	11/10/2014		440	GPM
M-05	Flow	11/11/2014		440	GPM
M-05	Flow	11/12/2014		440	GPM
M-05	Flow	11/13/2014		440	GPM
M-05	Flow	11/17/2014		420	GPM
M-05	Flow	11/18/2014		420	GPM
M-05	Flow	11/19/2014		400	GPM
M-05	Flow	11/20/2014		400	GPM
M-05	Flow	11/24/2014		400	GPM
M-05	Flow	11/25/2014		400	GPM
M-05	Flow	11/26/2014		400	GPM
M-05	Flow	11/28/2014		400	GPM
M-05	Flow	12/1/2014		400	GPM
M-05	Flow	12/2/2014		400	GPM
M-05	Flow	12/3/2014		400	GPM
M-05	Flow	12/4/2014		400	GPM
M-05	Flow	12/8/2014		400	GPM
M-05	Flow	12/9/2014		400	GPM
M-05	Flow	12/10/2014		400	GPM
M-05	Flow	12/11/2014		400	GPM
M-05	Flow	12/15/2014		400	GPM
M-05	Flow	12/16/2014		400	GPM
M-05	Flow	12/17/2014		400	GPM
M-05	Flow	12/18/2014		400	GPM
M-05	Flow	12/22/2014		400	GPM
M-05	Flow	12/23/2014		400	GPM
M-05	Flow	12/24/2014		390	GPM
M-05	Flow	12/25/2014		400	GPM
M-05	Flow	12/29/2014		390	GPM
M-05	Flow	12/30/2014		380	GPM
M-05	Flow	12/31/2014		380	GPM
M-05	Tetrachloroethylene	1/15/2014	<	2.0	mG/L
M-05	Tetrachloroethylene	2/10/2014	<	2.0	mG/L
M-05	Tetrachloroethylene	3/11/2014	<	2.0	mG/L
M-05	Tetrachloroethylene	3/11/2014	<	2.0	mG/L
M-05	Tetrachloroethylene	4/1/2014	<	2.0	mG/L
M-05	Tetrachloroethylene	5/6/2014	<	2.0	mG/L
M-05	Tetrachloroethylene	6/9/2014	<	2.0	mG/L
M-05	Tetrachloroethylene	6/9/2014	<	2.0	mG/L
M-05	Tetrachloroethylene	7/21/2014	<	2.0	mG/L
M-05	Tetrachloroethylene	8/12/2014	<	2.0	mG/L
M-05	Tetrachloroethylene	9/9/14 ^c		INVALID	mG/L
M-05	Tetrachloroethylene	9/30/2014	<	2.0	mG/L
M-05	Tetrachloroethylene	10/8/2014	<	2.0	mG/L
M-05	Tetrachloroethylene	11/4/2014	<	2.0	mG/L
M-05	Tetrachloroethylene	12/10/2014	<	2.0	mG/L
M-05	Trichloroethylene	1/15/2014	<	2.0	mG/L
M-05	Trichloroethylene	2/10/2014	<	2.0	mG/L
M-05	Trichloroethylene	3/11/2014	<	2.0	mG/L
M-05	Trichloroethylene	3/11/2014	<	2.0	mG/L
M-05	Trichloroethylene	4/1/2014	<	2.0	mG/L
M-05	Trichloroethylene	5/6/2014	<	2.0	mG/L
M-05	Trichloroethylene	6/9/2014	<	2.0	mG/L
M-05	Trichloroethylene	6/9/2014	<	2.0	mG/L
M-05	Trichloroethylene	7/21/2014	<	2.0	mG/L
M-05	Trichloroethylene	8/12/2014	<	2.0	mG/L
M-05	Trichloroethylene	9/9/14 ^c		INVALID	mG/L
M-05	Trichloroethylene	9/30/2014	<	2.0	mG/L
M-05	Trichloroethylene	10/8/2014	<	2.0	mG/L
M-05	Trichloroethylene	11/4/2014	<	2.0	mG/L
M-05	Trichloroethylene	12/10/2014	<	2.0	mG/L

2014 National Pollutant Discharge Elimination System Industrial Wastewater Monitoring Data

Abbreviations					
COL/100ML-colonies per 100 milliliters		GPM-gallons per minute		NF-no flow	
°F-degrees Fahrenheit		MG/L-milligrams per liter		SU- standard units	
GPD-gallons per day		MGD-million gallons per day		mG/L-micrograms per liter	
Outfall ID	Parameter	Collection Date (Grab or 24-Hrs Composite)	Less Than (<)	Result	Unit
S-04 was rendered incapable of discharge in July 2007; no further discharges can be made. The following parameters were measured when a sample was collected at S-04: Copper, Flow, Lead, Manganese, Nickel, pH and Zinc. Since there was no flow from S-04 during 2014, no sample was collected.					
X-8C was rendered incapable of discharge in November 2013; no further discharges can be made. The following parameters were measured when a sample was collected at X-8C: Flow, Manganese, Tetrachloroethylene and Trichloroethylene. Since there was no flow from X-8C during 2014, no sample was collected.					